

SUBCHAPTER 28. CARBON MONOXIDE  
ALARMS**Authority**

P.L. 1999, c.15, section 6; and N.J.S.A. 52:27D-133.4.

**Source and Effective Date**

R.1999 d.259, effective August 16, 1999.  
See: 31 N.J.R. 825(a), 31 N.J.R. 2330(a).

**5:10-28.1 Carbon monoxide alarms**

(a) Carbon monoxide alarms shall be installed and maintained in full operating condition in the following locations:

1. Single station carbon monoxide alarms shall be installed and maintained in the immediate vicinity of the sleeping area in every guestroom or dwelling unit in buildings that contain a fuel-burning appliance or that have an attached garage.

2. As an alternative to the requirements in (a)1 above, carbon monoxide alarms may be installed in the locations specified in the Uniform Construction Code (N.J.A.C. 5:23-3.20) with the approval of the Bureau.

(b) Carbon monoxide alarms shall be manufactured, listed and labeled in accordance with UL 2034 and shall be installed in accordance with the requirements of this subchapter and NFPA 720. Carbon monoxide alarms shall be battery operated, hard-wired or of the plug-in type.