

5:18-1.3 Compliance

(a) All liquefied petroleum gas systems shall be installed and maintained in a safe operating condition in accordance with these rules.

(b) Zoning considerations shall be the responsibility of the municipality in which the system is located.

(c) All buildings or structures housing liquefied petroleum systems and foundations for containers shall be constructed in accordance with the applicable provisions of the Uniform Construction Code, N.J.A.C. 5:23.

(d) Only a qualified person shall sell, fill, or refill liquefied petroleum gas at a dispensing or distributing point.

(e) No person shall install, remove, connect, disconnect, fill or refill any liquefied petroleum gas container without permission of the owner of the container.

1. Exception: Containers at one or two-family residential properties may be disconnected and moved provided that the qualified person removing the container secures the fill line, gauge openings, fuel lines and pump connections against tampering and leaves the container in a safe and secure location.

(f) The owner of an LP-Gas container found to be in a hazardous condition shall remove the container from the site as soon as possible or necessary, but in no case later than five working days of written notification by the Bureau.

(g) The Commissioner may order the owner or operator of a system to meet additional requirements:

1. Where unusual conditions exist; and
2. When it is necessary for the protection of the health, safety or welfare of persons.

(h) LP-Gas systems having a product vapor pressure greater than that allowed in the referenced standards for commercial propane, with the product measured at 100 degrees Fahrenheit, shall be subject to the approval of the Commissioner.

(i) When liquefied petroleum gas equipment is to be abandoned or temporarily placed out of service, the user/owner shall comply with the provisions of Section F-3608.0, Abandonment of Equipment, of the Fire Prevention Code, N.J.A.C. 5:70-3.

(j) Any person seeking a waiver or modification of any requirement set forth in this chapter in a specific situation where strict adherence to the requirement poses a hardship, or where technological advances allow an alternative that provides equivalent protection, may submit a request for such waiver or modification to the Bureau Chief. The application shall include a statement that explains why strict adherence to the rules would be problematic, or why an alternative would

be appropriate, and a statement that documents that the alternative(s) requested would be consistent with the intent of the Act and of this chapter and would not result in any increased health or safety risk. The Bureau Chief may grant any such waiver or modification only upon a finding that doing so would not result in any increased health or safety risk and would be consistent with the intent of the Act and of this chapter.

Amended by R.1990 d.436, effective September 4, 1990.
See: 22 N.J.R. 1984(a), 22 N.J.R. 2744(a).

Recodified from N.J.A.C. 12:200-1.8. Prior N.J.A.C. 12:200-1.3 was "Scope," which was recodified as N.J.A.C. 12:200-1.1.

Deleted old (j) and (k) regarding specific containers and distance requirements, recodifying old (l) as new (j) and adding new (k). In (e), deleted reference to systems utilizing containers of over 30 pounds product capacity and added "at a dispensing or distributing point."

Amended by R.1995 d.391, effective July 17, 1995.

See: 27 N.J.R. 1950(a), 27 N.J.R. 2694(b).

Amended by R.2003 d.200, effective May 19, 2003.

See: 35 N.J.R. 7(a), 35 N.J.R. 2187(a).

Rewrote the section.

Amended by R.2003 d.455, effective December 1, 2003.

See: 35 N.J.R. 3474(a), 35 N.J.R. 5371(b).

Added (j).

5:18-1.4 Registration

(a) All existing LPG systems of greater than 2,000 gallons water capacity vapor delivery service, all liquid withdrawal systems and all fill plants shall be registered by the owner with the Bureau.

1. The submission of plans pursuant to N.J.A.C. 5:18-6.1 shall be accepted as satisfying the registration requirement.

(b) When there is a change in the ownership of an existing LPG system, the new owner shall register with the Bureau within ten business days of the change in ownership.

(c) All LP-Gas facilities, including producers, bulk plants and industrial plants of 10,000 gallons water capacity or more, gas utility plants, marine or pipeline terminals or tank farms, shall be registered with the Bureau in accordance with N.J.A.C. 5:18-9.1.

New Rule, R.2003 d.200, effective May 19, 2003.

See: 35 N.J.R. 7(a), 35 N.J.R. 2187(a).

Former N.J.A.C. 5:18-1.4, Reporting emergency situations, recodified to N.J.A.C. 5:18-1.7.

5:18-1.5 Inspection of LPG systems by the Bureau

(a) All LPG systems of greater than 2,000 gallons water capacity vapor delivery service, all liquid withdrawal service systems and all fill plants shall be inspected annually by the Bureau, with the exception of LPG systems meeting the requirements of N.J.A.C. 5:18-9, which shall be subject to a triennial audit, and those subject to local inspection, as set forth in N.J.A.C. 5:18-1.2(c).

(b) Upon successful completion of an initial inspection by the Bureau, a site-specific certificate of operation shall be issued.

(c) The certificate of operation shall indicate that the LPG system is in compliance with the applicable requirements of this chapter and shall be posted at a conspicuous location where representatives of the Bureau and members of the public may inspect it.

(d) Failure to remove any violations found as a result of an inspection made by the Bureau shall result in issuance of a written notice to abate the violations. Correction of violations shall be done in accordance with N.J.A.C. 5:18-7.3.

Recodified from N.J.A.C. 12:200-1.10 by R.1990 d.436, effective September 4, 1990.

See: 22 N.J.R. 1984(a), 22 N.J.R. 2744(a).

Prior N.J.A.C. 12:200-1.5 was "Repeal of prior chapters."

Amended by R.1995 d.391, effective July 17, 1995.

See: 27 N.J.R. 1950(a), 27 N.J.R. 2694(b).

Repeal and New Rule, R.2003 d.200, effective May 19, 2003.

See: 35 N.J.R. 7(a), 35 N.J.R. 2187(a).

Section was "Reporting of fires, explosions or accidents".

5:18-1.6 Container markings

(a) Containers of 100 pounds product capacity or more shall be legibly marked "FLAMMABLE GAS" and the name of the gas to indicate contents, such as "FLAMMABLE GAS—PROPANE" or "FLAMMABLE GAS—BUTANE," except as provided in (b) below. Compliance with the marking requirements of Title 49 of the Code of Federal Regulations shall be accepted as meeting this requirement.

1. Exception: Container marking shall not be required for containers at one or two-family residential properties.

(b) A company identification system for marking containers which is approved by the Commissioner shall be acceptable in lieu of compliance with (a) above at processing plants.

(c) As required by N.J.A.C. 5:11, all ASME containers shall be stamped with the National Board number. The number shall be readily visible on the container shell or head and shall not be concealed by paint or otherwise. The National Board registration number shall be affixed at all times for inspection purposes. The stamping may be affixed to a metal tag or shall otherwise be permanently marked in lettering of not less than 5/16 of an inch in height.

(d) All LP-Gas containers exceeding 250 gallons individual or aggregate water capacity shall be provided with a marker plate or sign indicating who should be called in the event of an emergency involving the LP-Gas container. The marker or sign shall have lettering not less than one inch high and the lettering shall contrast in color with the background of the LP-Gas container. The marker or sign shall include the following:

1. The name of the LP-Gas supplier, owner or operator who will respond to the emergency; and

2. That person's telephone number.

(e) Prior to filling any cylinder of four to 40 pounds LP-Gas capacity, except fork lift cylinders, the operator of the fill plant or distribution plant shall affix a label to the collar of the cylinder that includes the following warning printed in English and in Spanish: "Flammable Gas—Never Use or Store Indoors/Gas Inflammable—Nunca Se Use o Guarde Adentro."

Repealed by R.1990 d.436, effective September 4, 1990.

See: 22 N.J.R. 1984(a), 22 N.J.R. 2744(a).

Section was "Validity."

New Rule, R.2003 d.200, effective May 19, 2003.

See: 35 N.J.R. 7(a), 35 N.J.R. 2187(a).

Amended by R.2004 d.199, effective June 7, 2004.

See: 36 N.J.R. 910(a), 36 N.J.R. 2733(a).

In (d), inserted the second sentence in the introductory paragraph.

Amended by R.2005 d.425, effective December 5, 2005.

See: 37 N.J.R. 2744(a), 37 N.J.R. 4531(b).

Added (e).

5:18-1.7 Reporting emergency situations

(a) The LP-Gas supplier, owner or operator shall respond when notified to all LP-Gas emergencies occurring at his systems and shall maintain a 24-hour phone service.

(b) Whenever there is a fire or explosion or accident involving the public which results in serious injury or loss of life or significant property damage from liquefied petroleum gas, the Bureau shall be notified in writing by the user/owner before the end of the first working day following the incident.

Recodified from N.J.A.C. 12:200-1.9 by R.1990 d.436, effective September 4, 1990.

See: 22 N.J.R. 1984(a), 22 N.J.R. 2744(a).

Prior N.J.A.C. 12:200-1.4 was "Effective Date."

Repealed by R.1990 d.436, effective September 4, 1990.

See: 22 N.J.R. 1984(a), 22 N.J.R. 2744(a).

Section "Existing installations" was recodified to 1.2.

Recodified from N.J.A.C. 5:18-1.4 and amended by R.2003 d. 200, effective May 19, 2003.

See: 35 N.J.R. 7(a), 35 N.J.R. 2187(a).

Former N.J.A.C. 5:18-1.7, was reserved. Rewrote the section.

5:18-1.8 (Reserved)

Repealed by R.1990 d.436, effective September 4, 1990.

See: 22 N.J.R. 1984(a), 22 N.J.R. 2744(a).

Section "Compliance" was recodified to 1.3.

5:18-1.9 (Reserved)

Repealed by R.1990 d.436, effective September 4, 1990.

See: 22 N.J.R. 1984(a), 22 N.J.R. 2744(a).

Section "Reporting emergency situations" recodified to 1.4.

5:18-1.10 (Reserved)

Repealed by R.1990 d.436, effective September 4, 1990.

See: 22 N.J.R. 1984(a), 22 N.J.R. 2744(a).

Section "Reporting of fires, explosions or accidents" was recodified to 1.5.

5:18-8.2 Payment of annual assessment

(a) The owner of liquefied petroleum gas immediately prior to odorization shall be responsible for the payment of the assessment on the volume of liquefied petroleum gas at the time of import or odorization, whichever is earlier.

(b) All assessments shall be payable to "Treasurer, State of New Jersey" and shall be remitted to the Bureau of Code Services, PO Box 816, Trenton, NJ 08625-0816 on a quarterly basis on or before the 25th day of the month following the end of the quarter.

(c) A penalty of five percent shall be added to all payments received by the Bureau after the 25th day of the month following the end of the quarter.

(d) In addition to the penalty imposed under (c) above, interest at an annual rate of 12 percent shall be added to all payments received by the Bureau 30 days or more after the 25th day of the month following the end of the quarter.

Amended by R.2003 d.200, effective May 19, 2003.
See: 35 N.J.R. 7(a), 35 N.J.R. 2187(a).

5:18-8.3 Forms

(a) The following forms, which are incorporated by reference as Appendix B of this chapter, shall be used for the purposes indicated:

1. Remittance Report (LPG-1);
2. Odorizer or Importer Registration (LPG-2);
3. Load Exemption: Certificate of LPG Destined for Export (LPG-3);
4. LPG Usage Report (LPG-4);
5. Assessment Refund Request (LPG-5); and
6. Odorization Report for Terminal Operators (LPG-6)

—————

**SUBCHAPTER 9. QUALITY CONTROL AND
MAINTENANCE AUDITS**

5:18-9.1 Registration of LPG bulk and industrial plants

(a) The owner or operator of a LP-Gas facility, including producers, bulk plants and industrial plants of 10,000 gallons water capacity or more, gas utility plants, marine or pipeline terminals or tank farms, shall register with the Bureau on forms provided by the Bureau.

(b) The registration shall include information as to all locations at which odorized or unodorized LP-Gas is stored or sold by the business, whether at the facility or elsewhere.

5:18-9.2 Quality control manual and records

(a) The owner or operator of a facility required to be registered pursuant to N.J.A.C. 5:18-9.1 shall prepare, maintain and follow a quality control manual which shall, at a minimum, include the following:

1. A cover sheet indicating the full name of the owner and operator and the street address of the facility;
2. An organization chart detailing the lines of communication and authority and identifying the individual, who shall be a senior company official, who is responsible for implementation of the quality control manual;
3. A complete site plan for each registered facility and a process flow diagram that illustrates piping, valves, equipment, and emergency shutdowns of the facility;
4. A description of a training program for LPG handling and safety approved by the Bureau of Code Services. The training program shall meet the following requirements:
 - i. There shall be ongoing training for all individuals involved in the operation and maintenance of LPG equipment; and
 - ii. All training shall be consistent with national standards for LPG safety training and with this chapter;
5. Standard operating procedures (SOP) and checklists for each facility in order to ensure, at a minimum, safe operation. Any such SOP or checklist shall include, where applicable, but not be limited to, the following:
 - i. Filling, refilling and/or venting containers;
 - ii. Delivery of LPG to any location. A checklist shall be provided to each driver and, when requested, to the Bureau inspector, to ensure that proper procedures, as required by this chapter, are followed;
 - iii. Evacuation of cylinders;
 - iv. Emergency procedures;
 - v. Accident reporting and documentation;
 - vi. Installation guidelines and standards for every type of container;
 - vii. Repair or reconditioning of vessels; and
 - viii. Testing, repair and maintenance of pressure relief valves and other control or flow devices;
6. Documentation of compliance with the NJDEP Risk Management Program, if applicable, including details specific to the following:
 - i. Plant safety information, including hazard review scenarios with both normal and emergency shutdown procedures;

- ii. System operating procedures;
- iii. Employee training;
- iv. Maintenance procedures and programs;
- v. Compliance audits;
- vi. Plant fire safety analysis; and
- vii. Incident investigations;

7. Documentation assuring that only acceptable materials are used for new, existing or replacement systems and that all required materials are properly identified when received; and

8. Nonconformance reports documenting all conditions not conforming to this chapter and ensuring that any problems identified through procedures, controls, inspections, specifications or testing are effectively corrected and documented.

(b) The owner or operator of a facility shall maintain a file system for equipment inspection records, which shall list, by number and such abbreviated description as may be necessary for identification, each ASME pressure vessel covered by these rules, the date of the last inspection of the vessel, and the approximate date for the next inspection.

(c) The owner or operator of a facility shall maintain the following records for the times specified:

- 1. Manufacturer's data reports of new and used pressure vessels: life of the vessel;
- 2. All documentation of repairs: life of the vessel;
- 3. Reports of training: term of employment;
- 4. Reports of nonconformance: five years; and
- 5. All results of nondestructive examination tests and other tests and all repair or alteration documentation: life of the vessel.

(d) The Bureau shall have free access to the records of the facility maintained under (a), (b), and (c) above.

5:18-9.3 Pressure vessel maintenance, repair and alteration

Any pressure vessel code item shall be maintained, repaired and altered in accordance with the original code of construction, the National Board Inspection Code, the applicable ASME code and this chapter.

5:18-9.4 Certificates of operation and audits

(a) The owner or operator of a facility required to be registered pursuant to N.J.A.C. 5:18-9.1 shall be audited by the Bureau triennially after a satisfactory initial audit.

(b) Upon successful completion of an initial audit, the Bureau shall issue a site-specific certificate of operation, which shall be valid for three years.

(c) The certificate of operation shall indicate that the facility is in compliance with all applicable requirements of this chapter and shall be posted at a conspicuous location within the facility where it may be inspected by representatives of the Bureau and members of the public.

(d) In the event that an audit is not successful, an owner or operator shall be given 30 days to address all identified deficiencies. Subsequent audits shall be made as necessary in order to verify compliance with all applicable requirements.

1. The owner or operator may apply for, and the Bureau may grant, an extension of time to address deficiencies if the Bureau finds that such extension is needed, that the owner is making a good faith effort to correct deficiencies and that there is no threat to public health or safety.

(e) Failure to remove any violations found as a result of an audit made by the Bureau shall result in issuance of a written notice to abate the violations. Correction of violations shall be done in accordance with N.J.A.C. 5:18-7.3.

SUBCHAPTER 10. LICENSING

5:18-10.1 Licenses required

(a) No person, firm or corporation shall engage in the business of marketing LP-Gas within the State of New Jersey without being licensed to do so by the Bureau.

(b) A license issued by the Bureau shall be valid for a period of 36 months.

(c) No license shall be issued to any person, firm or corporation that does not maintain general liability insurance in an amount of not less than \$5,000,000.

(d) No license shall be issued to any person, firm or corporation that markets LP-Gas and does not maintain either an adequate storage capacity for customers or contract(s) with other marketers to provide LP-Gas.

(e) Retention and reissuance of a license shall be contingent upon satisfactory completion of all audits required pursuant to this chapter.

Amended by R.2004 d.199, effective June 7, 2004.

See: 36 N.J.R. 910(a), 36 N.J.R. 2733(a).

In (c), deleted "per occurrence" following "\$5,000,000".

5:18-10.2 Application for licensure; fees

(a) An application for licensure shall be submitted on a form provided by the Bureau and shall include the following information:

1. The name of the business;
2. The names, addresses and telephone numbers of the officers, directors, partners or proprietors of the business;
3. The activities having to do with LP-Gas in which the business is engaged in the State of New Jersey;
4. Proof of insurance as required by N.J.A.C. 5:18-10.1(c);
5. The location(s) at which or from which each such activity is conducted and the LP-Gas storage capacity at each such location or information on contracts with other marketers to provide LP-Gas;
6. Emergency contact information in conformance with N.J.A.C. 5:18-1.7;
7. A listing of all persons employed by the business who are in any way engaged in handling LP-Gas, together with the locations at which they work and Certified Employee Training Program (CETP) of the National Propane Gas Association certifications held by them;
8. A statement indicating whether or not the business, or any officer, director, partner or proprietor of the business, has at any time within the previous ten years been the subject of any order or finding of violation by any governmental entity with regard to the business or any other LP-Gas business or has been convicted of any crime or of any offense involving the business or any other LP-Gas business; and
9. A certification that the information set forth in the application is complete and correct.

(b) Each application for a license shall be accompanied by a fee in the amount of \$100.00. Checks shall be made payable to "Treasurer, State of New Jersey."

5:18-10.3 Employee certification

(a) Any employee of a marketer licensed pursuant to N.J.A.C. 5:18-10.1 handling LP-Gas shall obtain Certified Employee Training Program (CETP) of the National Propane Gas Association certification for Book One, "Basic Principles and Practices," within three months of the date of hiring.

1. All employees of a licensed marketer who are responsible for delivering propane shall take and pass part 2.1 of the CETP program, and shall pass part 2.2 if they drive a bulk delivery vehicle, part 2.4 if they drive a cylinder delivery truck or part 2.5 if they are involved in the transportation/relocation of ASME tanks.

2. All employees of a licensed marketer who are responsible for plant operations such as maintaining, purging or reconditioning tanks, shall pass parts 3.1, 3.2, 3.3, and 3.4 of the CEPT program and shall pass, as applicable, part 3.5 or 3.6 if the employee is responsible for any aspect of cargo tank product transfers or rail car transfers, respectively.

3. All employees of a licensed marketer who are responsible for the installation, alteration or repair of propane distribution systems shall pass part 4.2 of the CETP program.

4. The appropriate parts of 2, 3 and 4 of the CETP program must be completed within 21 months of the date of hire or by September 6, 2005, whichever is later.

5. The licensed LP-Gas marketer shall maintain documentation from CETP that each employee, responsible for any specific task listed above, has passed the appropriate CETP test(s) and the required practicum(s) for the task(s).

6. Employees who have completed the previous version of Book One, "Basic Principles and Practices," Book Two, "Propane Delivery," Book Three, "Plant Operations," and Book Four, "Distribution System Operations" of the CETP program are deemed to comply with this rule.

(b) Licensees shall maintain records of employee certification and shall make those records available to the Bureau upon request.

Amended by R.2005 d.174, effective June 6, 2005.

See: 36 N.J.R. 5282(a), 37 N.J.R. 2012(c).

Rewrote (a).

5:18-10.4 Fill plant and dispensing station operator training

(a) All fill plant or dispensing station operators shall be trained using the "Dispensing Propane Safely" manual (2000 edition) published by the National Propane Gas Association, incorporated herein by reference, or an equivalent accepted by the Department. An employee shall receive training prior to dispensing LP-Gas. It shall be the responsibility of the business operating the tank, working together with the marketer, to ensure all employees dispensing LP-Gas are trained properly.

(b) Licensees shall maintain records of employee training and shall make those records available to the Bureau upon request.

New Rule, R.2003 d.250, effective July 7, 2003.

See: 35 N.J.R. 1176(a), 35 N.J.R. 2864(a).

Section was Reserved.

5:18-10.5 Suspension and revocation of licenses and certifications and alternative sanctions

(a) The Bureau may suspend or revoke a license, or may deny renewal or issuance of a license, upon a finding that an applicant or licensee has engaged in acts or omissions harmful to public safety or to the protection of the public. Factors in determining whether a license should be revoked or suspended, or for how long a suspension should be in effect, shall include, but not be limited to, the extent and duration of the hazard to the public, the extent to which

willful or reckless behavior was evident, prior history of like or similar violations and the extent to which appropriate corrective action was taken.

(b) As an alternative to revocation or suspension of a license, the Bureau may assess a civil penalty, in accordance with N.J.S.A. 21:1B-5, or may issue a letter of warning, reprimand or censure, if the Bureau determines any such action to be warranted. Any penalty imposed or letter issued shall be part of the licensing file of the business or individual, as the case may be.

(c) Conviction of a crime, or of an offense in connection with the LP-Gas business, shall constitute grounds for suspension or revocation of a license.

(d) Any person to whom the Bureau denies a license, or whose license is suspended or revoked, or who is ordered to pay a civil penalty, shall be entitled to appeal the action of the Bureau in an administrative hearing conducted in accordance with the Administrative Procedure Act, N.J.S.A. 52:14B-1 et seq., and the Uniform Administrative Procedure Rules, N.J.A.C. 1:1. The final decision shall be issued by the Commissioner.

APPENDIX A

AVAILABILITY OF STANDARDS AND PUBLICATIONS REFERRED TO IN THIS CHAPTER

A copy of each of the standards and publications referenced in this chapter is on file and may be inspected at the following office of the Division of Codes and Standards between the hours of 9:00 A.M. and 5:00 P.M. on normal working days:

State of New Jersey
 Department of Community Affairs
 Division of Codes and Standards
 101 South Broad Street
 Trenton, New Jersey

Copies of the referenced standards and publications may be obtained from the organizations listed below. The abbreviations preceding these standards and publications have the following meanings and refer to the organizations issuing the standards and publications listed or to volumes of statutes or administrative rules.

- API American Petroleum Institute
 1220 L Street Northwest
 Washington, D.C. 20005
- BOCA Building Officials and Code Administration
 4051 W. Flossmoor Rd.
 Country Club Hills, Illinois 60477-5795
- CFR Code of Federal Regulations
 Copies available from:

Superintendent of Documents
 Government Printing Office
 Washington, D.C. 20402

- NFPA National Fire Protection Association
 Batterymarch Park
 Quincy, Massachusetts 02269
- N.J.A.C. New Jersey Administrative Code
 Copies of N.J.A.C. 5:18 are available from:
 Bureau of Code Services
 New Jersey Department of Community Affairs
 PO Box 816
 Trenton, New Jersey 08625-0816
 Copies of N.J.A.C. 5:70-3 are available from
 Division of Fire Safety
 New Jersey Department of Community Affairs
 PO Box 809
 Trenton, New Jersey 08625-0809
- N.J.S.A. New Jersey Statutes Annotated
 Copies of N.J.S.A. 21:1B-1 et seq. are available from:
 Bureau of Code Services
 New Jersey Department of Community Affairs
 PO Box 816
 Trenton, New Jersey 08625-0816
- USC United States Code
 Copies available from:
 Occupational Safety and Health Administration
 U.S. Department of Labor
 1515 Broadway
 New York, New York 10036

<i>No. and Edition</i>	<i>Title</i>
API-2510-2001	American Petroleum Institute 2510-2001, Design and Construction of Liquefied Petroleum Gas Installations
BOCA-1996	The BOCA National Building Code
NFPA No. 30-1993	Flammable and Combustible Liquids Code
NFPA No. 58-2004	Liquefied Petroleum Gas Code
NFPA No. 59-1998	Storage and Handling of Liquefied Petroleum Gases at Utility Gas Plants
N.J.A.C. 5:70	New Jersey Uniform Fire Code
N.J.A.C. 5:23	New Jersey Uniform Construction Code
N.J.A.C. 5:11	Boilers, Pressure Vessels and Refrigeration
N.J.S.A. 21:1B-1 et seq.	Liquefied Petroleum Gas Act
29 USC 651 et seq.	Occupational Safety and Health Act
Amended by R.1990 d.436, effective September 4, 1990. See: 22 N.J.R. 1984(a), 22 N.J.R. 2744(a). Updated citations, addresses and added API to appendix. Amended by R.1995 d.391, effective July 17, 1995. See: 27 N.J.R. 1950(a), 27 N.J.R. 2694(b). Amended by R.2003 d.200, effective May 19, 2003. See: 35 N.J.R. 7(a), 35 N.J.R. 2187(a). Updated citations, addresses. Amended by R.2005 d.425, effective December 5, 2005. See: 37 N.J.R. 2744(a), 37 N.J.R. 4531(b). Substituted "API 2510-2001" for "API 2510-1995"; substituted "NFPA No. 58-2004" for "NFPA No. 58-1998."	