

iii. Section 1607.9, Reduction in live loads, shall be amended as follows: In the first sentence, "and applied" shall be inserted after "reduced." After the first sentence, "The method chosen shall be applied throughout the building." shall be inserted.

iv. In Section 1607.9.1.4, Group A occupancies, "and Group E" shall be added to the title of the section and after "Group A" insert "and Group E".

v. In Section 1607.9.2, Alternate floor live load reduction, Item 1, "or Group E" shall be inserted after "Group A."

vi. In Section 1611.1, Design rain load, the second sentence shall be deleted and "The design rainfall rates shall be based on the plumbing subcode, N.J.A.C. 5:23-3.15." shall be inserted.

vii. In Section 1611, Rain loads, Figure 1611.1, "100-year, 1-hour rainfall (inches)" shall be deleted.

viii. In Section 1612.1, General, in the first sentence, "including substantial improvement and restoration of substantial damage to buildings and structures" shall be deleted.

ix. Section 1613.3, Existing building, shall be deleted in its entirety.

17. Chapter 17, Structural Tests and Special Inspections, shall be amended as follows:

i. In Section 1701.1, Scope, "shall apply to Class 1 buildings and smoke control systems in all buildings and" shall be inserted after "chapter."

ii. Section 1702.1, General, shall be amended as follows: In the title, "/Special Inspector" shall be inserted after "Agency." In the first sentence, "or design professional acting as the approved agency" shall be inserted after "agency." At the end of the definition, add the sentence, "Special inspectors shall be certified in accordance with the administrative provisions of the Uniform Construction Code."

iii. Section 1703.1, Approved agency, shall be amended as follows: In the first sentence, "Upon the request of the construction official" shall be inserted before "An." In the same sentence, "building official" shall be deleted and "construction official" shall be inserted and "applicable" shall be deleted and "following" shall be inserted.

iv. Add new section 1703.1.4 as follows: "1703.1.4 Certification. An approved agency shall employ personnel certified in accordance with the administrative provisions of the Uniform Construction Code, to conduct, supervise and evaluate tests or inspections."

v. In Section 1703.6, Evaluation and follow-up inspection, "in accordance with N.J.A.C. 5:23-4.26" shall be inserted after the second "assembly."

vi. Section 1704.1, General, shall be amended as follows: In the first sentence of the first paragraph, "the registered design professional" shall be deleted and "person" shall be inserted. Also, in the first sentence of the first paragraph, "of Class 1 buildings only or any building containing a smoke control system" shall be inserted after "construction." In the second sentence of the second paragraph, "the registered design professional" shall be deleted and "person" shall be inserted.

vii. Section 1704.1.2, Report requirement, shall be amended as follows: In the second sentence, "building official" shall be deleted and "construction official" shall be inserted and "registered design professional" shall be deleted and "person" shall be inserted. In the same sentence, "in accordance with N.J.A.C. 5:23-2.21(c)" shall be inserted after "charge." In the fifth sentence, "building official" shall be deleted and "construction official" shall be inserted and "registered design professional" shall be deleted and "person" shall be inserted. In the last sentence, "building official" shall be deleted and "construction official" shall be inserted.

viii. In Section 1704.3, Steel construction, "the on-site erection of" shall be inserted after "for."

ix. In Table 1704.3, Required Verification and Inspection of Steel Construction, Items 1, 3, and 4 shall be deleted.

x. In Section 1704.5, Masonry construction, "in Seismic Design Category D" shall be inserted after the word "construction" within the text. In the same section, in Exception 2, the reference to "Table 1807.1.6.3(1)" shall be deleted.

xi. Section 1704.6, Wood construction, shall be deleted in its entirety.

xii. In Section 1705.3, Seismic resistance, "for Seismic Design Category D buildings" shall be inserted after "inspections."

xiii. Sections 1705.4, Wind resistance; 1705.4.1, Wind requirements in the statement of special inspections; and 1705.4.2, Detailed requirements, shall be deleted in their entirety.

xiv. Section 1706, Special inspection for wind requirements, shall be deleted.

xv. In Section 1707.1, Special Inspections for Seismic Resistance, in items 1 and 3, "C," shall be deleted in reference to seismic design categories.

xvi. In Section 1707.7, Mechanical and Electrical Components, in items 1, 3, 4 and 5, "C," shall be deleted in reference to seismic design categories.

xvii. Section 1708.3, Structural steel, shall be deleted.

xviii. In Section 1709.1, Contractor responsibility, in the first sentence, "main – wind- or" shall be deleted. In addition, in the same sentence, "or a wind-" shall be deleted.

xix. Section 1710, Structural Observations, shall be deleted in its entirety.

18. Chapter 18, Soils and Foundations, shall be amended as follows:

i. Section 1803.3.1, Scope of investigation, shall be amended as follows: After the first sentence, the following sentence from Section 1802.1 of the 1996 BOCA National Building Code shall be inserted: "There shall be at least one exploratory boring to rock or to an adequate depth below the load-bearing strata for every 2,500 square feet (232 m²) of built-over area, and such additional tests as the code official requires."

ii. In the title of Section 1803.5.11, "C" shall be deleted and "D" shall be inserted. In the first sentence, the reference to "C" shall be deleted.

iii. New Section 1803.5.13 from Section 1802.1 of the 1996 BOCA National Building Code shall be inserted as follows: "Building Height: For all buildings that are more than three stories or 40 feet (12,192 mm) in height above the grade plane, the building official shall request soil tests."

iv. In Section 1805.4.3, Drainage discharge, "International Plumbing Code" shall be deleted and "plumbing subcode (N.J.A.C. 5:23-3.15)" shall be inserted.

v. New Section 1807.4 from Section 1813.8 of the 1996 BOCA National Building Code shall be inserted as follows: "1807.4 Erosion protection: Where water impacts the ground from the edge of the roof, downspout, scupper or other rain water collection or diversion device, provisions shall be made to prevent soil erosion and direct the water away from the foundation."

vi. Section 1809.4, Depth and width of footings, shall have the following exceptions added:

"Exceptions:

1. Garden-type utility sheds and similar structures that are 100 square feet or less in area, 10 feet or less in height and accessory to structures of Group R-2, R-3 or R-4 and does not contain a water, gas, oil or sewer connection. These structures shall be of sufficient weight to remain in place or shall be anchored to the ground.

2. Garden-type utility sheds and similar structures that are greater than 100 square feet, but not more than 200 square feet in area, 10 feet or less in height and accessory to structures of Group R-2, R-3 or R-4 provided the shed is dimensionally stable

without the foundation system and does not contain a water, gas, oil or sewer connection. A shed shall be considered dimensionally stable if it is provided with a floor system that is tied to the walls of the structure such that it reacts to loads as a unit. These structures shall be of sufficient weight to remain in place or shall be anchored to the ground."

vii. New Section 1810.3.1.7 from Section 1816.9 of the 1996 BOCA National Building Code shall be inserted as follows: "Spacing: The minimum center-to-center spacing of piles shall not be less than twice the average diameter of a round pile, nor less than 1 3/4 times the diagonal dimension of a rectangular pile. Where driven to or penetrating into rock, the spacing shall not be less than 24 inches (610 mm). Where receiving principal support at the end from materials other than rock, or through friction resistance, the spacing shall not be less than 30 inches (762 mm) except that for piles having enlarged bases formed either by compacting concrete or driving a pre-cast base, the minimum center-to-center spacing shall be 4 1/2 feet (1,372 mm). The spacing of piles shall be such that the average load on the supporting strata will not exceed the safe load-bearing value of those strata as determined by test borings or other approved methods."

viii. In Section 1810.3.3.1.3, Load test evaluation methods, Item 4 shall be deleted.

ix. In Section 1810.3.13, Seismic ties, in the exception, "and U" and "subject to approval of the building official" shall be deleted.

19. Chapter 23, Wood, shall be amended as follows:

i. In Section 2303.4.1.4.1, Truss design drawings, "Where required by the registered design professional, the building official, or the statutes of the jurisdiction in which the project is to be constructed," shall be deleted.

ii. In Section 2303.4.2, Truss placement diagram, in the last sentence, "that serve only as a guide for installation and do not deviate from the permit submittal drawings" shall be deleted.

iii. New Section 2303.4.8, entitled "Truss Identification," shall be inserted as follows: "Each truss shall be labeled or otherwise indelibly marked at the factory with the individual truss number as assigned in the truss layout plan. The indelible marking or label shall be located on the bottom chord of the truss, inside the bearing points. When indelible markings are used, each digit shall be not less than one inch high. When labels are used, the label shall be a minimum of five inches by three inches and shall be affixed to the truss by a truss plate. Labels shall remain affixed to the truss."

iv. In Table 2306.2.1(2), Allowable shear for wood structural panel blocked diaphragms utilizing multiple rows of fasteners (high load diaphragms) with framing

Amended by R.1985 d.154, effective April 1, 1985 (operative July 1, 1985.)

See: 17 N.J.R. 239(a), 17 N.J.R. 810(a).

(a)2 added; subsection (c) added.

Correction: N.J.A.C. 5:23-3.14(c)5 was incorrect in adoption.

See: 17 N.J.R. 1409(a).

Amended by R.1985 d.324, effective July 1, 1985.

See: 17 N.J.R. 861(c), 17 N.J.R. 1646(a).

(b)3i: amended text.

Amended by R.1986 d.380, effective September 22, 1986.

See: 18 N.J.R. 1235(a), 18 N.J.R. 1931(a).

Substantially amended.

Amended by R.1987 d.374, effective September 21, 1987.

See: 19 N.J.R. 1024(a), 19 N.J.R. 1720(b).

Model subcode revisions.

Amended by R.1988 d.270, effective June 20, 1988.

See: 20 N.J.R. 575(a), 20 N.J.R. 1344(a).

Added (a)3 and (c).

Amended by R.1990 d.253, effective May 21, 1990.

See: 22 N.J.R. 909(b), 22 N.J.R. 1554(a).

Text added at (c)2ii, 4, 5 and 7.

Amended by R.1990 d.325, effective July 2, 1990.

See: 21 N.J.R. 1654(a), 22 N.J.R. 2001(a).

Text added at (b)5xii(1) to conform to Fire Code.

Amended by R.1990 d.507, effective October 15, 1990.

See: 22 N.J.R. 2208(a), 22 N.J.R. 3214(a).

Text conformed to BOCA National Code/1990.

Amended by R.1990 d.558, effective November 19, 1990.

See: 22 N.J.R. 1969(b), 22 N.J.R. 3483(a).

Conditional exemption for hoopouses or polyhouses added.

Amended by R.1991 d.325, effective July 1, 1991.

See: 23 N.J.R. 805(a), 23 N.J.R. 2046(a).

Article 26 amended at (b)14.

Amended by R.1991 d.429, effective August 19, 1991.

See: 23 N.J.R. 1487(a), 23 N.J.R. 2501(a).

In (a), added 3. Added (c).

Amended by R.1992 d.244, effective June 15, 1992.

See: 24 N.J.R. 1147(a), 24 N.J.R. 2243(a).

Text added at (b)10v through viii.

Amended by R.1993 d.662, effective December 20, 1993.

See: 25 N.J.R. 3891(a), 25 N.J.R. 5918(a).

Amended by R.1995 d.144, effective March 20, 1995 (operative July 1, 1995).

See: 26 N.J.R. 2698(a), 26 N.J.R. 3524(a), 27 N.J.R. 1180(a).

Amended by R.1995 d.477, effective September 5, 1995.

See: 27 N.J.R. 1717(a), 27 N.J.R. 3328(a).

Added (b)2v.

Amended by R.1998 d.332, effective July 6, 1998.

See: 30 N.J.R. 1377(a), 30 N.J.R. 2421(b).

Rewrote the section.

Amended by R.2000 d.492, effective December 18, 2000.

See: 32 N.J.R. 3219(a), 32 N.J.R. 4437(b).

Rewrote (b)25.

Amended by R.2001 d.127, effective April 16, 2001.

See: 33 N.J.R. 392(a), 33 N.J.R. 1195(a).

In (a)9, added new ix and recodified former ix through xiii as new x through xiv.

Amended by R.2001 d.368, effective October 15, 2001.

See: 33 N.J.R. 1990(a), 33 N.J.R. 3673(b).

In (b)9, inserted a new ix and recodified former ix through xiv as x through xv.

Amended by R.2001 d.369, effective October 15, 2001.

See: 33 N.J.R. 2365(a), 33 N.J.R. 3674(a).

In (b), substituted "seven" for "7 1/3 (2335 mm)" in 2vi, rewrote 10, added a new 17, and recodified former 17 through 26 as 18 through 27.

Amended by R.2002 d.215, effective July 1, 2002.

See: 34 N.J.R. 1078(a), 34 N.J.R. 2312(a).

In (b)22, inserted new ii and recodified existing ii through xvii as iii through xviii.

Administrative correction.

See: 34 N.J.R. 3771(b).

Amended by R.2003 d.187, effective May 5, 2003.

See: 34 N.J.R. 4248(a), 35 N.J.R. 1939(c).

Rewrote the section.

Administrative correction.

See: 35 N.J.R. 2864(b).

Amended by R.2003 d.351, effective September 2, 2003.

See: 35 N.J.R. 1177(a), 35 N.J.R. 4051(a).

In (b)9, added xi; recodified existing xi to xiii as xii to xiv.

Amended by R.2003 d.420, effective November 3, 2003.

See: 34 N.J.R. 4248(a), 35 N.J.R. 5073(a).

Rewrote (b).

Administrative correction.

See: 36 N.J.R. 3525(c).

Amended by R.2004 d.423, effective November 15, 2004.

See: 36 N.J.R. 3004(a), 36 N.J.R. 5090(a).

In (b)5, added ii.

Amended by R.2005 d.4, effective January 3, 2005.

See: 36 N.J.R. 4049(a), 37 N.J.R. 47(a).

In (b)19, added new iv and recodified former iv and v as v and vi.

Administrative correction.

See: 37 N.J.R. 502(b), 674(a).

Amended by R.2005 d.403, effective November 21, 2005.

See: 37 N.J.R. 2753(a), 37 N.J.R. 4399(b).

Added (b)14xi and recodified former (b)14xi-xiii as (b)14xii-xiv;

added (b)18 and recodified former (b)18-25 as (b)19-26.

Amended by R.2005 d.446, effective December 19, 2005.

See: 37 N.J.R. 2747(a), 37 N.J.R. 4907(a).

In (b)3viii(3), substituted "one- and two-family" for "single-family"; in (b)3viii(5), "Group R-5 also includes: ..."

Amended by R.2006 d.28, effective January 17, 2006.

See: 37 N.J.R. 2750(a), 38 N.J.R. 485(b).

Rewrote (b)9, 20 and 21.

Amended by R.2006 d.157, effective May 1, 2006.

See: 37 N.J.R. 3108(a), 38 N.J.R. 1824(a).

Rewrote (b)21ii.

Administrative Correction.

See: 38 N.J.R. 3024(a).

Amended by R.2006 d.381, effective November 6, 2006.

See: 38 N.J.R. 35(a), 38 N.J.R. 4691(a).

In (b)15ii, added the last sentence; added new (b)15iv; and recodified former (b)15iv through (b)15xv as (b)15v through (b)15xvi.

Amended by R.2007 d.51, effective February 5, 2007.

See: 38 N.J.R. 375(a), 39 N.J.R. 371(a).

Added new (b)2viii; recodified former (b)2viii through (b)2x as (b)2ix through (b)2xi; added new (b)3iii; recodified former (b)3iii through (b)3viii as (b)3iv through (b)3ix; added new (b)9i; recodified former (b)9i through (b)9xi as (b)9ii through (b)9xii; added new (b)9xiii; recodified former (b)9xii through (b)9xv as (b)9xiv through (b)9xvii; added new (b)10xxii and (b)10xxiii; and recodified former (b)10xxii as (b)10xxiv.

Amended by R.2007 d.65, effective February 20, 2007.

See: 38 N.J.R. 3348(a), 39 N.J.R. 633(a).

Rewrote the section.

Administrative correction.

See: 39 N.J.R. 1249(a).

Amended by R.2007, d.384, effective December 17, 2007.

See: 39 N.J.R. 2684(a), 39 N.J.R. 5211(a).

Added new (b)3i and (b)3ii; and recodified former (b)3i through (b)3vii as (b)3iii through (b)3ix.

Amended by R.2008 d.39, effective March 3, 2008.

See: 39 N.J.R. 2175(a), 40 N.J.R. 1084(a).

Added new (b)24iii; and recodified former (b)24iii as (b)24iv.

Administrative correction.

See: 40 N.J.R. 1829(a).

Amended by R.2008 d.184, effective July 7, 2008.

See: 39 N.J.R. 2176(a), 40 N.J.R. 3990(a).

Deleted former (b)9vii; and recodified former (b)9viii through (b)9xlii as (b)9vii through (b)9xli.

Amended by R.2009 d.48, effective February 2, 2009.

See: 40 N.J.R. 5319(a), 41 N.J.R. 733(b).

In (b)3iii, inserted "(not including food or drink consumption)"; added new (b)5ii; recodified former (b)5ii as (b)5iii; added new (b)5iv and (b)5v; recodified former (b)5iii through (b)5ix as (b)5vi through (b)5xii; in (b)7i, deleted "at" preceding and ", and group U when used as an accessory to Group R3" following "Note b"; added new (b)8iii; recodified former (b)8iii through (b)8v as (b)8iv through (b)8vi; in (b)8v, substituted "Exceptions 4 and 6" for "Exception 4" and "their" for "its";

in the second paragraph of (b)9ii, deleted “.1” following “903.1.2”; in (b)9v1, deleted “that conforms to the requirements of Section 1005.3.6,” following “stairway” and substituted “1023” for “1003.3.4”; in the introductory paragraph of (b)9vi, substituted “903.2.14” for “903.2.16”; in (b)9xii3, substituted “903.3.1.1” for “906.2.1”; rewrote (b)9xiii through (b)9xli; added (b)9xlii; rewrote (b)10, (b)17xiv through (b)17xxii; added new (b)18v; recodified former (b)18v through (b)18xi as (b)18vi through (b)18xii; rewrote (b)21; and in (b)22iv, deleted “In” preceding “Section” and “Item 3” preceding “shall”.

Amended by R.2009 d.126, effective April 20, 2009.

See: 41 N.J.R. 16(a), 41 N.J.R. 1725(a).

Added new (b)18v; and recodified former (b)18v through (b)18xii as (b)18vi through (b)18xiii.

Amended by R.2009 d.255, effective August 17, 2009.

See: 41 N.J.R. 1919(a), 41 N.J.R. 3065(a).

In (b)21ii, inserted “insert” twice, substituted “8.6” for “8.6.1.6.5” and deleted “shall be inserted” preceding “after” twice.

Amended by R.2010 d.195, effective September 7, 2010.

See: 41 N.J.R. 3140(a), 42 N.J.R. 2043(a).

Rewrote the section.

Amended by R.2012 d.179, effective November 5, 2012.

See: 44 N.J.R. 1679(a), 44 N.J.R. 2557(a).

Added new (b)9xlvii, (b)10xxx and (b)10xxxii; recodified former (b)9xlvii through (b)9liii as (b)9xlvii through (b)9liv; and recodified former (b)10xxx through (b)10xxxviii as (b)10xxxii through (b)10xli.

Amended by R.2013 d.081, effective June 3, 2013.

See: 44 N.J.R. 1303(a), 45 N.J.R. 1393(a).

In (b)17i, substituted “1” for “I”.

Case Notes

Set back provisions of borough zoning ordinance controlled conflicting state building code provisions. *Pfeuffer v. Sculco*, 242 N.J.Super. 181, 576 A.2d 309 (A.D.1990).

5:23-3.15 Plumbing subcode

(a) Rules concerning subcode adopted are as follows:

1. Pursuant to authority of P.L. 1975, c. 217, as modified by P.L. 1996, c. 53, the Commissioner hereby adopts the Model Code of the Plumbing Heating-Cooling Contractors—National Association, known as “The National Standard Plumbing Code/2009,” as the plumbing subcode for New Jersey.

i. Copies of this code may be obtained from the sponsor at: PHCC-NA, P.O. Box 6808, Falls Church, VA 22046.

2. “The National Standard Plumbing Code/2009,” including appendices, may be known and cited as “the plumbing subcode.”

(b) The following pages, chapters, sections or appendices of the plumbing subcode shall be amended as follows:

1. The section entitled “Administration,” comprising sections ADM 1.1 through ADM 1.13, is deleted in its entirety.

2. Chapter 1 of the plumbing subcode, entitled “Definitions,” shall be amended as follows:

i. Delete the term and definition of “Adopting Agency.”

ii. Amend the definition of “approved” as follows: delete “Sec. 3.12” and insert “N.J.A.C. 5:23-3.7.”

iii. Delete the definition of “Authority Having Jurisdiction” and insert the following: “Unless otherwise

defined herein, or unless the context clearly indicates otherwise, the term “authority having jurisdiction” for purposes of the plumbing subcode, shall mean the “plumbing subcode official.”

iv. The definition of the term “building” is deleted, and substitute in lieu thereof, the definition of the term “building” found in N.J.A.C. 5:23-1.4.

v. In the definition of “Building Classification” delete “authority having jurisdiction” and insert “building subcode” at N.J.A.C. 5:23-3.14.

vi. The term and definition of “code” are deleted.

vii. The term and definition of “family” are deleted.

viii. The definition of “hot water” shall be deleted and the following definition shall be inserted: “Hot Water: Potable water at a temperature of not less than 120 degrees F and not more than 140 degrees F.”

ix. The definition of “Dead End, Potable Water” shall be deleted in its entirety.

x. The definition of “tempered water” shall be amended as follows: before “temperature,” delete “desired” and after “temperature,” delete “for its intended use, typically” and insert “of.”

xi. The term and definition of “nuisance” are deleted.

xii. Add the following new definition after the definition of Swimming Pool: Swimming Pool, Public: A swimming pool located on any property other than a one or two family residential property and including, but not limited to, swimming pools open to the use of members, residents or the public.

3. Chapter 2 of the plumbing subcode, entitled “General Regulations,” shall be amended as follows:

i. Section 2.5 is deleted in its entirety.

ii. In Section 2.9.3 delete “Building Code or as required by the proper Authority Having Jurisdiction” and insert “building subcode.”

iii. In Section 2.11, Piping materials exposed within plenums, “Codes” shall be deleted and “subcodes” shall be inserted.

iv. In Section 2.12, Sleeves, subparagraph e, “regulations” shall be deleted and “subcode” shall be inserted.

v. In Section 2.16, Freezing or overheating, at item 1, “42” shall be inserted in the blank space provided. Additionally, the following shall be inserted: “Combination domestic/fire water service piping shall be installed such that the minimum earth cover is 42 inches or the top of the pipe is 12 inches below the frost depth of the locality, whichever is greater. Limited-area sprinkler systems installed in accordance with Section 903.3.5.1.1 of the building subcode, shall be installed such that the