

(b) Unless otherwise specifically provided, all references to article or section numbers, or to provisions not specifically identified by number, shall be construed to refer to such article, section or provision of this subchapter.

(c) Except as is otherwise specified, these regulations shall control all matters concerning the construction, alteration, addition, repair, removal, demolition, use, location and occupancy of all buildings and structures and their service equipment as herein defined, and shall apply to existing or proposed buildings and structures in the State of New Jersey.

(d) The regulations shall be construed to secure its expressed intent, which is to insure public safety, health and welfare insofar as they are affected by building construction,

through structural strength, adequate egress facilities, sanitary equipment, light and ventilation, and fire safety; and, in general, to secure safety to life and property from all hazards incident to the design, erection, repair, removal, demolition or use and occupancy of buildings, structures or premises.

5:23-2.2 Matter covered

(a) The provisions of the regulations shall apply to all buildings and structures and their appurtenant construction, including vaults, area and street projections, and accessory additions; and shall apply with equal force to municipal, county, State and private buildings, except where such buildings are otherwise specifically provided for by the regulations.

New Jersey State Library

(b) A building or structure shall not be constructed, extended, repaired, removed, renovated, altered or reconstructed in violation of these provisions, except that no permit shall be required for ordinary repairs as provided herein, and except further that the raising, lowering or moving of a building or structure on the same lot, as a unit, necessitated by a change in legal grade or widening of a street, shall be permitted, provided the building or structure is not otherwise altered or its use or occupancy changed.

1. Any new work, such as foundations or utility connections shall, however, be in accordance with the regulations.

(c) Any requirement essential for structural, fire or sanitary safety of a building or structure, or essential for the safety of the occupants thereof, and which is not specifically covered by the regulations, shall be determined by the construction official, and appropriate subcode official.

(d) The continuation of occupancy or use of a building or structure, or of a part thereof, contrary to the provisions of the regulations, shall be deemed a violation and subject to the remedies prescribed in this subchapter.

(e) Where provisions herein specify requirements for structural, fire and sanitary safety, no provision of any municipal zoning or other municipal code shall conflict, govern or have effect. Where the provisions herein specify requirements with respect to location, use, permissible area and height, and the municipal zoning code establishes requirements as well, then the more restrictive requirements of this code or the zoning code shall govern.

Amended by 1981 d.134, effective May 7, 1981.

See: 13 N.J.R. 119(a), 13 N.J.R. 258(b).

(e): "other municipal" was "general".

Administrative Correction to (b): Changed "construed" to "constructed".

See: 22 N.J.R. 2503(b).

Amended by R.1998 d.28, effective January 5, 1998.

See: 29 N.J.R. 3603(a), 30 N.J.R. 129(a).

Rewrote (b), new exception that no permit required for ordinary repairs.

Case Notes

Portable fire extinguishers could not be required to be placed in hotel and motel efficiency units with cooking facilities. *Venuti v. Cape May County Const. Bd. of Appeals*, 231 N.J.Super. 546, 555 A.2d 1175 (A.D.1989).

Construction code official authorized to determine particular fire code prevention requirements of building where building use deviates in any significant respect from building uses "specifically covered" by fire prevention subcode; hearing held by construction board of appeals was procedurally deficient. In the Matter of the "Analysis of Walsh Trucking Occupancy and Sprinkler System," 215 N.J.Super. 22, 2, 521 A.2d 883 (App.Div.1987).

5:23-2.3 Applicability

These regulations shall apply to all construction undertaken after the effective date of the regulations or any subsequent amendment thereof.

Amended by R.1998 d.28, effective January 5, 1998.

See: 29 N.J.R. 3603(a), 30 N.J.R. 129(a).

Case Notes

Forum for seeking double damages under Planned Real Estate Development Full Disclosure Act (PREDFDA) was Superior Court. *Department of Community Affairs, Div. of Housing and Urban Development v. Atrium Palace Syndicate*, 259 N.J.Super. 578, 614 A.2d 1069 (A.D.1992).

Site lighting installations at locations without construction permits were in violation of uniform construction code act. *Public Service Electric and gas company v. Department of Community Affairs*, 94 N.J.A.R.2d (CAF) 13.

5:23-2.4 Alterations, replacements and damages

(a) Existing structures, when repaired, renovated, altered or reconstructed, shall conform to the requirements of N.J.A.C. 5:23-6, Rehabilitation Subcode.

(b) If an existing structure is damaged by fire or any other cause, the requirements of N.J.A.C. 5:23-6, Rehabilitation Subcode, shall apply to the restoration of such building or structure.

(c) Any work which is mandated by any housing, property or fire safety maintenance code, standard or regulation or other State or local law requiring improvements to buildings or structures shall be made to conform only to the requirements of that code, standard, law or regulation and shall not be required to conform to the subcodes adopted pursuant to this chapter unless the code requiring the alteration so provides.

1. Except as otherwise provided in N.J.A.C. 5:23-6.2(g), any requirement of any other code, standard, regulation, ordinance or law that is more restrictive than any requirement of N.J.A.C. 5:23-6 applicable to the same issue shall not be enforceable.

Amended by R.1985 d.16, effective February 4, 1985.

See: 16 N.J.R. 3073(b), 17 N.J.R. 275(a).

(a)7 added.

Amended by R.1995 d.144, effective March 20, 1995 (operative July 1, 1995).

See: 26 N.J.R. 2698(a), 26 N.J.R. 3524(a), 27 N.J.R. 1180(a).

Amended by R.1995 d.381, effective July 17, 1995.

See: 27 N.J.R. 970(a), 27 N.J.R. 2715(a).

Amended by R.1998 d.28, effective January 5, 1998.

See: 29 N.J.R. 3603(a), 30 N.J.R. 129(a).

Rewrote (a) stating existing structures shall conform to 5:23-6, "Rehabilitation Subcode"; deleted (a)1 through (a)6; rewrote (b), (c) and inserted (c)1; deleted (a)7 through (b)1.

Amended by R.2002 d.5, effective January 7, 2002.

See: 33 N.J.R. 3392(a), 34 N.J.R. 267(a).

Rewrote (c)1.

5:23-2.5 Concerning increase in size

If the structure is increased in floor area or height, then the increased portion of the structure shall conform to the requirements of this chapter applicable to new construction, while any related work within the existing structure shall conform with the requirements of N.J.A.C. 5:23-6, Rehabilitation Subcode.

Amended by R.1988 d.389, effective August 15, 1988.
 See: 20 N.J.R. 1026(a), 20 N.J.R. 2073(a).
 Amended by R.1993 d.61, effective February 1, 1993.
 See: 24 N.J.R. 1421(a), 25 N.J.R. 463(c).
 Hardwired smoke detectors added.
 Amended by R.1994 d.433, effective September 6, 1994 (operative January 1, 1995).
 See: 26 N.J.R. 1910(a), 26 N.J.R. 3706(a).
 Amended by R.1997 d.409, effective October 6, 1997.
 See: 29 N.J.R. 2736(a), 29 N.J.R. 4281(a).
 In (a)2, amended NFIPA reference.
 Amended by R.1998 d.28, effective January 5, 1998.
 See: 29 N.J.R. 3603(a), 30 N.J.R. 129(a).
 Rewrote (a) to conform with "Rehabilitation Subcode"; deleted (a)1 through (c)

Case Notes

Municipal order under zoning ordinance to remove sleeping trailers and disconnect utilities used by refinery repair crew proper exercise of police power; action not preempted by Occupational Safety and Health Act. *Twp. of Greenwich v. Mobil Oil Corp.*, 504 F.Supp. 1275 (D.N.J. 1981).

Permits required to ensure use of proper materials and construction methods; permit requirements not inconsistent with pollution control laws; sewerage authority obliged to obtain local permits and approval before beginning pumping station construction. *Shupack v. Manasquan River Regional Sewerage Authority*, 194 N.J.Super. 199, 476 A.2d 816 (App.Div.1984).

5:23-2.6 Change of use

(a) Continuation of existing use: The legal use of any structure existing on the effective date of the regulations may be continued without change, except as may be specifically provided in these regulations or in any property or fire safety maintenance code, or minimum housing standard or regulation, adopted pursuant to law.

1. A certificate of continued occupancy shall be granted upon request, subject to this subchapter.

(b) Change of use: It shall be unlawful to change the use of any structure or portion thereof without the prior application for and issuance of a certificate of occupancy as herein provided.

1. A certificate of occupancy shall be issued provided such structure shall comply with the provisions of N.J.A.C. 5:23-6, Rehabilitation Subcode.

2. If any non-residential occupancy, other than Use Groups F, H or S, accommodates seven or more non-consecutive group overnight stays within a calendar year for persons over 2½ years of age, and the activities involve planned periods of sleep, the building is considered to have undergone a change of use. In such a case, it shall be necessary to apply for and be issued a Certificate of Occupancy. This shall be a dual Certificate of Occupancy to allow Use Group R-1 in addition to the existing use of the building. Any facility that accommodates six or fewer overnight stays within a calendar year shall obtain a permit under the Uniform Fire Code, N.J.A.C. 5:70. Group overnight stays in Use Groups F, H and S shall be prohibited.

3. The temporary or permanent use of an existing structure as a "special amusement building," as defined in the building subcode, shall be a change in the character of use of the existing building. The building or portion thereof shall be required to comply with the building subcode and fire protection subcode requirements of N.J.A.C. 5:23-6.31(a)5x.

Amended by R.1985 d.16, effective February 4, 1985.
 See: 16 N.J.R. 3073(b), 17 N.J.R. 275(a).
 (a) Added text: "or fire safety" and "or minimum housing standard or regulation".
 Amended by R.1993 d.662, effective December 20, 1993.
 See: 25 N.J.R. 3891(a), 25 N.J.R. 5918(a).
 Amended by R.1995 d.144, effective March 20, 1995 (operative July 1, 1995).
 See: 26 N.J.R. 2698(a), 26 N.J.R. 3524(a), 27 N.J.R. 1180(a).
 Amended by R.1995 d.611, effective December 4, 1995 (operative April 4, 1996).
 See: 27 N.J.R. 3257(a), 27 N.J.R. 4884(a).
 Amended by R.1998 d.28, effective January 5, 1998.
 See: 29 N.J.R. 3603(a), 30 N.J.R. 129(a).
 New heading "Change of use"; rewrote (b); added "Rehabilitation Subcode" in (b)1; deleted (b)1i through (c).
 Amended by R.2002 d.255, effective August 5, 2002.
 See: 33 N.J.R. 4177(a), 34 N.J.R. 2783(a).
 In (b), added 2.
 Amended by R.2003 d.157, effective April 21, 2003.
 See: 34 N.J.R. 4247(a), 35 N.J.R. 1663(b).
 In (b), added 3.

Case Notes

Civil rights action challenging township actions regarding use of property as church were not ripe for adjudication until township planning board decided site plan application and any need for variance. *Trinity Resources, Inc. v. Township of Delanco*, D.N.J.1994, 842 F.Supp. 782.

5:23-2.7 Ordinary maintenance

(a) Ordinary maintenance to structures may be made without filing a permit application with or giving notice to the construction official.

(b) Such maintenance shall not include any of the following:

1. The cutting away of any wall, partition or portion thereof;
2. The removal or cutting of any structural beam or bearing support;
3. The removal or change of any required means of egress, or rearrangement of parts of a structure affecting the exitway requirements;
4. Any work affecting structural or fire safety;
5. Any work that will increase the nonconformity of any existing building or structure with the requirements of the regulations;
6. Addition to, or alteration, replacement or relocation of:
 - i. Any standpipe;

Amended by R.1982 d.436, effective December 20, 1982.

See: 14 N.J.R. 734(a), 14 N.J.R. 1449(a).

Added appeals to be made to the Division of Housing, cases to be heard by the OAL with final decision by the Commissioner. Also added APA cite.

Amended by R.1988 d.352, effective August 1, 1988.

See: 19 N.J.R. 1270(a), 20 N.J.R. 1873(b).

Added (b).

Amended by R.1991 d.428, effective August 19, 1991.

See: 23 N.J.R. 1730(a), 23 N.J.R. 2500(d).

In (b), added codification 1 through 5. In (b)3, added "what corrective measures shall be required by owner or agency".

Amended by R.1997 d.409, effective October 6, 1997.

See: 29 N.J.R. 2736(a), 29 N.J.R. 4281(a).

In (a), inserted N.J.S.A. reference, amended Division name, and designated second and third sentences as (a)1 and 2; in (a)2, amended N.J.S.A. references and substituted "construction boards of appeal" for "county or municipal boards".

Amended by R.1997 d.417, effective October 6, 1997.

See: 29 N.J.R. 3387(a), 29 N.J.R. 4285(a).

In (a), amended where to appeal.

Amended by R.1999 d.351, effective October 18, 1999.

See: 31 N.J.R. 1838(a), 31 N.J.R. 3082(a).

In (b), inserted a reference to owners and administering agencies, and changed N.J.A.C. reference in the introductory paragraph.

5:23-2.39 Automatic fire suppression systems

(a) Applications for tax exemption pursuant to P.L. 1983, c.309 shall be made on a form prepared by the Department of Treasury, Division of Taxation, and made available to the public at the office of the enforcing agency.

(b) Construction official's responsibilities:

1. The construction official shall have responsibility for determining the eligibility of any proposed automatic fire suppression systems.

2. The construction official shall consult with the appropriate subcode officials in determining conformity with the building and fire protection subcodes and their referenced standards, as well as, where applicable, the most recently published editions of NFPA 13D, NFPA 20, NFPA 22 and NFPA 24. A system shall only be eligible for tax exemption if it conforms to such of these standards as are applicable to that type of automatic fire suppression system and appurtenant installations.

i. A system shall not be deemed ineligible because it is in a new building or because it only provides coverage to part of a building.

3. The construction official shall, in addition, review the cost estimates provided by the applicant.

4. The construction official may require documentation in the form of signed contracts, contractor estimates and the like if he deems it necessary.

5. The construction official shall grant or deny certification of the system prior to issuance of the construction permit and shall notify the applicant of his decision at that time.

6. The construction official shall forward a copy of the approved application for exemption to the municipal assessor for his action upon issuance of the certificate of occupancy or certification of completion.

(c) The enforcing agency, after giving written notice to the owner, may revoke such certification whenever any of the following appears:

1. The exemption was obtained by fraud or misrepresentation;

2. The claimant for tax exemption has failed substantially to proceed with the construction, reconstruction, installation or acquisition of an automatic fire suppression system;

3. The mechanical system to which the certificate relates has ceased to be used for the primary purpose of providing automatic fire suppression and is being used for a different primary purpose;

4. The claimant for tax exemption hereunder has so departed from the equipment, design and construction previously certified by the enforcing agency that, in the opinion of said enforcing agency, the automatic fire suppression system is not suitable and reasonably adequate for the purpose of providing automatic fire suppression.

(d) The construction official shall notify the assessor in writing of the revocation of the certification.

(e) Appeals may be made regarding the decision of the construction official to the Construction Board of Appeals having jurisdiction, in accordance with N.J.A.C. 5:23A.

New Rule, R.1984 d.121, effective April 16, 1984.

See: 16 N.J.R. 180(a), 16 N.J.R. 874(a).

This section replaces 5:23-6.2, Construction Official's Responsibilities, which was recodified as N.J.A.C. 5:23-6.1(b).

Recodified from 5:23-6.2 by R.1987 d.387, effective October 5, 1987.

See: 19 N.J.R. 433(b), 19 N.J.R. 1793(a).

Recodified from 5:23-6.4 and amended by R.1997 d.409, effective October 6, 1997.

See: 29 N.J.R. 2736(a), 29 N.J.R. 4281(a).

In (e), amended N.J.A.C. reference.

SUBCHAPTER 3. SUBCODES

5:23-3.1 Title; scope; intent

(a) This section of the regulations, adopted pursuant to authority of the State Uniform Construction Code Act and entitled "Subcodes," shall be known and may be cited throughout the regulations as "N.J.A.C. 5:23-3," and when referred to in this subchapter may be cited as "this subchapter."

(b) When used alone, the term "subchapter," "section," and so forth, refers to that portion of the regulations. When used in conjunction with the term "building subcode," "plumbing subcode" or "electrical subcode," and so forth, the term "article" or "section," and so forth, refers to that subcode.

(c) This subchapter shall control matters relating to:

1. The adoption of subcodes of the Uniform Construction Code.
2. Modifications to the subcodes adopted.
3. The organization of enforcement responsibilities.
4. The use of standards of accepted practice.
5. Approvals and interrelations.
6. The division of plan review responsibilities and State reserved activities; and
7. Procedures for adoption of future subcode amendments.

(d) This subchapter provides a uniform system of construction standards throughout the State through the adoption of model codes applicable throughout the State. Modifications made to the subcodes are for the purpose of providing a uniform, harmonious system of construction code interface and administration, and to resolve conflicts with preempting Federal and State legislation.

(e) Provisions concerning underground storage tanks, jointly enforced by the Department of Environmental Protection (DEP), are in N.J.A.C. 5:23-3.11B and in the DEP's rules at N.J.A.C. 7:14B.

Amended by R.1990 d.562, effective November 19, 1990.
See: 22 N.J.R. 2629(c), 22 N.J.R. 3482(d).
Added reference to N.J.A.C. 7:14B.

5:23-3.2 Matters covered; exceptions

(a) Except as is otherwise provided in (b), (c) and (d) below, the provisions of this subchapter shall apply uniformly throughout the State. Any standards other than those provided herein are void and of no effect.

(b) Rules concerning exceptions in health care facilities are as follows:

1. Construction or rehabilitation of health care facilities shall be in accordance with this code and with the "Guidelines for Construction and Equipment of Hospital and Medical Facilities" (American Institute of Architects Committee on Architecture for Health), 1996-1997 edition or current edition. In the event of any conflict, the more restrictive code provision shall govern.
2. The Department of Health may adopt licensing standards for the physical plant and environment of health care facilities that supplement this code and the

"Guidelines for Construction and Equipment of Hospital and Medical Facilities," although these standards may not be in conflict with these codes.

3. The publication "Guidelines for Construction and Equipment of Hospital and Medical Facilities" is available from The American Institute of Architects Press, 1735 New York Ave., N.W., Washington, D.C. 20006.

(c) Individual on-site water supply and sewage disposal systems shall be in accordance with N.J.S.A. 58:11-23 et seq., and N.J.A.C. 7:10-3.1 et seq. and N.J.A.C. 7:9-2.1 et seq.

(d) Rules concerning commercial farm buildings are as follows:

1. A commercial farm building means any building located on a commercial farm which produces not less than \$2,500 worth of agricultural or horticultural products annually which building's main use or intended use is related to the production of agricultural or horticultural products produced on that farm.

2. Buildings constructed in accordance with the provisions of this section and meeting the requirements of (d)1 above shall be classified as commercial farm buildings. For those provisions not covered by this section, commercial farm buildings shall comply with the construction code provisions applicable to Use Group S-2. Commercial farm buildings shall include, but not be limited to, the following: stall barns, milking parlors, poultry houses, horse arenas, packing houses for agricultural or horticultural commodities, farrowing houses, greenhouses, and buildings used for the storage of agricultural or horticultural products, farm machinery and farm equipment, or farm materials and supplies that are produced or used on the farm.

3. Pre-engineered grain bins, silos, manure handling equipment and impoundments used on a farm for the storage of agricultural commodities or by-products which are produced by or used on the farm shall not require a construction permit. However, all on-site construction work such as foundations and plumbing and electrical connections shall be subject to all requirements and inspections of any applicable subcode(s).

4. The type and amount of materials or supplies stored in a commercial farm building, including hay, straw, and livestock bedding materials, shall not be subject to limitation. However, other hazardous materials within spaces of commercial farm buildings occupied by more than 10 persons shall not exceed the allowable exempt amounts shown in Tables 307.8(1) and 307.8(2) of the building subcode unless separated from the occupied area by appropriate fire resistance rated construction as prescribed in the building subcode.

5. A commercial farm building may be used as a place of public assembly for not more than 15 days in a

calendar year. For the purposes of enforcing this requirement, a public assembly shall be a gathering of 50 or more people. A permit shall be obtained from the local fire official pursuant to the Uniform Fire Safety Act, N.J.S.A. 52:27D-192 et seq., and the fee for issuing the permit shall not exceed \$75.00 per event.

i. A commercial farm building that is used as a place of public assembly for not more than 15 days in a calendar year and that is provided with electricity shall comply with section 1024 of the BOCA National Building Code.

ii. The temporary or permanent use of a commercial farm building as a "special amusement building," as defined in the building subcode, shall be a change in the character of use of the existing building. The building or portion thereof shall be required to comply with the building subcode and fire protection subcode requirements of N.J.A.C. 5:23-6.31(a)5x.

6. Buildings containing any of the following uses are not included in the definition of a commercial farm building:

i. Residential structures;

ii. High hazard facilities, such as grain elevators or grain storage silos used to store products which are neither used nor produced on the farm itself;

iii. Processing facilities that include specialized machinery to perform functions other than the washing, cleaning, hydrocooling, vacuum cooling, grading, sizing and packing of agricultural or horticultural products, unless the exempted functions are only the first step in a sequence of processing to be performed on the farm;

iv. Mercantile structures, such as farm retail markets or nursery greenhouse retail sales areas;

v. Offices with either 11 or more occupants, or floor area of greater than 1,200 square feet; and

vi. Buildings that contain any use not included in the definition of commercial farm building, except incidental offices as provided in (d)9vii below.

7. A commercial farm building may include a use that does not meet the definition of a "commercial farm building," provided that the space that does not meet the commercial farm building definition is separate from the remainder of the building with the required fire separation assemblies and meets all applicable requirements of the building subcode.

8. Construction type, height and allowable area requirements for commercial farm buildings and structures shall be as specified in the building subcode and shall not exceed the area or height limitations of Table 503 for the type of construction used, except as follows:

i. The height and area of a one story commercial farm building of any type of construction shall not be limited if the building meets the fire resistance rating and fire separation distance as specified in section 507.2 of the building subcode.

ii. The height and area of a two story commercial farm building of any type of construction shall not be limited if the building meets the fire resistance rating and fire separation distance as specified in section 507.2 of the building subcode and is provided with an approved automatic fire suppression system throughout, conforming to the Uniform Construction Code.

iii. Two or more commercial farm buildings excepted under (d)8i and ii above may be constructed on the same lot, or on an owner's contiguous lots without meeting the fire separation distance between them specified in section 507.2 of the building subcode. However, the fire separation distance specified in section 507.2 of the building subcode must be maintained between a commercial farm building and any building not eligible for this exemption.

9. Commercial farm buildings exempted under (d)8i above shall meet the following requirements in lieu of those requirements specified in the subsections of Chapter 10, Means of Egress, of the BOCA National Building Code:

i. In lieu of the requirements of Section 1006.0, the maximum distance of travel from any point in the building to an exit shall not exceed 150 feet;

ii. In lieu of the requirements of Section 1010.0, one exit is required for each 15,000 square feet of floor area and fraction thereof;

iii. In lieu of the requirements of Section 1023.0, exit signs must be posted. Exit signs are not required to be illuminated;

iv. The provisions of section 1024.0 shall apply in commercial farm buildings where the owner has determined to provide electricity. Where electricity is provided, any electric light provided in the commercial farm building shall be deemed to meet the means of egress lighting requirements and a back up power source shall not be required unless the commercial farm building will be used as a place of public assembly in accordance with (d)5 above.

v. In lieu of the requirements of section 1008.0, occupancy is limited to 30 people;

vi. Lightning protection of the type required for the structure by NFIPA 780, fire extinguishers and "no smoking" signs shall be provided;

vii. Offices with 10 or fewer occupants and a floor area not in excess of 1,200 square feet shall be considered incidental to the structure, if direct exit to the exterior is provided.

10. Site plans signed and sealed by a registered architect or a licensed engineer, pursuant to N.J.A.C. 5:23-2.15(e)1viii, shall not be required, provided that a sketch plan of the site is submitted to the construction official.

Amended by R.1981 d.132, effective May 7, 1981.
 See: 13 N.J.R. 121(a), 13 N.J.R. 258(d).
 Amended by R.1986 d.448, effective November 3, 1986.
 See: 18 N.J.R. 757(a), 18 N.J.R. 2194(a).
 Deleted (b)1 and 4; recodified (b)2 and 3 to (b)1 and 2.
 Amended by R.1987 d.374, effective September 21, 1987.
 See: 19 N.J.R. 1024(a), 19 N.J.R. 1720(b).
 (b)1: model subcode revisions.
 Amended by R.1988 d.144, effective April 4, 1988.
 See: 19 N.J.R. 1778(a), 20 N.J.R. 783(a).
 Changed (b)2 to (c) and (d).
 Amended by R.1993 d.662, effective December 20, 1993.
 See: 25 N.J.R. 3891(a), 25 N.J.R. 5918(a).
 Amended by R.1995 d.603, effective November 20, 1995 (operative March 20, 1996).
 See: 27 N.J.R. 2655(a), 27 N.J.R. 4699(a).
 Amended by R.1997 d.269, effective July 7, 1997.
 See: 29 N.J.R. 968(a), 29 N.J.R. 2817(a).
 Inserted (d)5i; in (d)6vi, amended N.J.A.C. reference; in (d)8, inserted reference to construction type and inserted “, except as follows:”; deleted (d)8i; recodified former (d)8i(1) through (3) as (d)8i through iii; inserted new (d)9iv; recodified former (d)9iv through vi as (d)9v through vii; and recodified former (e) as (d)10.
 Amended by R.1997 d.417, effective October 6, 1997.
 See: 29 N.J.R. 3387(a), 29 N.J.R. 4285(a).
 Substantially amended (b)1.
 Amended by R.1999 d.424, effective December 6, 1999.
 See: 31 N.J.R. 2428(a), 31 N.J.R. 4001(c).
 In (a)1, substituted a reference to rehabilitation for a reference to alteration, and changed guideline reference.
 Administrative correction.
 See: 33 N.J.R. 3735(a).
 Amended by R.2003 d.157, effective April 21, 2003.
 See: 34 N.J.R. 4247(a), 35 N.J.R. 1663(b).
 In (d)5, added ii.

5:23-3.3 Enforcement

(a) In accordance with the delineation of responsibility for enforcement specified herein, subject to specific reservations by the Department to itself, the appropriate official(s) shall enforce the subcode and shall act on any question relative to the mode or manner of construction, and the materials to be used in the erection, addition to, repair, renovation, alteration, reconstruction, removal, demolition, installation of service equipment, and the location, use and occupancy of all buildings and structures, except as may be otherwise specifically provided for in the regulations, including, but not limited to:

1. Applications, certificates and permits: Such official(s) shall review applications for permits for the erection, repair (other than ordinary maintenance), renovation, alteration and reconstruction of buildings and structures; indicate approval or denial to the construction official; and inspect the premises for which such permits have been issued and enforce compliance with the provisions of the regulations.

2. Notices and orders: Such official(s) shall issue all necessary notices or orders to remove illegal or unsafe conditions; to require the necessary safeguards during

construction; and to insure compliance with all requirements for the safety, health and general welfare of the public.

3. Inspections: Such official(s) shall make all the required inspections, and all reports of such inspections shall be in writing and certified by them or they may engage such expert opinion as he may deem necessary to report upon unusual technical issues that may arise, subject to the approval of the construction official and appointing authority.

4. Enforcing agency records: Such official(s) shall assist in the keeping of official records of applications received, permits and certificates issued, fees collected, reports of inspections, and notices and orders issued as may be required by the construction official.

Amended by R.1998 d.28, effective January 5, 1998.
 See: 29 N.J.R. 3603(a), 30 N.J.R. 129(a).
 Amended by R.1999 d.424, effective December 6, 1999.
 See: 31 N.J.R. 2428(a), 31 N.J.R. 4001(c).

In (a), deleted a reference to other State agencies in the introductory paragraph, and substituted a reference to ordinary maintenance for a reference to ordinary repairs in 1.

5:23-3.4 Responsibilities

(a) An individual acting as a building subcode official or building inspector shall have responsibility for enforcing the adopted subcodes listed below.

1. Plan review for the sections listed below shall be the responsibility of the building subcode official:

BUILDING SUBCODE

Chapter 3 ^F	Chapters 22-25
Chapter 4 as follows:	Chapter 26 as follows:
401.0-403.7 ^F	2601.0-2601.2
403.10-405.6 ^F	2603.0-2605.0 ^F
406.0 ^F	2606.0-2609.0
407.0	Chapter 28
408.0-414.4 ^F	Chapter 30 as follows:
416.0-416.10 ^F	3001.0 ^{EL}
416.12-416.14.5 ^F	3006.0-3011.0 ^{EL, F}
416.15-417.5.3 ^F	Chapter 31 as follows:
417.5.5-419.3 ^F	3101.0-3105.0
420.0-421.11	3106.0 ^F
Chapters 5-6	3107.0-3111.0
Chapters 7-8 ^F	Chapter 32
Chapter 10 ^F	Chapter 33 as follows:
Chapter 12	3301.0-3304.0
Chapter 14-20	3305.0 ^F
Chapter 21 as follows:	3306.0-3315.0
2101.0-2112.0	Chapter 34 as follows:
2113.0-2117.0 ^F	3406.0 ^F
2118.0	

ELECTRICAL SUBCODE

Section 250-50(c)^EConcrete-Encased Electrode—as applicable

MECHANICAL SUBCODE

Chapter 3 as follows:

301^F
 302
 308^F
 310^F
 311^F
 Chapter 4
 Chapter 5 as follows:
 501
 502^F through 511^F
 512
 513^F
 Chapter 6^F
 Chapter 8^F
 Chapter 9^F (All except 908.5,
 908.6 and 908.7)
 Chapter 13 as follows:
 1301.2^{F, P}
 1301.3^F
 1301.4^{F, P}
 1306^F
 Chapter 14^P

402.14-403.1
 403.3.3
 404.1
 404.3
 404.5
 404.7-405.2
 405.4
 406.0-408.3
 408.3.2-409.4
 410.0-412.5
 413.1-413.2
 413.5.3-414.4
 415.0-416.3
 416.6-416.10
 416.12-416.14.5
 416.16-416.15.1
 416.15.3
 417.6.4-417.6.5
 418.1-418.3.1.6
 418.3.3.3-421.11

Chapters 14-20
 Chapter 21
 Chapters 22-26
 Chapter 28
 Chapter 30 as follows:
 3007.1
 3007.4-3007.6
 3008.1-3008.3
 3010.1-3010.2.1
 3010.2.3
 3010.4
 3011.2
 3011.2.1
 Chapters 31-32
 Chapter 33 as follows:
 3301.0-3304.0
 3306.0-3315.0
 Chapter 34 as follows:
 3406.0

ENERGY SUBCODE

Chapter 1 as applicable	Chapter 6 as follows:
Chapters 3-4	602
Chapter 5 as follows:	603
502	
503	

FUEL GAS SUBCODE

Chapter 3 as follows:
 301.8
 301.10
 301.11
 301.12
 301.13^F
 301.14
 301.15
 302
 308^F
 Chapter 5^F
 Chapter 6^F
 (All except 623, 625,
 626.2, 626.3, 626.8,
 626.9, 627.4 & 630)

E = Joint with Electrical Subcode Official
 EL = Joint with Elevator Subcode Official for devices covered by N.J.A.C. 5:23-12 except those installed in Use Group R-3, R-4, or in R-2 structures where the elevator devices are wholly within dwelling units and not accessible to the general public.
 F = Joint with Fire Protection Subcode Official
 P = Joint with Plumbing Subcode Official

2. Field inspection for the sections listed below shall be performed by an inspector possessing a building technical license.

BUILDING SUBCODE

Chapter 3	Chapters 5-8
Chapter 4 as follows:	Chapter 10
401.0-402.9	Chapter 12

ELECTRICAL SUBCODE

Section 250-50(c) Concrete-Encased Electrode—as applicable

MECHANICAL SUBCODE

Chapter 3 as follows:
 301
 302
 Chapter 4
 Chapter 5 as follows:
 501
 502
 504
 510 through 512
 Chapter 6
 Chapter 8 as follows:
 801.3
 Chapter 9
 (All except:
 908.5, 908.6 and
 908.7)
 Chapter 13 as follows:
 1301.2
 1301.3
 1301.4^P
 1306

ENERGY SUBCODE

Chapter 1 as applicable	Chapter 6 as follows:
Chapters 3-4	602
Chapter 5 as follows:	603
502	
503	

FUEL GAS SUBCODE

Chapter 3 as follows:
 301.8
 301.10 through 301.15
 302
 Chapter 5 as follows:
 501.3
 501.7
 501.11

- 501.15.3
- 503.5.3
- Chapter 6 as follows:
- 602
- 608 through 613
- 614 (All except 614.4 and 614.5)
- 616 through 618
- 619 (All except 619.4)
- 620 through 622
- 624
- 626.1
- 626.4 through 626.7
- 627 (All except 627.4)
- 628
- 629
- 632

- 626.2
 - 626.3
 - 626.8
 - 626.9
 - 627.4
 - 630
- B = Joint with Building Subcode Official
 F = Joint with Fire Subcode Official

2. Field inspection for the sections listed below shall be performed by an inspector possessing a plumbing technical license.

P = Joint with Plumbing Subcode Official

(b) An individual acting as a plumbing subcode official or plumbing inspector shall have the responsibility for enforcing the adopted subcodes as listed below.

1. Plan review for the sections listed below shall be the responsibility of the plumbing subcode official:

PLUMBING SUBCODE

ALL

MECHANICAL SUBCODE

- Chapter 3 as follows:
- 305
- 307
- Chapter 9 as follows:
- 908.5
- 908.6
- 908.7^F
- Chapter 10
- Chapter 11
- Chapter 12
- Chapter 13 as follows:
- 1301.2^{B, F}
- 1301.4^{B, F}
- 1302 through 1305
- 1307
- 1308
- Chapter 14^B

ENERGY SUBCODE

- Chapter 1 as applicable
- Chapter 5 as follows:
- 504
- Chapter 6 as follows:
- 604

B = Joint with Building Subcode Official

FUEL GAS SUBCODE

- Chapter 3 as follows:
- 301.6
- 307
- Chapter 4
- Chapter 6 as follows:
- 623
- 625

ALL

MECHANICAL SUBCODE

- Chapter 3 as follows:
- 305
- 307
- Chapter 9 as follows:
- 908.5 through 908.7
- Chapter 10
- Chapter 11
- Chapter 12
- Chapter 13 as follows:
- 1301.4^B
- 1302 through 1305
- 1307
- 1308
- Chapter 14

ENERGY SUBCODE

- Chapter 1 as applicable
- Chapter 5 as follows:
- 504
- Chapter 6 as follows:
- 604

FUEL GAS SUBCODE

- Chapter 3 as follows:
- 301.6
- 307
- Chapter 4
- Chapter 6 as follows:
- 623
- 625
- 626.2
- 626.3
- 626.8
- 626.9
- 627.4
- 630

B = Joint with Building Subcode Official

(c) An individual acting as an electrical subcode official or electrical inspector shall have responsibility for enforcing the adopted subcodes as listed below:

1. Plan review for the sections listed below shall be the responsibility of the electrical subcode official:

BUILDING SUBCODE

Chapter 4 as follows: 416.11^F
 403.9^F 416.14.6^F
 405.7-405.9^F 417.5.4^F
 414.5^F

ELECTRICAL SUBCODE

Article 90—Introduction

Chapter 1	Chapter 5 ^F
Chapter 2 as follows:	Chapter 6 as follows:
200-1 to 250-50(b)	600 to 610
250-50(c) ^B	620 ^{EL}
250-50(d) to 280-25	625 to 690
Chapter 3 as follows:	695 ^F
300-1 to 300-20	Chapter 7 as follows:
300-21 ^F	700 to 727
300-22 to 384	760 ^F
Chapter 4 as follows:	770 to 780
400 to 450 part B	Chapter 8
450 part C ^F	Chapter 9
455 to 480	

ENERGY SUBCODE

Chapter 1 as applicable	Chapter 6 as follows:
Chapter 5 as follows:	605
505	

F = Joint with Fire Subcode Official
 E = Joint with Electrical Subcode Official
 EL = Joint with Elevator Subcode Official for N.J.A.C. 5:23-12 devices not installed in Use Group R-3, R-4, or in R-2 structures in which the elevator devices are wholly within dwelling units and are not accessible to the general public.

2. Field inspection for the sections listed below shall be performed by an inspector possessing an electrical technical license.

ELECTRICAL SUBCODE

Article 90 Introduction

Chapter 1

Chapter 2 (except for section 250-50(c) Concrete-Encased Electrode)

Chapters 3-5

Chapter 6 as follows:

600-610

620 (Note: The following sections are enforced by the electrical inspector when N.J.A.C. 5:23-12 devices are installed in any use group structures excluding installations in Use Group R-3, R-4, or R-2 where the elevator devices are located wholly within dwelling units and are not accessible to the general public.)

620-13 (on the line side of the machine room/machinery space disconnect(s))

620-22 (on the line side of the machine room/machinery space disconnects(s))

620-23

620-24

620-38 (for elect. equipment and materials only)

620-51 (except for (b), (c) and (d))

620-61(c) and 620-61(d) (on the line side of the machine room/machinery space disconnect(s))

620-85 (except for cartop receptacles)

620-91(b)

625-695

Chapters 7-9

N.J.A.C. 5:23-3.16(c) Automatic rain sensor device

ENERGY SUBCODE

Chapter 1 as applicable	Chapter 6 as follows:
Chapter 5 as follows:	605
505	

(d) An individual acting as a fire protection subcode official or fire protection inspector shall have responsibility for enforcing the adopted subcodes as listed below.

1. Plan review for the sections listed below shall be the responsibility of the fire protection subcode official:

BUILDING SUBCODE

Chapter 3 ^B	Chapters 7-8 ^B
Chapter 4 as follows:	Chapter 9
401.0-403.7 ^B	Chapter 10 ^B
403.9 ^E	Chapter 21 as follows:
403.10-405.6 ^B	2113.0-2117.0 ^B
405.7-405.9 ^E	Chapter 26 as follows:
406.0 ^B	2603.0-2605.0 ^B
408.0-414.4 ^B	Chapter 30 as follows:
414.5 ^E	3006.0-3011.0 ^{B, EL}
416.0-416.10 ^B	Chapter 31 as follows:
416.11 ^E	3106.0 ^B
416.12-416.14.5 ^B	Chapter 33 as follows:
416.14.6 ^E	3305.0 ^B
416.15-417.5.3 ^B	Chapter 34 as follows:
417.5.4 ^E	3406.0 ^B
417.5.5-419.3 ^B	

MECHANICAL SUBCODE

Chapter 3 as follows:

301^B

303

304
 306
 308^B
 310^B
 311^B
 Chapter 5 as follows:
 502^B through 511^B
 513^B
 Chapter 6^B
 Chapter 7
 Chapter 8^B
 (All except 801.3)
 Chapter 9^B
 (All except 908.5 and
 908.6)
 908.7^P
 Chapter 13 as follows:
 1301.2^{B, P}
 1301.3^B
 1301.4^{B, P}
 1306^B

N.J.A.C. 5:23-3.20(c) Carbon monoxide alarms

ELECTRICAL SUBCODE

Chapter 3 as follows: 300-21 ^E	Chapter 6 as follows: 695 ^E
Chapter 4 as follows: 450 Part C ^E	Chapter 7 as follows: 760 ^E
Chapter 5 ^E	

FUEL GAS SUBCODE

Chapter 3 as follows:
 301.1.1
 301.2 through 301.4
 301.4.1
 301.5
 301.7
 301.13^B
 303 through 306
 308^B
 Chapter 5^B
 Chapter 6^B
 (All except 623, 625,
 626.2, 626.3, 626.8,
 626.9, 627.4 and 630)

B = Joint with Building Subcode Official
 P = Joint with Plumbing Subcode Official
 E = Joint with Electrical Subcode Official
 EL = Joint with Elevator Subcode Official for N.J.A.C. 5:23-12 devices not installed in Use Group R-3, R-4, or in R-2 structures in which the elevator devices are wholly within dwelling units and not accessible to the general public.

2. Field inspection for the sections listed below shall be performed by an inspector possessing a fire protection technical license.

BUILDING SUBCODE

Chapter 4 as follows: 402.10-402.13	416.4-416.5 416.11
--	-----------------------

403.2-403.3.2	416.14.6
403.4-403.7	416.15.2
403.9-403.10	417.1-417.6.3
404.2	417.6.6
404.4	418.3.2-418.3.3.2
404.6	Chapter 9
405.3	Chapter 30 as follows: 3007.3
405.5-405.9	3010.2.2
408.3.1	3011.2.2
409.5	Chapter 33 as follows: 3305.0
412.6-412.8	
413.3-413.5.2	
414.5	

MECHANICAL SUBCODE

Chapter 3 as follows:
 303
 304
 306
 308
 310
 311
 Chapter 5 as follows:
 503
 505 through 509
 513
 Chapter 7
 Chapter 8
 (All except 801.3)

N.J.A.C. 5:23-3.20(c) Carbon monoxide alarms

FUEL GAS SUBCODE

Chapter 3 as follows:
 301.1.1
 301.2
 301.3
 301.4
 301.4.1
 301.5
 301.7
 303 through 306
 308
 Chapter 5
 (All except
 501.3
 501.7
 501.11
 501.15.3
 503.5.3)
 Chapter 6 as follows:
 603 through 607
 614.4
 614.5
 615
 619.4

(e) An individual acting as an elevator subcode official or elevator inspector shall have responsibility for enforcing the adopted subcodes as listed below.

1. Plan review for the sections listed below shall be the responsibility of the elevator subcode official:

BUILDING SUBCODE

Chapter 4 as follows[†]:

403.8

Chapter 30 as follows[†]:3001.0^B

3003.3

3006.0-3011.0^{B, F}

ELECTRICAL SUBCODE

Chapter 6 as follows[†]:620^E

ELEVATOR SUBCODE

All (except as otherwise provided for in N.J.A.C. 5:23-12)

B = Joint with Building Subcode Official

E = Joint with Electrical Subcode Official

F = Joint with Fire Protection Subcode Official

[†]These sections are enforced by the elevator subcode official when elevator devices covered by N.J.A.C. 5:23-12 are installed in any use group structures excluding installations in Use Group R-3, R-4, or R-2 where the elevator devices are located wholly within dwelling units and are not accessible to the general public.

2. Field inspection for the sections listed below shall be performed by an inspector possessing an elevator technical license:

BUILDING SUBCODE

Chapter 4 as follows[†]:

403.8

3007.7

3008.4

Chapter 30 as follows[†]:

3001.0

3009.0

3003.3

3010.3

3006.0

3010.5

3007.2

3011.1

ELECTRICAL SUBCODE

Article 620 as follows[†]:

Part A and B excluding Sections 620-13 and 620-22 on the line side of the machine room/machinery space disconnect(s)

Part C (except Sections 620-23 and 620-24)

Part D (except Section 620-38)

Part E

Part F excluding Sections 620-51 and 620-51(a)

Part G excluding Sections 620-61(c) and 620-61(d) on the line side of the machine room/machinery space disconnect(s)

Part H

Part J (except Section 620-85 with the provision that the car top receptacles remains the responsibility of the elevator inspector)

Part K except section 620-91(b)

ELEVATOR SUBCODE

All (except as otherwise provided for in N.J.A.C. 5:23-12)

[†]These sections are enforced by the elevator inspector when elevator devices covered by N.J.A.C. 5:23-12 are installed in any use group structures excluding installations in Use Group R-3, R-4, or R-2 where the elevator devices are located wholly within dwelling units and are not accessible to the general public.

(f) Where responsibility for enforcement of a section is joint between two officials and there are conflicting opinions regarding enforcement, the construction official shall rule as to which interpretation or application shall be followed.

(g) Responsibility for enforcement of the barrier free and radon hazard subcodes shall be as delineated in N.J.A.C. 5:23-7.6A and 10.3, respectively.

(h) A mechanical inspector employed by the Department or by a municipality, and so assigned by the construction official, shall have responsibility for enforcement of all provisions of the code, except electrical, relating to the installation of mechanical equipment, such as refrigeration, air conditioning or ventilating apparatus, gas piping or heating systems, in Use Group R-3 or R-4 structures.

1. When assigned by the construction official, a plumbing subcode official shall have responsibility for the enforcement of all provisions of the code, except electrical, for the replacement of heating or cooling equipment or water heaters in Use Group R-3 and R-4 structures. A plumbing subcode official need not be a mechanical inspector to perform these inspections.

Amended by R.1981 d.132, effective May 7, 1981.

See: 13 N.J.R. 121(a), 13 N.J.R. 258(d).

Amended by R.1986 d.380, effective September 22, 1986.

See: 18 N.J.R. 1235(a), 18 N.J.R. 1931(a), 18 N.J.R. 2063(a).

Substantially amended.

Amended by R.1987 d.14, effective January 5, 1987.

See: 18 N.J.R. 2083(a), 19 N.J.R. 63(a).

(f)4 added; old (f)4-6 renumbered (f)5-7.

Amended by R.1987 d.374, effective September 21, 1987.

See: 19 N.J.R. 1024(a), 19 N.J.R. 1720(b).

(a)1 through 4: model subcode revisions.

Amended by R.1990 d.226, effective May 7, 1990.

See: 21 N.J.R. 3696(a), 22 N.J.R. 1356(a).

Provisions for enforcement of radon subcode added at (g).

Amended by R.1990 d.507, effective October 15, 1990.

See: 22 N.J.R. 2208(a), 22 N.J.R. 3214(a).

Text conformed to BOCA National Code/1990.

Amended by R.1991 d.325, effective July 1, 1991.

See: 23 N.J.R. 805(a), 23 N.J.R. 2046(a).

Other elevator devices covered; enforcement responsibilities clarified.

Amended by R.1992 d.147, effective April 6, 1992.

See: 24 N.J.R. 170(a), 24 N.J.R. 1397(a).

Elevators wholly within R-2 residences exempt.
Amended by R.1992 d.183, effective April 20, 1992.

See: 24 N.J.R. 167(a), 24 N.J.R. 1475(b).

Enforcement of indoor air quality subcode assigned to building subcode official.

Amended by R.1993 d.187, effective May 3, 1993.

See: 25 N.J.R. 624(a), 25 N.J.R. 1875(a).

Added subsection (j); deleted "Allocation of enforcement" from heading.

Amended by R.1993 d.662, effective December 20, 1993.

See: 25 N.J.R. 3891(a), 25 N.J.R. 5918(a).

Amended by R.1995 d.143, effective March 20, 1995 (operative July 1, 1995).

See: 26 N.J.R. 4872(a), 27 N.J.R. 1179(b).

Amended by R.1997 d.409, effective October 6, 1997.

See: 29 N.J.R. 2736(a), 29 N.J.R. 4281(a).

In (g), deleted reference to exception to exclusive authority provided in N.J.A.C. 5:23-3.11(h).

Amended by R.1997 d.418, effective October 6, 1997.

See: 29 N.J.R. 3402(a), 29 N.J.R. 4286(a).

In (f), inserted reference to (j); and added (j)1.

Amended by R.1998 d.28, effective January 5, 1998.

See: 29 N.J.R. 3603(a), 30 N.J.R. 129(a).

Inserted (k) stating responsibility for the enforcement of the rehabilitation subcode.

Repeal and New Rule, R.1998 d.332, effective July 6, 1998.

See: 30 N.J.R. 1377(a), 30 N.J.R. 2421(b).

Section was "Responsibility".

Amended by R.1999 d.259, effective August 16, 1999.

See: 31 N.J.R. 825(a), 31 N.J.R. 2330(a).

In (d)1 and (d)2, under "MECHANICAL SUBCODE", added references to N.J.A.C. 5:23-3.20(c).

Amended by R.2000 d.166, effective April 17, 2000.

See: 31 N.J.R. 4151(a), 32 N.J.R. 1376(a).

In (b)2, changed Chapter 21 and Chapter 31 through 33 references in the Building Subcode, and inserted Chapter 12 reference in the Mechanical Subcode; and in (d)2, deleted a former Chapter 21 reference in the Building Subcode, and changed Chapter 12 reference in the Mechanical Subcode.

Amended by R.2001 d.141, effective May 7, 2001.

See: 32 N.J.R. 3917(a), 33 N.J.R. 746(a), 33 N.J.R. 1399(d).

In (b)1 and (b)2, deleted "as follows: (All except M-801.2)" following "Chapter 8" in the Mechanical Code; in (d)1, deleted "Chapter 8 as follows: M-801.2" in the Mechanical Code; in (d)2, deleted "3007.3" following "413.5.2", inserted "3305.0" following "414.5", and deleted "408.3.1", "3305.0" and "414.5" at the end of the Building Subcode, and deleted "Chapter 8 as follows: M-801.2" in the Mechanical Subcode.

Amended by R.2001 d.196, effective June 18, 2001.

See: 33 N.J.R. 6(a), 33 N.J.R. 2090(a).

In (a)1, (a)2, (b)1, (b)2, (d)1 and (d)2, rewrote Mechanical Subcode and inserted Fuel Gas Subcode.

Amended by R.2001 d.244, effective July 16, 2001 (operative January 16, 2002).

See: 33 N.J.R. 1241(a), 33 N.J.R. 2471(a).

In "ENERGY SUBCODE" categories of (a) through (c), listed specific sections of Chapters 5 and 6, relating to building subcode official responsibility.

Administrative correction.

See: 33 N.J.R. 3308(a).

Amended by R.2002 d.6, effective January 7, 2002.

See: 33 N.J.R. 2570(a), 33 N.J.R. 3883(a), 34 N.J.R. 268(a).

In (a), inserted "ELECTRICAL SUBCODE" in categories 1 and 2, and updated references to officials in "ENERGY SUBCODE" category 1; in (c)1 and 2, updated "ELECTRICAL SUBCODE" chapter references.

Amended by R.2003 d.240, effective June 16, 2003.

See: 34 N.J.R. 3045(a), 35 N.J.R. 2637(c).

In (c)2, added "N.J.A.C. 5:23-3.16(c) Automatic rain sensor device".

5:23-3.5 Posting structures

(a) Posted use and occupancy: Every building and structure and part thereof designed for business, factory and

industrial, high hazard, mercantile, or storage use, (use groups B, F, H, M and S) as defined in article 2 of the building subcode shall be posted on all floors by the owner with a suitably designed placard in a form designated by the building subcode official, which shall be securely fastened to the structure in a readily visible place, stating the use group and the live load and occupancy load.

(b) Posted occupancy load: Every building and structure and part thereof designed for use as a place of public assembly or as an institutional building for harboring people for penal, correctional, educational, medical or other care or treatment (use groups A, E and I) shall be posted with an approved placard designating the maximum occupancy load.

(c) Replacement of posted signs: All posting signs shall be furnished by the owner and shall be of permanent design; they shall not be removed, or defaced and, if lost, removed or defaced, shall be immediately replaced.

(d) Posted hydraulic system data plate: In lieu of the nameplate of the referenced NFPA standard(s), fire sprinkler system contractors are required to identify hydraulically designed fire sprinkler systems by affixing a permanently marked weatherproof metal or rigid plastic sign at the alarm valve. The nameplate shall contain information relative to the design parameters of the system as indicated on Form No. F380. The plate shall be secured at the alarm valve with corrosion resistant wire, chain, or other approved means.

(e) Identifying emblems for structures with truss construction: Identifying emblems shall be permanently affixed to the front of structures with truss construction as required by N.J.A.C. 5:70-2.20.

1. The emblem shall be of a bright and reflective color, or made of reflective material. The shape of the emblem shall be an isosceles triangle and the size shall be 12 inches horizontally by six inches vertically. The following letters, of a size and color to make them conspicuous, shall be printed on the emblem:

- i. "F" to signify a floor with truss construction;
- ii. "R" to signify a roof with truss construction; or
- iii. "F/R" to signify both a floor and roof with truss construction.

2. The emblem shall be permanently affixed to the left of the main entrance door at a height between four and six feet above the ground and shall be installed and maintained by the owner of the building.

3. Detached one and two-family residential structures with truss construction that are not part of a planned real estate development shall be exempt from the requirements of (e) above, unless required by municipal ordinance.

4. Individual structures and dwelling units with truss construction that are part of a planned real estate development shall not be required to have an identifying emblem if there is an emblem affixed at each entrance to the development.

(f) Swimming pools, spas and hot tubs: A valid electrical certificate of compliance and a bonding and grounding certificate shall be posted by the owner in a conspicuous place in or around the pool pump house or equipment control room.

Amended by R.1989 d.555, effective November 6, 1989.
See: 21 N.J.R. 2783(a), 21 N.J.R. 3460(a).

Added reference to E Use Group (educational facilities) at (b).
Amended by R.1990 d.507, effective October 15, 1990.
See: 22 N.J.R. 2208(a), 22 N.J.R. 3214(a).

Text conformed to BOCA National Code/1990.
Amended by R.2000 d.47, effective February 7, 2000.
See: 31 N.J.R. 2314(a), 32 N.J.R. 443(a).

Added (f).
Amended by R.2000 d.166, effective April 17, 2000.
See: 31 N.J.R. 4151(a), 32 N.J.R. 1376(a).

Rewrote (d) and (e).

5:23-3.6 Standards; accepted practice

(a) This chapter, together with the subcodes, national standards and appendices it adopts by reference, shall be the primary guide to accepted engineering practice in respect to any material, equipment, system or method of construction therein specified.

(b) When this chapter and the subcodes, national standards and appendices it adopts by reference are silent, a manufacturer's recommendations for the installation of any material or assembly may be considered to be accepted engineering practice; provided, however, that a manufacturer's recommendations shall not be read to overrule this chapter or any subcode, national standard or appendix which it adopts by reference.

New Rule, R.1988 d.283, effective June 20, 1988.
See: 20 N.J.R. 699(a), 20 N.J.R. 1343(c).

Old text repealed and new text substituted.
Amended by R.1998 d.28, effective January 5, 1998.
See: 29 N.J.R. 3603(a), 30 N.J.R. 129(a).

Case Notes

Contractor not liable for injuries caused by failure of subcontractor to provide and install material in conformance with State building code. *Miltz v. Borroughs—Shelving, a Div. of Lear Siegler, Inc.*, 203 N.J.Super. 451, 497 A.2d 516 (App.Div.1985).

5:23-3.7 Municipal approvals of alternative materials, equipment, or methods of construction

(a) Approvals: Alternative materials, equipment, or methods of construction shall be approved by the appropriate subcode official provided the proposed design is satisfactory and that the materials, equipment, or methods of construction are suitable for the intended use and are at least the equivalent in quality, strength, effectiveness, fire resistance, durability and safety of those conforming with the requirements of the regulations.

1. A field evaluation label and report or letter issued by a nationally recognized testing laboratory verifying that the specific material, equipment, or method of construction meets the identified standards or has been tested and found to be suitable for the intended use, shall be accepted by the appropriate subcode official as meeting the requirements of (a) above.

2. Reports of engineering findings issued by nationally recognized evaluation service programs, such as, but not limited to, the Building Officials and Code Administrators (BOCA), the International Conference of Building Officials (ICBO), the Southern Building Code Congress International (SBCCI), the International Code Council (ICC), and the National Evaluation Service, Inc., shall be accepted by the appropriate subcode official as meeting the requirements of (a) above. The materials, equipment, or assembly shall be installed in accordance with the conditions specified in the report.

(b) Research and investigations: The appropriate subcode official shall require that sufficient technical data be submitted to substantiate the proposed use of any material or assembly, and if it is determined that the evidence submitted is satisfactory proof of performance for the use intended, he may approve its use subject to the requirements of the regulations. The cost of all tests, reports and investigations required under these provisions shall be paid by the applicant.

(c) Research reports: The appropriate subcode official may accept, as supporting data to assist in this determination, duly authenticated research reports from approved authoritative sources for all materials or assemblies proposed for use which are not specifically provided for in the regulations.

Amended by R.1992 d.390, effective October 5, 1992.
See: 24 N.J.R. 1844(a), 24 N.J.R. 3515(b).

Reference to exception in 3.8 added.
Amended by R.2003 d.384, effective October 6, 2003.
See: 35 N.J.R. 2422(a), 35 N.J.R. 4712(a).

Rewrote (a).

5:23-3.8 Products violating the Code

(a) The Department shall, after public hearing and in accordance with the Administrative Procedure Act (P.L. 1968, c.410, as amended), establish and distribute to all enforcing agencies a list of items, devices and materials the regular and intended use of which would violate any provision of the State Uniform Construction Code. A list of such items is set forth in (d) below.

(b) Upon determining that any manufacturer or distributor in the State is selling or offering for retail sale any product on the list which does not have a regular and intended use that does not violate the Code, or any product which may have one or more such non-violative regular and intended use but which is being advertised or promoted for a use that does violate the Code, the Department or any enforcing agency having jurisdiction shall give written notice of the violation of N.J.S.A. 52:27D-138a(5) to such seller. Such notice shall forbid the further sale or offering for retail sale of such product within the State and shall specify a date and time by which such product shall be removed from display to customers.

(c) Any person who, having received a notice of violation pursuant to this section, continues to sell or offer for retail sale products specified in such notice, shall be deemed to be knowingly selling or offering the product for sale in violation of the Code and shall be subject to penalty as provided by statute, in accordance with the procedures set forth in N.J.A.C. 5:23-2.31.

(d) The Commissioner has determined that the following materials and supplies are not in conformance with the State Uniform Construction Code:

1. Building materials and supplies:

i. Wood paneling being used as an interior finish not in conformance with section 803.2 of the building subcode. This section specifies that finish shall be classified in accordance with ASTM E84;

ii. Carpeting used as an interior floor finish material not in conformance with section 805.2 of the building subcode. This section specifies that interior floor finish shall be classified in accordance with ASTM E648; and

2. Electrical materials/supplies:

i. As stated in the National Electric Code (sections 90-7, 110-2, 110-3, and 100), only products listed, labeled, approved, and identified are acceptable. Approval is to be based on tests and listings of testing laboratories such as Underwriters Laboratories Inc. (UL), Factory Mutual (FM), or Canadian Standards Association/Nationally Recognized Testing Laboratory (CSA/NRTL), etc.

3. Plumbing materials/supplies:

i. All purpose solvent cement, except transition glues permitted in the plumbing subcode;

ii. Clear PB piping;

iii. Flexible traps and tailpieces;

iv. Sheet and tubular copper and brass trap and tailpiece fittings less than B & S 17 gauge (.045 in.);

v. Water closets requiring in excess of an average of 1.6 gallons per flush, that either have a manufacturer's date stamp of July 1, 1991 or later or were not purchased by the distributor prior to July 1, 1991;

vi. Plumbing fixtures that do not meet the standards listed in the plumbing subcode.

4. Miscellaneous materials and supplies:

i. Portable unvented natural gas, liquified petroleum gas and kerosene heaters when offered for sale for use in buildings for human occupancy, unless they are tested, listed, labeled and certified by a nationally recognized testing laboratory such as the American Gas Association Laboratories (AGA), Underwriters Laboratories Inc. (UL) or Factory Mutual (FM);

ii. Urea formaldehyde foam insulation, unless offered for sale for use elsewhere than in buildings.

R.1983 d.296, effective August 1, 1983.

See: 15 N.J.R. 587(a), 15 N.J.R. 1247(a).

Amended by R.1985 d.38, effective February 19, 1985.

See: 16 N.J.R. 3074(a), 17 N.J.R. 421(a).

(d) added.

Amended by R.1987 d.374, effective September 21, 1987.

See: 19 N.J.R. 1024(a), 19 N.J.R. 1720(b).

(d)1i and ii: 904.2 was 1404.2; 904.3 was 1404.3.

Amended by R.1990 d.507, effective October 15, 1990.

See: 22 N.J.R. 2208(a), 22 N.J.R. 3214(a).

Text conformed to BOCA National Code/1990.

Amended by R.1992 d.47, effective February 3, 1992.

See: 23 N.J.R. 3602(a), 24 N.J.R. 405(a).

Low volume water closet exception added at (d)4iii.

Amended by R.1993 d.662, effective December 20, 1993.

See: 25 N.J.R. 3891(a), 25 N.J.R. 5918(a).

Amended by R.1997 d.508, effective December 1, 1997.

See: 29 N.J.R. 3762(a), 29 N.J.R. 5062(a).

In (d)2i, added reference to CSA/NRTL standards; in (d)3i, added the exception for transition glues; and inserted (d)3vi.

Recodified from N.J.A.C. 5:23-3.8A by R.2003 d.384, effective October 6, 2003.

See: 35 N.J.R. 2422(a), 35 N.J.R. 4712(a).

Former N.J.A.C. 5:23-3.8, Department approval of nonconforming materials, repealed.

5:23-3.9 Interpretations and opinions

(a) Whenever the Commissioner shall, in accordance with applicable provisions of the Administrative Procedure Act, make any rule constituting an interpretation of any provision of the regulations, such shall be binding provided, however, that such interpretations shall be prospective in nature. Such interpretations shall not alter the ruling of a subcode official already rendered in a specific instance relating to a specific permit or structure. Requests for interpretations shall be in the form, and submitted in accordance with the procedure, set forth in N.J.A.C. 5:2-2.

(b) In response to a written inquiry or request setting forth a specific factual situation, or upon its own initiative, the Construction Code Element may issue a formal technical opinion to clarify provisions of the adopted subcodes. Such formal technical opinion shall be signed by the Assistant Director of the Element and shall be binding upon the Element and upon other code enforcement agencies and licensed officials. Formal technical opinions shall be prospective in nature, shall be based upon adopted subcodes or upon authoritative test results or standards incorporated by reference into an adopted subcode and shall not alter the ruling of a licensed official already rendered in a specific instance relating to a specific permit or structure, except that any such formal technical opinion may be considered in the context of an appeal from any such ruling.

(c) The Construction Code Element may issue bulletins to provide advice to code enforcing agencies, builders, and designers. Bulletins may be issued when the Element finds that an issue that is in need of clarification is adequately dealt with by existing rules and that rulemaking is therefore not appropriate or necessary. Consultation with the Code

Advisory Board shall be required prior to the issuance of any bulletin.

(d) In response to a written or oral inquiry or request setting forth a specific factual situation, a staff member of the Construction Code Element may issue an informal opinion as to the proper application of the regulations if the issue is one with which he has authority to deal. Such informal opinion shall only be in writing if it is issued in response to a written inquiry or request and shall not be binding upon the Element or any other party.

Amended by R.1981 d.454, effective December 7, 1981.

See: 13 N.J.R. 561(a), 13 N.J.R. 886(a).

Section substantially amended.

Administrative Correction: Name change.

See: 22 N.J.R. 2503(b).

Amended by R.1995 d.340, effective June 19, 1995.

See: 27 N.J.R. 1512(a), 27 N.J.R. 2388(a).

Redesignated (c) as (d) and added a new (c).

Administrative correction.

See: 31 N.J.R. 4259(a).

5:23-3.10 (Reserved)

Amended by R.1987 d.509, effective December 7, 1987.

See: 19 N.J.R. 1264(a), 19 N.J.R. 2270(a).

Substantially amended.

Amended by R.1990 d.507, effective October 15, 1990.

See: 22 N.J.R. 2208(a), 22 N.J.R. 3214(a).

Text conformed to BOCA National Code/1990.

Recodified to 5:23-4.3A by R.1992 d.272, effective July 6, 1992.

See: 24 N.J.R. 1446(a), 24 N.J.R. 2424(a).

Section was "Enforcing agency classification".

5:23-3.11 Enforcement activities reserved to the Department

(a) Except as otherwise provided in N.J.A.C. 5:23-3.11A(b), the Department of Community Affairs shall be the sole plan review agency for the following structures:

1. Electrical generating stations and substations, including nuclear;
2. Incineration plants;
3. Solid waste disposal plants;

4. Class I and Class II structures where required in accordance with N.J.A.C. 5:23-4.3A and N.J.A.C. 5:23-4.24(a)2ii;

5. Casino hotels;

6. Public mausoleums, vaults, crypts and other structures intended to hold or contain human remains;

7. All premanufactured systems for Class I and Class II structures, other than those authorized to be approved by an inplant inspection agency licensed to perform Class I and Class II plan review as provided in N.J.A.C. 5:23-4A.10, and all on-site installation of Class I and Class II premanufactured construction within the jurisdiction of a local enforcing agency that is not a Class I or Class II agency, as the case may be.

8. Health care facilities, as defined in N.J.A.C. 5:23-1.4; and

9. Public school facilities, as defined in N.J.A.C. 5:23-1.4.

(b) The Department of Community Affairs shall be the sole plan review agency for elevators, escalators, and moving walks in Use Groups other than R-3, R-4, or R-2 structures in which the elevator devices are wholly within dwelling units and not accessible to the general public, in all buildings and structures other than those that:

1. Are in a municipality that has an elevator subcode official; and
2. Are otherwise within the plan review jurisdiction of the local enforcing agency.

(c) A permit shall not be issued until the required plans for the building or structure have been released by the department. The department shall insure that the municipal enforcing agency receives a copy of the approved plans.

(d) The department may perform field inspections for any of the above projects when it deems such activity appropriate. However, such action shall not relieve the municipality of the obligation to perform field inspections for any project for which the municipality has granted a permit.

(d) Pursuant to Reorganization Plan No. 114-1996, the Department or the municipal code enforcing agency shall have authority to enforce and cite violations of N.J.A.C. 6A:26-6.2.

Amended by R.1986 d.142, effective May 5, 1986.

See: 17 N.J.R. 1169(a), 18 N.J.R. 945(a).

New (a)7; old (a)7 through 9 renumbered (a)8.-10.

Administrative Change: This section was originally part of N.J.A.C. 5:23-3.11.

See: 18 N.J.R. 1842(a).

Amended by R.1988 d.155, effective April 4, 1988.

See: 20 N.J.R. 824(d).

Added (d). This was amended by the rule adoption of the Department of Education published in the New Jersey Register at 20 N.J.R. 824(d).

Administrative Correction to (c).

See: 22 N.J.R. 2503(b).

Amended by R.1990 d.507, effective October 15, 1990.

See: 22 N.J.R. 2208(a), 22 N.J.R. 3214(a).

Text conformed to P.L. 1990, c.23, qualified agencies may perform plan review of public school structures.

Amended by R.1991 d.309, effective June 17, 1991.

See: 23 N.J.R. 1084(a), 23 N.J.R. 1922(a).

Rule conformed to P.L. 1990 c. 23; text at (c) revised to specify type of project covered; BOCA cites updated; reference to N.J.A.C. 6:22 added.

Amended by R.1993 d.662, effective December 20, 1993.

See: 25 N.J.R. 3891(a), 25 N.J.R. 5918(a).

Amended by R.1997 d.417, effective October 6, 1997.

See: 29 N.J.R. 3387(a), 29 N.J.R. 4285(a).

Deleted (a); recodified former (b) through (e) as (a) through (d); in (b), inserted "Prior to the release . . . of projects,"; in (b)1 and 2, inserted "public" preceding "school buildings"; in (c)7, deleted option of inspecting agency requiring subsequent correction of any errors in the plans, inserted second sentence, and in third sentence amended notice provisions.

Amended by R.1998 d.332, effective July 6, 1998.

See: 30 N.J.R. 1377(a), 30 N.J.R. 2421(b).

In (d), substituted "alarm" for "detection", changed BOCA reference and substituted a reference to (d)5ii for a reference to (e)5ii in 5, and changed BOCA in 6.

Amended by R.2000 d.166, effective April 17, 2000.

See: 31 N.J.R. 4151(a), 32 N.J.R. 1376(a).

Rewrote the section.

Amended by R.2001 d.127, effective April 16, 2001.

See: 33 N.J.R. 392(a), 33 N.J.R. 1195(a).

In (a)3, substituted "instructional spaces, the size of any such spaces" for "units" and substituted "such" for "instructional".

Administrative change.

See: 33 N.J.R. 4101(a).

5:23-3.11B Underground storage tank systems

(a) The installation, repair (other than "minor repair," as defined in N.J.A.C. 7:14B-10.5), and closure (or "demolition") of underground storage tank systems, as defined in N.J.A.C. 7:14B-10.1, shall be controlled by the State Uniform Construction Code and by N.J.A.C. 7:14B-1 through 15.

(b) A DEP permit for the installation, repair or closure of an underground storage tank system that requires a DEP approval, or any part thereof, or an emergency permit granted pursuant to N.J.A.C. 7:14B, shall be a prior approval for any permit application submitted pursuant to the State Uniform Construction Code Act and these rules. Applicants installing secondarily contained systems for which no prior DEP approval is necessary shall be required

to submit engineering drawings of the secondarily contained systems and to certify that the underground storage tank system meets all requirements of N.J.A.C. 7:14B.

(c) Construction code officials shall retain all penalty powers, as set forth in these rules, with respect to the installation, usage or closure (demolition) of underground storage tank systems and parts thereof in violation of the State Uniform Construction Code Act or these rules.

(d) The following types of underground storage tank systems requiring a construction permit are exempt from the requirements of N.J.A.C. 7:14B:

1. Farm or residential tanks of 1,100 gallons or less capacity used for storing motor fuel for noncommercial purposes;
2. Tanks with a capacity of 2,000 gallons or less used to store heating oil for onsite consumption in a nonresidential building;
3. Tanks used to store heating oil for onsite consumption in a residential building;
4. Septic tanks installed in compliance with rules adopted by DEP pursuant to P.L. 1954, c.199 (N.J.S.A. 58:11-23 et seq.);
5. Tanks situated in an underground area, including, but not limited to, basements, cellars, mines, drift shafts, or tunnels, if the storage tank is situated upon or above the surface of the floor;
6. Tanks situated in an underground area, including, but not limited to, basements, cellars, mines, drift shafts, or tunnels, if the storage tank is equipped with secondary containment and is uncovered so as to allow visual inspection of the exterior of the tank;
7. Wastewater treatment tanks;
8. Electrical equipment;
9. Hydraulic lift tanks; and
10. Any pipes, lines, fixtures, or other equipment connected to any tank exempted from the provisions of N.J.A.C. 7:14B as set forth in (b)1 to 9 above.

New Rule, R.1990 d.562, effective November 19, 1990.

See: 22 N.J.R. 2629(c), 22 N.J.R. 3482(d).

Amended by R.1997 d.409, effective October 6, 1997.

See: 29 N.J.R. 2736(a), 29 N.J.R. 4281(a).

In (d)3, deleted maximum capacity for tanks of 2000 gallons.

Amended by R.1998 d.332, effective July 6, 1998.

See: 30 N.J.R. 1377(a), 30 N.J.R. 2421(b).

In (d)3, deleted "with a capacity of 2000 gallons or less" following "Tanks".

5:23-3.12 Amended rules

Whenever the Commissioner shall make any modifications to the rules, notice of same shall be published in the New Jersey Register.

Amended by R.1995 d.544, effective October 16, 1995.
 See: 27 N.J.R. 2827(a), 27 N.J.R. 3933(a).
 Amended by R.2000 d.413, effective October 16, 2000.
 See: 32 N.J.R. 2278(a), 32 N.J.R. 3783(a).
 Rewrote the section.

5:23-3.13 State-sponsored code change proposals

(a) Any municipality, other political subdivision, or agency of the State seeking to submit a "State-sponsored code change proposal" shall do so not less than 90 days prior to the code change meeting of the model code adoption agency for which the amendment is proposed.

(b) Such proposal shall be on a form provided by the model code organization where one is available. If none is available, such proposal shall state the name and address of the official proposing the code change, the agency or political subdivision represented, the text of the amendment suggested and an explanation of the amendment together with any technical justification deemed necessary by the proponents.

(c) A hearing shall thereafter be held in accordance with N.J.S.A. 52:27D-124 of the Act.

(d) Copies of the submitted applications for code change proposals, transcripts of hearings on such applications and State-sponsored code change proposals as adopted, shall be available from the department at a fee of \$.50 per page.

(e) Whenever a model code change hearing is scheduled so as not to permit adequate time to meet the procedures set forth in this section and in N.J.S.A. 52:27D-124 of the Act, the Commissioner may hold a hearing and require the advice of the code advisory board within a lesser time period, as the situation dictates.

5:23-3.14 Building subcode

(a) Rules concerning the building subcode are as follows:

1. Pursuant to authority of P.L. 1975, c.217, as modified by P.L. 1996, c.53, the Commissioner hereby adopts the model code of the International Code Council, International Building Code, known as the "IBC/2000." This code is hereby adopted by reference as the building subcode for New Jersey subject to the modifications stated in (b) below.

i. Copies of this code may be obtained from the International Code Council at 4051 West Flossmoor Road, Country Club Hills, Illinois 60478-5795.

ii. The IBC/2000, as amended, may be known and cited as the "building subcode."

2. Any references to the mechanical code, plumbing code, International Residential Code, ICC A117.1 standard (including reference to Chapter 11) or the ICC Electrical Code listed in Chapter 35 shall be considered a reference to the appropriate adopted mechanical, plumbing, one-and two-family dwelling or electrical subcode referenced in N.J.A.C. 5:23-3 or to the barrier free subcode, N.J.A.C. 5:23-7, as appropriate.

(b) The following chapters of the building subcode are modified as follows:

1. Chapter 1, Administration, shall be deleted in its entirety. In addition, any referenced section of Chapter 1 shall be deleted throughout the code and "the administrative provisions of the Uniform Construction Code (N.J.A.C. 5:23)" shall be inserted.

2. Chapter 2, Definitions, shall be amended as follows:

i. The definition of "addition," shall be deleted.

ii. In the definition of agricultural buildings, "A structure qualifying under the Uniform Construction Code definition of a Commercial Farm Building may be built according to the regulations at N.J.A.C. 5:23-3.2(d)" shall be inserted after the last sentence.

iii. The definition of "alteration" shall be deleted.

iv. The definition of "building" shall be deleted and the following shall be inserted: "BUILDING. A structure enclosed with exterior walls or fire walls, built, erected and framed of component structural parts, designed for the housing shelter, enclosure and support of individuals, animals or property of any kind. When used herein, building and structure shall be interchangeable except where the context clearly indicates otherwise."

v. The definition of "building line" shall be deleted.

vi. The definition of "building official" shall be deleted and the following shall be inserted: "BUILDING SUBCODE OFFICIAL. A qualified person appointed by the municipal appointing authority or the commissioner pursuant to the act and the regulations to enforce the provisions of the building subcode within the jurisdiction of the enforcing agency."

vii. The definitions of "existing structure," "historic building," and "jurisdiction" shall be deleted.

viii. The definition of "owner" shall be deleted and the following shall be inserted: "OWNER. The owner or owners in fee of the property of a lesser estate therein, a mortgagee or vendee in possession, an assignee of rents, receiver, executor, trustee, lessee or any other person, firm or corporation, directly or indirectly in control of a building, structure or real property and shall include any subdivision thereof of the State."

ix. The definitions of "permit," "person," and "repair" shall be deleted.

x. The definition of "structure" shall be deleted and the following shall be inserted: "STRUCTURE. A combination of materials to form a construction for occupancy, use, or ornamentation, whether installed on, above, or below the surface of a parcel of land; provided the word "structure" shall be construed when used herein as though followed by the phrase "or part or parts thereof and all equipment therein" unless the context clearly requires a different meaning."

3. Chapter 3, Use and Occupancy Classification, shall be amended as follows:

i. In Section 302.3.3, Separated uses, the first sentence of Exception 2 shall be deleted and the following shall be inserted: "A private garage located beneath a room(s) shall have walls, partitions, floors, and ceilings separating the garage from the adjacent interior spaces constructed with not less than a one-hour fire resistance rating. Attached private garages shall be completely separated from the adjacent interior spaces and the attic area by a means of ½-inch gypsum board or equivalent applied to the garage side."

ii. In Table 302.3.3, Required Separation of Occupancies (Hours)^a, Use Group U shall be deleted.

iii. Section 308.2, Group I-1, shall be amended as follows: In the first sentence, "16" shall be deleted and "5" shall be inserted. In the second sentence, "responding to" shall be deleted and "slow evacuation as defined in Section 22-1.3 of NFPA 101-97, referenced in Chapter 35, in" shall be inserted. In the third sentence, "residential board and care facilities, assisted living facilities" shall be deleted and "boarding houses" shall be inserted. In the same sentence, "abuse" shall be inserted after "drug." Also, "A facility such as above, housing at least six and not more than 16 persons shall be classified as a Group R-4" shall be deleted and the following definition of "boarding house" shall be inserted:

"Boarding House: A building arranged or used for single occupancy where meals or personal or financial services are provided to the residents."

iv. In Section 308.3, Group I-2, "who are not capable of self-preservation" shall be deleted and "where evacuation is impractical as defined in Section 22-1.3 of NFPA 101-97, referenced in Chapter 35" shall be inserted. In the second sentence, a comma shall be inserted after "to" and "assisted living facilities" shall be inserted before "mental hospitals."

v. In Section 308.5, Group I-4, in the second sentence, "with" shall be deleted and "accessory to a dwelling unit and having" shall be inserted.

vi. In Section 308.5.1, Adult Care Facility, "accommodations for less than 24 hours for more than five unrelated adults and provides" shall be deleted, "services" shall be deleted after "care," and the following shall be inserted: "on less than a 24-hour basis where evacuation is slow or impractical as defined in Section 22-1.3 of NFPA 101-97, referenced in Chapter 35, shall be classified as Group I-4. Where evacuation is prompt, the facility shall be classified as Group A-3."

vii. Section 308.5.2, Child Care Facility, shall be deleted and the following shall be inserted: "A facility that provides supervision and personal care on less than a 24-hour basis for children 2½ years of age or less shall

be classified as Group I-4." In the same section, the exception shall be deleted.

viii. Section 310, Residential Group R, shall be deleted and the following definitions shall be inserted:

"(1) R-1 Residential occupancies where the occupants are primarily transient (less than 30 days) including:

Hotels (including motels) having transient occupancy

Rooming houses, with more than five residents, having transient occupancy

(2) R-2 Residential occupancies containing more than two dwelling units where the occupants are primarily permanent in nature, including:

Apartment houses

Convents

Dormitories

Fraternity and sorority houses

Monasteries

Rooming houses with more than five residents, not having transient occupancy

Therapeutic residences with more than 16 residents

(3) R-3 Detached one-and two-family dwellings greater than three stories in height, multiple single-family townhouses greater than three stories in height, and attached two-family dwellings separated from adjacent units by firewalls, including:

Single residential occupancies, accessory to a dwelling unit, having no more than five roomers or lodgers. (Single occupancies, accessory to a dwelling unit, having more than five roomers or lodgers shall be classified as Group R-2 or I-1, as appropriate.)

Adult and child day care facilities, accessory to a dwelling unit, serving five or fewer persons of any age for less than 24 hours.

Rooming houses with five or fewer residents.

Therapeutic residences with five or fewer residents.

(4) R-4 Therapeutic residences including more than five but not more than 16 occupants, excluding staff, capable of prompt evacuation as defined by Section 22-1.3 of NFPA 101-97, referenced in Chapter 35.

Group R-4 occupancies shall meet the requirements for construction as defined for Group R-3 except as otherwise provided in the code.

(5) R-5 Detached one-and two-family dwellings not more than three stories in height and multiple single-family townhouses not more than three stories in height designed and constructed in accordance with the International Residential Code."

4. Section 310.2, Definitions, shall be amended as follows:

i. The definition of "Boarding House" shall be deleted in its entirety.

ii. In the first sentence of the definition of "Dwelling Unit," "living as a single housekeeping unit" shall be inserted after "persons" and before "including."

iii. The definition of "Personal Care Service" shall be deleted in its entirety.

iv. The definition of "Residential Care/Assisted Living Facilities" shall be deleted in its entirety.

v. The definition of "Rooming House" shall be inserted as follows: "Rooming House: A building arranged or used for single occupancy where no meals or personal or financial services are provided to the residents."

vi. The definition of "Single Residential Occupancy" shall be inserted as follows: "Single Residential Occupancy: A building arranged or used for individual residency by persons living independently of one another, regardless of whether the residents share the use of common facilities, such as kitchen or bathing facilities."

vii. The definition of "Therapeutic Residence" shall be inserted as follows: "Therapeutic Residence: A residence for adults, each of whom is capable of prompt evacuation as defined by Section 22-1.3 of NFPA 101-97, referenced in Chapter 35, and who live within a single dwelling unit for therapeutic purposes, without a resident landlord or operator, but with some government or private social service provider oversight."

viii. The definition of "Transient Occupancy" shall be inserted as follows: "Transient Occupancy: A residential occupancy where no more than fifteen percent of the residents occupy the residency for more than 90 days."

5. Chapter 4, Special Detailed Requirements Based on Use and Occupancy, shall be amended as follows:

i. In Section 402.4.2, Number of Means of Egress, "used by persons other than employees" shall be deleted.

6. Chapter 5, General Building Heights and Areas, shall be amended as follows:

i. Table 503, Allowable Heights and Building Areas, shall be amended as follows:

(1) Under construction Type VA for Group A-1, "2" shall be deleted and "1" shall be inserted.

(2) Under construction Type IB for Group A-2, "11" shall be deleted and "3" shall be inserted. Under construction Types IIA and IIB for Group A-2, "3" and "2" shall be deleted and "2" and "1" shall be inserted, respectively. Under construction Types IIIA and IIIB for Group A-2, "3" and "2" shall be deleted and "2" and "1" shall be inserted, respectively. In addition, under construction Type IV for Group A-2, "3" shall be deleted and "2" shall be inserted. Finally, under construction Type VA for Group A-2, "2" shall be deleted and "1" shall be inserted.

(3) Under construction Type IB for Group A-3, "11" shall be deleted and "5" shall be inserted. In addition, under construction Type VA for Group A-3, "2" shall be deleted and "1" shall be inserted.

(4) Under construction Type IB for Group A-4, "11" shall be deleted and "5" shall be inserted. In addition, under construction Type VA for Group A-4, "2" shall be deleted and "1" shall be inserted.

(5) The maximum number of stories and maximum allowable area for Group A-5, construction Types IIIB, IV, VA and VB shall be deleted.

(6) Under construction Type IB for Group B, "11" shall be deleted and "7" shall be inserted. In addition, under construction Type IIB for Group B, "4" shall be deleted and "3" shall be inserted. Finally, under construction Type IIIA and IIIB for Group B, "5" and "4" shall be deleted and "4" and "3" shall be inserted, respectively.

(7) Under construction Type IB for Group F-1, "11" shall be deleted and "6" shall be inserted.

(8) Under construction Type IB for Group F-2, "11" shall be deleted and "7" shall be inserted.

(9) The maximum number of stories and maximum allowable area for Group H-2, construction Type VB shall be deleted and "NP" shall be inserted.

(10) Under construction Type IIIA for Group H-3, "4" shall be deleted and "3" shall be inserted.

(11) Under construction Type IIIA for Group H-4, "5" shall be deleted and "4" shall be inserted.

(12) The maximum number of stories and the maximum allowable area for Group I-3, construction Type VB shall be deleted and "NP" shall be inserted.

(13) Under construction Type IB for Group M, "11" shall be deleted and "6" shall be inserted. Under construction Type IIB for Group M, "4" shall be deleted and "2" shall be inserted. In addition, under construction Types IIIA and IIIB, "4" shall be deleted and "3" and "2" shall be inserted, respectively. Finally, under construction Type VA, "3" shall be deleted and "2" shall be inserted.

(14) Under construction Type IB for Group R-1, "11" shall be deleted and "9" shall be inserted. In addition, under construction Type IIB for Group R-1, "4" shall be deleted and "3" shall be inserted. Finally, under construction Type IIIB for Group R-1, "4" shall be deleted and "3" shall be inserted.

(15) Under construction Type IB for Group R-2, "11" shall be deleted and "9" shall be inserted. In addition, under construction Type IIB for R-2, "4" shall be deleted and "3" shall be inserted. Finally, under construction Type IIIB for Group R-2, "4" shall be deleted and "3" shall be inserted.

(16) Under construction Type IB for Group R-3, "11" shall be deleted and "4" shall be inserted. Under construction Type IIB for Group R-3, "4" shall be deleted and "3" shall be inserted. In addition, under construction Type IIIB for Group R-3, "4" shall be deleted and "3" shall be inserted. Finally, under construction Type VB for Group R-3, "3" shall be deleted and "2" shall be inserted.

(17) Under construction Type IB for Group R-4, "11" shall be deleted and "4" shall be inserted. Under construction Type IIB for Group R-4, "4" shall be deleted and "3" shall be inserted. In addition, under construction Type IIIB for Group R-4, "4" shall be deleted and "3" shall be inserted. Finally, under construction Type VB for Group R-4, "3" shall be deleted and "2" shall be inserted.

(18) Under construction Type IB for Group S-1, "11" shall be deleted and "5" shall be inserted. Under construction Type IIB for Group S-1, "3" shall be deleted and "2" shall be inserted. In addition, under construction Type IIIB for Group S-1, "3" shall be deleted and "2" shall be inserted. Finally, under construction Type VA for Group S-1, "3" shall be deleted and "2" shall be inserted.

(19) Under construction Type IB for Group S-2, "11" shall be deleted and "7" shall be inserted. Under construction Type IIB for Group S-2, "4" shall be deleted and "3" shall be inserted. In addition, under construction Type IIIB for Group S-2, "4" shall be deleted and "3" shall be inserted. Finally, under construction Type VA for Group S-2, "4" shall be deleted and "3" shall be inserted.

(20) Use Group U shall be deleted.

(21) At the end of the table, after "UL = Unlimited," "NP = Not permitted" shall be inserted.

ii. Section 507.1, Unsprinklered, one story, shall be deleted in its entirety.

iii. Section 507.3, Two-story, shall be amended as follows: In the first sentence, "building of Type I or Type II construction under " shall be inserted after "two-story."

7. Chapter 6, Types of Construction, shall be amended as follows:

i. In Table 602, Fire Resistance Rating Requirements for Exterior Walls Based on Fire Separation Distance^a, "U" shall be deleted from the heading of the fifth column. In addition, in the same table, at Note b, "and Group U when used as an accessory to Group R3" shall be deleted.

ii. In Section 602.3, Type III, the last sentence shall be deleted.

8. Chapter 7, Fire-Resistance-Rated Construction, shall be amended as follows:

i. In Table 705.4, Fire Wall Fire Resistance Ratings, under the heading "Group," "U" shall be deleted.

ii. Section 705.5, Horizontal continuity, shall be deleted in its entirety. Section 707.6 of the 1996 BOCA National Building Code shall be inserted as follows: "Horizontal Continuity. Firewalls shall be made smoke tight at the junction of exterior walls. In exterior wall construction employing studs, the wall shall extend through the stud space to the exterior sheathing."

iii. Section 707.14.1, Elevator lobby, shall be amended as follows: In the first sentence, "In buildings having occupied floors greater than 75 feet above the lowest level of fire department vehicle access" shall be inserted before "elevators." In the same section, Exception 4 shall be deleted in its entirety.

9. Chapter 9, Fire Protection Systems, shall be amended as follows:

i. In Section 903.2.5, Group I, the exception shall be deleted and the following shall be inserted: "Exceptions

1. For other than buildings of construction Types IIIB and VB, an automatic fire sprinkler system installed in accordance with Section 903.3.1.2. shall be allowed in Group I-1 facilities.

2. An automatic fire sprinkler system shall not be required for Group I-4 child care facilities that are located at the level of exit discharge and that accommodate 100 or fewer children and in which each child care room has an exit door directly to the exterior."

ii. Section 903.2.8, Group R-2, shall be deleted in its entirety. Section 904.9 of the 1996 BOCA National

Building Code shall be inserted as follows: "Group R-2: An automatic fire sprinkler system shall be provided throughout all buildings with an occupancy in Group R-2 in accordance with Section 903.3.1.1 or 903.3.1.2:

Exception: Buildings that do not exceed two stories including basements, which are not considered a story above grade, and with a maximum of 12 dwelling units per fire area. Each dwelling unit shall have at least one door opening to an exterior exit access that leads directly to the exits required to serve the dwelling unit."

iii. In Section 903.2.9, Group R-4, the reference to "Section 903.3.1.3" shall be deleted.

iv. Section 903.2.12.1, Stories and basements without openings, shall be deleted in its entirety and Section 904.10 of the 1996 BOCA National Building Code shall be inserted as follows: "Windowless story: An automatic fire sprinkler system shall be provided throughout every story or basement of all buildings where there is not provided at least one of the following types of openings:

1. An exterior stairway that conforms to the requirements of Section 1005.3.6, or an outside ramp that conforms to the requirements of Section 1003.3.4, leading directly to grade in each 50 linear feet (15240 mm) or fraction thereof of exterior wall in the story or basement, on at least one side of the building.

2. Openings entirely above the adjoining ground level totaling 20 square feet (1.9 m²) in each 50 linear feet (15240 mm) or fraction thereof of exterior wall in the story or basement, on at least one side of the building. Openings shall have a least dimension of not less than 22 inches (559 mm), and shall have a minimum net clear opening of 5 square feet (0.5 m²). Access to such openings from the exterior shall be provided to the fire department and such openings shall be unobstructed to allow fire fighting and rescue operations from the exterior.

Where openings in a story are provided on only one side and the opposite wall of such story is more than 75 feet (22860 mm) from such openings, the story shall be equipped throughout with an automatic fire sprinkler system or openings as specified herein shall be provided on at least two sides of the exterior walls of the story. If any portion of a basement is located more than 75 feet (22860 mm) from the openings required in this section, the basement shall be equipped throughout with an automatic sprinkler system.

Exception: Occupancies in Group R-3."

v. New Section 903.2.16, Automatic sprinkler system thresholds, shall be inserted as follows: "An automatic sprinkler system shall be required in accordance with Section 903.3.1.1 when the maximum area is exceeded for the following construction types of Groups B, F-2, and S-2 according to table 903.2.16, Automatic Sprinkler System Thresholds. All others not listed shall follow the applicable requirements as set forth in the IBC/2000."

"Automatic Sprinkler System Thresholds

Group B		IIB	IIB	VB
Story	Max. Area	Max. Area	Max. Area	Max. Area
1	36,000	*	*	*
2	72,000 (36,000 per floor)	*	*	*
3	99,360 (36,000 per floor)	99,360 (36,000 per floor)	*	*

Group F-2		IIB	IIB	VB
Story	Max. Area	Max. Area	Max. Area	Max. Area
1	36,000	*	*	18,000
2	72,000 (36,000 per floor)	*	*	36,000 (18,000 per floor)
3	99,360 (36,000 per floor)	99,360 (36,000 per floor)	*	*

Group S-2a		IIB	IIB	VB
Story	Max. Area	Max. Area	Max. Area	Max. Area
1	36,000	36,000	36,000	18,000
2	72,000 (36,000 per floor)	72,000 (36,000 per floor)	72,000 (36,000 per floor)	36,000 (18,000 per floor)
3	99,360 (36,000 per floor)	99,360 (36,000 per floor)	99,360 (36,000 per floor)	*

a. Exception—Open parking structures in accordance with Section 406.3
*Requirements as set forth in the IBC/2000"

vi. Section 903.3.2, Quick response and residential sprinklers, shall be deleted in its entirety.

vii. In Section 905.2, Installation standards, Sections 915.4, 915.5, and 915.6 of the 1996 BOCA National Building Code shall be inserted as follows: "905.2.1 Piping design. The riser piping, supply piping and the water service piping shall be sized to maintain a residual pressure of at least 65 psi (448 kPa) at the topmost outlet of each riser while flowing the minimum quantities of water specified in Sections 905.2.1.1 and 905.2.1.2. The pipe size shall be based on the capacity of the automatic water supply system or, where an automatic water supply is neither required nor provided to maintain the residual pressure of 65 psi (448 kPa), the pipe size shall be based on a pressure of 150 psi (1,034 kPa) available at the fire department connection.

Exception: The residual pressure of 65 psi (448 kPa) is not required in buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 and where the highest floor level is not more than 150 feet (45720 mm) above the lowest level of fire department vehicle access.

905.2.1.1 Riser sizing: The riser size shall be based on hydraulic calculations for a minimum flow of 500 gallons per minute (gpm) (1892 L/min.).

Exceptions:

1. Where only 1½-inch valves are provided, the riser(s) shall be sized to provide a minimum flow of 100 gpm (378 L/min.).

2. In buildings where limited area sprinkler systems are supplied with water from a common standpipe riser, the riser shall be sized to satisfy total demand.

3. For occupancies in Group B, I, R-1 or R-2 in buildings that are equipped throughout with an automatic sprinkler system in accordance with Section 906.2.1, each riser shall be sized for a minimum flow of 250 gpm (945 L/min.).

4. Risers that are sized in accordance with the pipe schedule requirements of NFPA 14 listed in Chapter 35 are not subject to this requirement.

905.2.1.2 System pipe sizing: The system piping, including the horizontal or common feeder lines shall be sized for a minimum flow of 500 gpm (1,892 L/min.). Where more than one standpipe riser is required or provided, all common system piping shall be sized for a minimum flow of 500 gpm (1892 L/min.) for the first riser plus 250 gpm (945 L/min.) for each additional riser, and the total shall not be required to exceed 1,250 gpm (4731 L/min.).

Exceptions

1. Where only 1½-inch valves are provided, the supply piping shall be sized for a minimum flow of 100 gpm (378 L/min.) for each riser, and the total shall not be required to exceed 500 gpm (1892 L/min.).

2. In buildings where limited area sprinkler systems are supplied with water from a common standpipe riser, the supply piping shall be sized for a minimum flow of 500 gpm (1892 L/min.) plus the sprinkler demand for the first riser, plus 250 gpm (945 L/min.) for each additional riser, and the total shall not be required to exceed 1,250 gpm (4731 L/min.).

3. For occupancies in Group B, I, R-1 or R-2 in buildings that are equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1, all common supply piping shall be sized for a minimum flow of 250 gpm (945 L/min.) for the first riser plus 250 gpm (945 L/min.) for each additional riser, and the total shall not be required to exceed 750 gpm (2838 L/min.).

905.2.2 Water supply: A water supply for fire department equipment shall be available to the building site. The water supply shall be capable of a minimum flow as required by Section 905.2.1.2 for a duration of 30 minutes.

905.2.2.1 Automatic water supply: An automatic water supply is required for all standpipe systems. The automatic water supply and supply piping shall be capable of delivering a flow of 500 gpm (1892 L/min.) at the residual pressure specified in Section 905.2.1 for a duration of 30 minutes.

Exceptions

1. In buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 where the highest floor is located not more than 150 feet (45720 mm) above the lowest level of fire department vehicle access, the automatic water supply is not required to exceed the requirements of NFPA 13 listed in Chapter 35.

2. Dry standpipe systems installed in open parking structures.

905.2.2.2 Interconnection: The required water supply shall be connected to the base of each standpipe riser. Where more than one standpipe riser is required, all risers shall be interconnected with a common supply line. An approved indicating valve shall be installed to permit individual risers to be taken out of service."

905.2.3 Control valves: Where a standpipe system riser also serves as the automatic sprinkler system riser in building required to have both systems or in buildings having both systems, sprinkler control valves shall be installed at each floor level at the connection to the riser.

viii. In Section 905.4, Location of class I standpipe hose connections, Items 1 and 2 shall be deleted in their entirety. Section 915.7 of the 1996 BOCA National Building Code shall be inserted as follows: "A standpipe hose connection shall be located at each floor level at every exit stairway, and on each side of the wall adjacent to the exit opening of a horizontal exit.

Exceptions

1. Where the floor area adjacent to a horizontal exit stairway outlets by a 30-foot (9,144 mm) hose stream from a nozzle attached to 100 feet (30,480 mm) of hose, a hose connection shall not be required at the horizontal exit.

2. Standpipe hose connections for systems required by Section 905.3.2. shall be permitted to be located only at exits such that all portions of the building floor area are not more than 200 feet (60,960 mm) from a hose connection or 200 feet (122 m) from the nearest point of fire department vehicle access."

ix. Section 905.4.2, Interconnection, shall be deleted in its entirety and Section 915.7.1 of the 1996 BOCA National Building Code shall be inserted as follows "905.4.2 Location: At each floor level and not more than 5 feet (1,524 mm) above the floor, there shall be connected to each standpipe a 2½ inch hose connection

with valves and threads compatible with the connections used by the local fire department.”

x. Section 906.0, Portable Fire Extinguishers, shall be deleted in its entirety and new Section 906.0, entitled “Fire Department Connections,” from Section 916.0 of the 1996 BOCA National Building Code shall be inserted as follows: “906.1 Required: All required water fire-extinguishing and standpipe systems shall be provided with a fire department connection in accordance with the applicable standards. Standpipes in buildings under construction or demolition shall conform to Section 3311.

Exceptions

1. Limited area sprinkler systems supplied from the domestic water system.
2. Where the local fire department approves a single connection for a large diameter hose of at least four inches (102 mm).
3. An automatic sprinkler system with less than 20 sprinklers.

906.2 Connections: Fire department connections shall be arranged in such a manner that the attachment to any one sprinkler connection will serve all sprinklers, and the attachment to any one standpipe connection will serve all standpipes within the building.

Exception: Fire protection systems in high rise buildings designed with a low zone and a high zone may be provided with a connection for each zone.

906.3 Location: Fire department connections shall be located and shall be visible on a street front or on a location approved by the fire department. Such connections shall be located so that immediate access is provided to the fire department. Fire department connections shall not be obstructed by fences, bushes, trees, walls, or any other similar object.

906.4 Height: Fire department connections shall not be less than 18 inches (457 mm) and more than 42 inches (1,067 mm) in elevation, measured from the ground level to the centerline of the inlets.

906.5 Projection: Where the fire department connection will otherwise project beyond the property line or into the public way, a flush-type fire department connection shall be provided.

906.6 Hose thread: Hose thread in the fire department connection shall be uniform with that used by the local fire department.

906.7 Fittings: Fire department inlet connection shall be fitted with check valves, ball drip valves and plugs with chains or frangible clips.

906.8 Signs: A metal sign with raised letters at least one inch (25 mm) in height shall be mounted on all fire department connections serving sprinklers or standpipes. Such signs shall read “Automatic Sprinklers” or “Standpipes,” or both, as applicable.”

xi. Sections 907.2.6 and 907.2.8 are amended as indicated at N.J.A.C. 5:23-3.17(a)1i(5).

xii. Section 907.2.10.1.4, Additions, alterations, or repairs to Group R, shall be deleted in its entirety.

xiii. In Section 907.2.10.3, Interconnection, Exception 2 shall be deleted in its entirety.

xiv. In Section 909.18.8.3, Reports, “The report shall be reviewed by the registered design professional and, when satisfied that the design intent has been achieved, the responsible registered design professional shall seal, sign, and date the report” shall be deleted.

10. Chapter 10, Means of Egress, shall be amended as follows:

i. In Section 1003.3.1.3.5, Security grilles, “In Groups B, F, M, and S” shall be deleted and “horizontal” shall be capitalized.

ii. Section 1003.3.1.8, Locks and latches, shall be amended as follows: In Exception 2, “Group A having an occupant load of 300 or less” shall be deleted. In the same section, Exception 5 shall be inserted as follows: “5. Key operation shall be permitted from a dwelling unit provided that the key cannot be removed from the lock when the door is locked from the side from which egress is made.”

iii. In Section 1003.3.1.8.2, Delayed egress locks, “E” shall be deleted.

iv. In Section 1004.2.2.1, Two exit or exit access doorways, the last sentence of Exception 1 shall be deleted.

v. Section 1004.2.3, Egress through intervening spaces, shall be deleted in its entirety. Section 1006.2.1 of the 1996 BOCA National Building Code shall be inserted as follows: “Egress through adjoining spaces: Egress from a room or a space shall not pass through adjoining or intervening rooms or areas, except where such adjoining rooms or areas are accessory to the area served; are not a high-hazard occupancy; and provide a discernable path of travel to an exit. A maximum of one exit access shall be permitted to pass through a kitchen, storeroom, restroom, closet or similar space provided that a passage through such space is not the only means of access to an exit. An exit access shall not pass through a room subject to locking. Means of egress from dwelling units or sleeping areas shall not lead through other dwelling units or sleeping areas and shall not lead through toilet rooms or bathrooms.”

vi. In Section 1004.3.2, Corridors, "and passageways" shall be inserted after "corridors."

vii. In Table 1004.3.2.1, Corridor Fire Resistance Rating, under the heading "Occupancy," "U" shall be deleted from the third row.

viii. In the title of Section 1004.3.2.2, "and passageway" shall be inserted after "Corridor." In addition, in the first sentence, "or passageway" shall be inserted after "corridor."

ix. Section 1004.3.2.3, Dead ends, shall be amended as follows: In the first sentence "and passageways" shall be inserted after "corridors." In Exception 1, "or passageway" shall be inserted after "corridor." In Exception 2, "and passageways" shall be inserted after "corridors." In Exception 3, "or passageway" shall be inserted after each "corridor."

x. In Table 1005.2.2, Buildings with One Exit, under the heading "Occupancy," "U" shall be deleted from the first row.

xi. In Section 1005.3.2, Vertical exit enclosures, Exception 1 shall be deleted and the following shall be inserted: "1. In other than Group H and I occupancies, a stairway connecting not more than two floor levels, one of which is the level of exit discharge, which serves an occupant load of not more than 10 or serves four or fewer dwelling units is not required to be enclosed." In the same section, Exception 8 shall be deleted.

xii. Section 1005.3.5, Horizontal exits, shall be deleted in its entirety. Section 1019.0 of the 1996 BOCA National Building Code shall be inserted as follows: "Horizontal Exits

1005.3.5 General: Horizontal exits shall be accepted as an approved exit element of a required means of egress. The connection between an area of a building that the horizontal exit serves and the area of refuge as herein required shall be accomplished by protected openings in a fire-resistance rated wall, or by an open-air balcony or bridge.

1005.3.5.1 Separation: The separation between buildings or areas of refuge connected by a horizontal exit shall be provided by at least a two-hour fire-resistance rated firewall or fire separation assembly with approved opening protectives complying with Chapter 7 and Table 602.

1005.3.5.2 Doors: All doors shall swing in the direction of egress travel. Where the horizontal exit serves as an exit from both sides of the wall, there shall be adjacent openings with swinging fire doors opening in opposite directions.

Exception: Horizontal sliding doors complying with Section 1003.3.1.3.3.

1005.3.5.3 Area of refuge: The discharge area of a horizontal exit shall be either public areas or spaces occupied by the same tenant, and each such area of refuge shall be adequate to hold the total occupant load of both connected areas. The capacity of areas of refuge shall be computed on a minimum net floor area allowance for each occupant to be accommodated therein, not including areas of stairways, elevators and other shafts or courts, as follows:

1. 30 square feet (3 m²) per patient for hospitals and nursing homes.

2. Six square feet (0.56 m²) per occupant on stories not housing patients confined to a bed or litter in an occupancy in Group I-2.

3. Six square feet (0.56 m²) per occupant in an occupancy in Group I-3.

4. Three square feet (0.28 m²) in all other cases.

1005.3.5.4 Egress from area of refuge: The path of egress travel from the horizontal exit through the area of refuge to another exit shall be continuously available. In other than occupancies in Group I-3, there shall be at least one exit on each side of the horizontal exit, which is not a horizontal exit. Any area of refuge not having access to an exit, other than a horizontal exit, shall be considered as part of an adjoining area of refuge with such exit. In the area(s) served by the horizontal exit, the length of exit access travel distance to the horizontal exit or another exit shall not exceed the requirements of Section 1004.2.4."

xiii. Section 1009.1, General, shall be amended as follows: In the second sentence, "Basements and" shall be deleted and "sleeping" shall be capitalized.

11. Chapter 11, Accessibility, shall be deleted in its entirety.

12. Chapter 13, Energy Efficiency, shall be deleted in its entirety.

13. Chapter 15, Roof Assemblies and Rooftop Structures, shall be amended as follows:

i. In Table 1505.1, Minimum Roof Covering Classification for Types of Construction, Note a shall be deleted in its entirety. In addition, at Note b, "and U occupancies" shall be deleted from the first sentence.

14. Chapter 16, Structural Design, shall be amended as follows:

i. Section 1603.3, Live loads posted, shall be deleted in its entirety.

ii. Section 1603.4, Occupancy permits for changed loads, shall be deleted in its entirety.

iii. New Section 1604.9, General structural integrity, from Section 1604.2 of the 1996 BOCA National Building Code, shall be inserted as follows: "The require-

ments for general structural integrity shall be in accordance with Section 1.4 of ASCE 7 listed in Chapter 35."

iv. In Table 1607.1, Minimum Uniformly Distributed Live Loads and Minimum Concentrated Live Loads, at Note g, "building official" shall be deleted and "design professional" shall be inserted.

v. Section 1607.9, Reduction in live loads, shall be amended as follows: In the first sentence, "and applied" shall be inserted after "reduced." After the first sentence, "The method chosen shall be applied throughout the building." shall be inserted.

vi. In Section 1607.9.1.3, Special occupancies, "or educational occupancies" shall be inserted after "public assembly occupancies."

vii. In Section 1607.9.2, Alternate floor live load reduction, Item 1, "or Group E" shall be inserted after "Group A."

viii. Section 1614.1.1, Addition to existing building, shall be deleted in its entirety.

ix. Section 1614.2, Change of Occupancy, shall be deleted in its entirety.

x. Section 1614.3, Alterations, shall be deleted in its entirety.

xi. In Section 1621.1.7, Component anchorage #1, Item 1 shall be deleted in its entirety.

xii. In Section 1621.3.14, Elevator design requirements, at the end of the section, the following shall be inserted: "The scope of Part XXIV of ASME A17.1, entitled "Elevator Safety Requirements for Seismic Risk Zone 2 or Greater," is deleted."

xiii. In Table 1622.2.5(2), Importance Factor (*I*) and Seismic Use Group Classification for Nonbuilding Structures, at Notes H-II and H-III, "authority having jurisdiction" shall be deleted and "construction official" shall be inserted.

15. Chapter 17, Structural Tests and Special Inspections, shall be amended as follows:

i. In Section 1701.1, Scope, "shall apply to Class I buildings and" shall be inserted after "chapter."

ii. Section 1702.1, General, shall be amended as follows: In the title, "/Special Inspector" shall be inserted after "Agency." In the first sentence, "or design professional acting as the approved agency" shall be inserted after "agency."

iii. Section 1703.1, Approved agency, shall be amended as follows: In the first sentence, "Upon the request of the construction official" shall be inserted before "An." In the same sentence, "building official" shall be deleted and "construction official" shall be inserted and "applicable" shall be deleted and "following" shall be inserted.

iv. In Section 1703.7, Evaluation and follow-up inspection, "in accordance with N.J.A.C. 5:23-4.26" shall be inserted after the second "assembly."

v. Section 1704.1, General, shall be amended as follows: In the first sentence, "of Class 1 buildings only" shall be inserted after "construction." In the second sentence, "the registered design professional" shall be deleted and "person" shall be inserted.

vi. Section 1704.1.2, Report requirement, shall be amended as follows: In the second sentence, "building official" shall be deleted and "construction official" shall be inserted and "registered design professional" shall be deleted and "person" shall be inserted. In the same sentence, "in accordance with N.J.A.C. 5:23-2.21(c)" shall be inserted after "charge."

vii. In Section 1704.3, Steel construction, "the on-site erection of" shall be inserted after "for."

viii. In Table 1704.3, Required Verification and Inspection of Steel Construction, Items 1, 3, and 4 shall be deleted.

ix. In Section 1704.5, Masonry construction, "in Seismic Design Category D" shall be inserted after the second "construction." In the same section, in Exception 2, the reference to "Table 1805.5(1)" shall be deleted.

x. Section 1704.6, Wood construction, shall be deleted in its entirety.

xi. Section 1704.9, Pier foundations, shall be deleted in its entirety.

xii. In Section 1705.1, Scope, "for Seismic Design Category D buildings" shall be inserted after "provided."

xiii. Section 1706, Quality Assurance for Wind Regulations, shall be deleted in its entirety.

xiv. Sections 1708.1, Masonry, 1708.1.1, Empirically designed masonry and glass unit masonry in nonessential facilities, 1708.1.2, Empirically designed masonry and glass unit masonry in essential facilities, 1708.1.3, Engineered masonry in nonessential facilities, 1708.1.4, Engineered masonry in essential facilities, 1708.3, Reinforcing and pre-stressing steel, 1708.4, Structural tests, and 1708.5, Mechanical and electrical equipment, shall be deleted in their entirety.

xv. Section 1709, Structural Observations, shall be deleted in its entirety.

16. Chapter 18, Soils and Foundations, shall be amended as follows:

i. In the title of Section 1802.2.6, "Seismic Design Category C" shall be deleted and "Seismic Design Category D" shall be inserted. In the first sentence, the reference to "Seismic Design Category C" shall be deleted and "Seismic Design Category D" shall be inserted.

ii. New Section 1802.2.8 from Section 1802.1 of the 1996 BOCA National Building Code shall be inserted as follows: "Building Height: For all buildings that are more than three stories or 40 feet (12,192 mm) in height, the building official shall request soil tests."

iii. Section 1802.4.1, Exploratory boring, shall be amended as follows: After the first sentence, the following sentence from Section 1802.1 of the 1996 BOCA National Building Code shall be inserted: "There shall be at least one exploratory boring to rock or to an adequate depth below the load-bearing strata for every 2,500 square feet (232.5 mm) of built-over area, and such additional tests as the code official requires."

iv. In Section 1802.6, Reports, "soil borings are required" shall be inserted after "Where."

v. In Section 1805.2.1, Frost protection, "400 square feet (37 m²)" shall be deleted and "100 square feet (9.25 m²)" shall be inserted.

vi. In Section 1806.3.1, Floors, "60" shall be deleted and "6" shall be inserted.

vii. New Section 1806.5 from Section 1813.8 of the 1996 BOCA National Building Code shall be inserted as follows: "1806.5 Erosion protection: Where water impacts the ground from the edge of the roof, downspout, scupper or other rain water collection or diversion device, provisions shall be made to prevent soil erosion and direct the water away from the foundation."

viii. Section 1807.2.6, Spacing, shall be deleted in its entirety and Section 1816.9 of the 1996 BOCA National Building Code shall be inserted as follows: "Spacing: The minimum center-to-center spacing of piles shall not be less than twice the average diameter of a round pile, nor less than 1 $\frac{3}{4}$ times the diagonal dimension of a rectangular pile. Where driven to or penetrating into rock, the spacing shall not be less than 24 inches (610 mm). Where receiving principal support at the end from materials other than rock, or through friction resistance, the spacing shall not be less than 30 inches (762 mm) except that for piles having enlarged bases formed either by compacting concrete or driving a pre-cast base, the minimum center-to-center spacing shall be 4 $\frac{1}{2}$ feet (1,372 mm). The spacing of piles shall be such that the average load on the supporting strata will not exceed the safe load-bearing value of those strata as determined by test borings or other approved methods."

ix. In Section 1807.2.23.2, Seismic Design Category D, E, or F, the references to "Seismic Design Categories E and F" shall be deleted.

x. Section 1808.2.2.1, Materials, shall be deleted in its entirety and Section 1821.2.2 of the 1996 BOCA National Building Code shall be inserted as follows: "All concrete shall have a 28-day specified compressive strength (f'_c) of not less than 4,000 psi (27579 kPa)."

17. Chapter 21, Masonry, shall be amended as follows:

i. In Figure 2111.1, Fireplace and Chimney Details, in the plan view illustration, Letter B is improperly dimensioned. The text of Section 2111.10 shall prevail.

18. Chapters 27, Electrical; 28, Mechanical Systems; and 29, Plumbing, shall be deleted in their entirety.

19. Chapter 30, Elevators and Conveying Systems, shall be amended as follows:

i. In Section 3001.1, Scope, "and where applicable N.J.A.C. 5:23-12" shall be inserted after "chapter."

ii. In Section 3001.2, Referenced standards, "this code" shall be deleted and "these rules" shall be inserted. In the same section, "with the exception of Rule 1206.1h, Part XX and Part XXI" shall be inserted after "ASME A17.1" and "ASME A18.1" shall be inserted after "ASME A90.1." In addition, at the end of the section, the following shall be inserted: "The scope of Part XXIV of ASME A17.1, entitled "Elevator Safety Requirements for Seismic Risk Zone 2 or Greater," is deleted."

iii. New Section 3002.4.1, Elevators in newly constructed multiple dwellings, shall be inserted as follows: "When an elevator is installed in a newly-constructed multiple dwelling, the elevator shall meet the dimensional requirements above."

iv. In Section 3004.4, Closed vents, "annealed glass" shall be deleted and "plain glass" shall be inserted.

v. In Section 3004.5, Plumbing and mechanical systems, the exception shall be deleted.

20. Chapter 31, Special Construction, shall be amended as follows:

i. New Section 3102.3.2, which shall be the text of Section 3104.6 of the 1996 BOCA National Building Code, shall be inserted as follows: "Certification: An affidavit or affirmation shall be submitted to the code official and a copy retained on the premises on which the tent or air-supported structure is located. The affidavit or affirmation shall attest to the following information relative to the flame-resistance of the fabric:

1. Names and addresses of the owners of the tent or air-supported structure.

2. Date the fabric was last treated with flame-resistant solution.

3. Trade name or kind of chemical used in treatment

4. Name of person or firm treating the material.

5. Name of testing agency and test standard by which the fabric was tested.”

ii. Section 3103.1.1 shall be deleted in its entirety and the following shall be inserted:

“(1) Temporary structures: A construction permit is required for the erection, operation or maintenance of all temporary structures (excluding tents and tensioned membrane structures) covering an area in excess of 120 square feet, including all connecting areas or spaces with a common means of egress or entrance, or which are used or intended to be used for gatherings of 10 or more persons;

(2) Tents with appurtenances: A construction permit is required for the erection, operation or maintenance of all tents or tensioned membrane structures of any size if they contain appurtenances such as platforms or electrical equipment;

(3) Tents without appurtenances: No permit is required for the erection, operation or maintenance of any tent or tensioned membrane structure without appurtenances if the tent or structure is no more than 900 square feet in area and no more than 30 feet in any dimension (excluding canopies), whether it is one unit or composed of multiple units. Tents used exclusively for recreational camping purposes shall be exempt from the above requirements.

(4) A temporary greenhouse, also called a “hoop-house” or “polyhouse,” used exclusively for the production or storage of live plants, shall be exempt from the permit requirements of the Uniform Construction Code if it meets the following criteria:

(A) There is no permanent anchoring system or foundation;

(B) There is no storage, temporary or otherwise, of solvents, fertilizers, gases, or other chemical or flammable materials;

(C) The structure is no wider than 31 feet and there is an unobstructed path of no greater length than 150 feet from any point to a door or fully accessible wall area; and

(D) The covering of the structure is of a material no greater than six nails (152.4 micrometers) in thickness, conforming to NFPA 701 standard, that yields approximately four pounds of maximum impact resistance to provide egress through the wall.

(5) The provisions of the Uniform Construction Code at N.J.A.C. 5:23-3.14(b)20ii(4) notwithstanding, if a temporary greenhouse contains any device subject to the electrical subcode or any mechanical equipment subject to the mechanical subcode, a permit shall be required for the device, system or fixture only. If the temporary greenhouse is connected to a potable water system, a permit shall be required for the backflow prevention devices only.

iii. Section 3109, Swimming Pool Enclosures, shall be deleted in its entirety and the following shall be inserted:

“3109

SWIMMING POOLS, SPAS AND HOT TUBS

3109.1 General. The provisions of this section shall control the design and construction of swimming pools, spas and hot tubs .

3109.2 Definitions. For the purposes of these requirements, the terms used shall be defined as follows and as set forth in Chapter 2.

BARRIER.

A fence, wall, building wall or combination thereof which completely surrounds the swimming pool and obstructs access to the swimming pool.

HOT TUB.

See “Swimming pool.”

IN-GROUND POOL.

See “Swimming pool.”

RESIDENTIAL.

That which is situated on the premises of a detached one- or two-family dwelling or a one-family townhouse not more than three stories in height.

SPA, NONPORTABLE.

See “Swimming pool.”

SWIMMING POOL.

Any structure intended for swimming or recreational bathing that contains water, provided that these regulations shall not be applicable to any such pool less than 24 inches (610 mm) deep or having a surface area less than 250 square feet (23.25 m²). This includes in-ground, aboveground and on-ground swimming pools, hot tubs and spas.

SWIMMING POOL, INDOOR.

A swimming pool that is totally contained within a structure and surrounded on all four sides by walls of said structure.

SWIMMING POOL, OUTDOOR.

Any swimming pool, which is not an indoor pool.

3109.3 In-ground public pools. In-ground pools shall be designed and constructed in conformance with ANSI/NSPI-1 as listed in Chapter 35.

3109.4 In-ground Residential pools. In-ground residential pools shall be designed and constructed in conformance with ANSI/NSPI-5 as listed in Chapter 35.

3109.5 Permanently installed public spas and hot tubs. Permanently installed public spas and hot tubs shall be designed and constructed in conformance with ANSI/NSPI-2 as listed in Chapter 35.

3109.6 Portable residential spas and hot tubs. Portable residential spas and hot tubs shall be designed and constructed in conformance with ANSI/NSPI-3 as listed in Chapter 35.

3109.7 Enclosures for private swimming pools, spas and hot tubs. The provisions of this section shall control the design of barriers for residential swimming pools, spas and hot tubs.

3109.7.1 Outdoor swimming pool. An outdoor swimming pool, including an in-ground, aboveground or on-ground pool, hot tub or spa shall be provided with a barrier which shall comply with the following:

1. The top of the barrier shall be at least 48 inches (1,219 mm) above grade measured on the side of the barrier, which faces away from the swimming pool. The maximum vertical clearance between grade and the bottom of the barrier shall be two inches (51 mm) measured on the side of the barrier, which faces away from the swimming pool. Where the top of the pool structure is above grade, such as an aboveground pool, the barrier may be at ground level, such as the pool structure, or mounted on top of the pool structure. Where the barrier is mounted on top of the pool structure, the maximum vertical clearance between the top of the pool structure and the bottom of the barrier shall be four inches (102 mm).

2. Openings in the barrier shall not allow passage of a four-inch-diameter (102 mm) sphere.

3. Solid barriers, which do not have openings, such as a masonry or stone wall, shall not contain indentations or protrusions except for normal construction tolerances and tooled masonry joints.

4. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the

horizontal members is less than 45 inches (1,143 mm), the horizontal members shall be located on the swimming pool side of the fence. Spacing between vertical members shall not exceed 1.75 inches (44 mm) in width. Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed 1.75 inches (44 mm) in width.

5. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is 45 inches (1,143 mm) or more, spacing between vertical members shall not exceed four inches (102 mm). Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed 1.75 inches (44 mm) in width.

6. Maximum mesh size for chain link fences shall be a 1.25-inch (32 mm) square unless the fence is provided with slats fastened at the top or the bottom that reduce the openings to not more than 1.75 inches (44 mm).

7. Where the barrier is composed of diagonal members, such as a lattice fence, the maximum opening formed by the diagonal members shall not be more than 1.75 inches (44 mm).

8. Access gates shall comply with the requirements of Section AG105.2, Items 1 through 7, and shall be equipped to accommodate a locking device. Pedestrian access gates shall open outward away from the pool and shall be self-closing and have a self-latching device. Gates other than pedestrian access gates shall have a self-latching device. Where the release mechanism of the self-latching device is located less than 54 inches (1,372 mm) from the bottom of the gate, the release mechanism and openings shall comply with the following:

- 8.1. The release mechanism shall be located on the pool side of the gate at least three inches (76 mm) below the top of the gate, and

- 8.2. The gate and barrier shall have no opening greater than 0.5 inch (12.7 mm) within 18 inches (457 mm) of the release mechanism.

9. Where an aboveground pool structure is used as a barrier or where the barrier is mounted on top of the pool structure, and the means of access is a ladder or steps, then:

- 9.1. The ladder or steps shall be surrounded by a barrier that meets the requirements of Section AG105.2, Items 1 through 9. When the ladder or steps are secured, locked or removed, any opening created shall not allow the passage of a four-inch-diameter (102 mm) sphere.

3109.8 Barrier exceptions. Spas or hot tubs with a safety cover that complies with ASTM F 1346, as listed in Chapter 35, shall be exempt from the provisions of this section.

3109.9 Enclosures for public swimming pools, spas and hot tubs. Public swimming pools shall be completely en-

closed by a fence at least four feet (1,290 mm) in height or a screen enclosure. Openings in the fence shall not permit the passage of a four-inch (102 mm) diameter sphere. The fence or screen enclosure shall be equipped with self-closing and self-latching gates."

21. Chapter 32, Encroachments into the Public Rights of Way, shall be amended as follows:

i. In Section 3202.1.2, Vaults and other enclosed spaces, "authority or legislative body having jurisdiction" shall be deleted and "Uniform Construction Code (N.J.A.C. 5:23)" shall be inserted.

ii. In Section 3202.3.4, Pedestrian walkways, "authority having jurisdiction" shall be deleted and "the construction official" shall be inserted.

iii. In Section 3202.4, Temporary encroachments, "local authority having jurisdiction" shall be deleted and "municipality" shall be inserted.

22. Chapter 33, Safeguards During Construction, shall be amended as follows:

i. Sections 3303.1, Construction documents; 3303.2, Pedestrian protection; 3303.4, Vacant lot; 3303.5, Water accumulation; and 3303.6, Utility connections, shall be deleted in their entirety.

ii. In the last sentence of Section 3309.1, Where required, "On construction sites," shall be inserted before "All." In addition, in the last sentence, "Section 906" shall be deleted and "the International Fire Code" shall be inserted.

23. Chapter 34, Existing Structures, shall be deleted in its entirety.

24. Chapter 35, Referenced Standards, shall be amended as follows:

i. Under the subheading "ASME," the following reference shall be inserted: "ASME A18.1-1999, Safety Standard for Platform Lifts and Stairway Chairlifts, with A18.1a-2001 addenda."

ii. Under the subheading "NFPA," "NFPA 13-96, Installation of Sprinkler Systems; NFPA 13D-96, Installation of Sprinkler Systems in One-and Two-family Dwellings and Manufactured Homes; and NFPA 13R-96, Installation of Sprinkler Systems in Residential Occupancies Up to and Including Four Stories in Height" shall be deleted and "NFPA 13-99 Installation of Sprinkler Systems; NFPA 13D-99, Installation of Sprinkler Systems in One-and Two-family Dwellings and Manufactured Homes; and NFPA 13R-99, Installation of Sprinkler Systems in Residential Occupancies Up to and Including Four Stories in Height" shall be inserted. In addition, "NFPA 20-99, Installation of Centrifugal Fire Pumps" shall be inserted after "NFPA 17A-98, Wet Chemical Extinguishing Systems."

iii. Under the subheading "NSPI" the following NSPI Standards shall be inserted: "ANSI/NSPI-1, Permanently Installed Public In-ground Public Pools, ANSI/NSPI-2, Permanently Installed Public Spas, ANSI/NSPI-3, Standard for Permanently Installed Residential Spas, ANSI/NSPI-4, Standard for Residential Above-Ground/One-Ground Swimming Pools, and ANSI/NSPI-5, Standard for Residential In-ground Swimming Pools."

25. The Appendices shall be amended as follows:

i. Appendix A, Employee Qualifications; Appendix B, Board of Appeals; Appendix C, Group U-Agricultural Buildings; Appendix D, Fire Districts; Appendix E, Supplementary Accessibility Requirements; Appendix F, Rodent Proofing; and Appendix G, Flood Resistant Construction, shall be deleted in their entirety.

ii. In Appendix H, at the beginning of the Appendix, the sentence, "The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance," shall be deleted in its entirety.

(1) In Appendix H, Section H101.2, Signs exempt from permits, shall be deleted in its entirety.

(2) In Appendix H, Section H105.2, Permits, drawings and specifications, "as provided in Chapter 1" shall be deleted and "as provided in N.J.A.C. 5:23-2.14" shall be inserted.

(3) In Appendix H, Section H106.1, Illumination, "ICC Electrical Code" shall be deleted and "electrical subcode" shall be inserted.

(4) In Appendix H, Section H106.2, Electrical service, "ICC Electrical Code" shall be deleted and "electrical subcode" shall be inserted.

iii. Appendix I, Patio Covers, and Appendix J, Supplementary Accessibility Requirements for Qualified Historic Buildings and Facilities, shall be deleted in their entirety.

Amended by R.1981 d.132, effective May 7, 1981.

See: 13 N.J.R. 121(a), 13 N.J.R. 258(d).

Amended by R.1983 d.12, eff. February 7, 1983, operative February 22, 1983.

See: 14 N.J.R. 132(a), 15 N.J.R. 141(c).

Added (a)2 and (c).

Amended by R.1984 d.314, eff. August 6, 1984.

See: 16 N.J.R. 1139(a), 16 N.J.R. 2084(b).

This section was substantially amended.

Amended by R.1985 d.154, effective April 1, 1985 (operative July 1, 1985.)

See: 17 N.J.R. 239(a), 17 N.J.R. 810(a).

(a)2 added; subsection (c) added.

Correction: N.J.A.C. 5:23-3.14(c)5 was incorrect in adoption.

See: 17 N.J.R. 1409(a).

Amended by R.1985 d.324, effective July 1, 1985.

See: 17 N.J.R. 861(c), 17 N.J.R. 1646(a).

(b)3i: amended text.

Amended by R.1986 d.380, effective September 22, 1986.

See: 18 N.J.R. 1235(a), 18 N.J.R. 1931(a).

Substantially amended.

Amended by R.1987 d.374, effective September 21, 1987.

See: 19 N.J.R. 1024(a), 19 N.J.R. 1720(b).

Model subcode revisions.

Amended by R.1988 d.270, effective June 20, 1988.

See: 20 N.J.R. 575(a), 20 N.J.R. 1344(a).

Added (a)3 and (c).

Amended by R.1990 d.253, effective May 21, 1990.

See: 22 N.J.R. 909(b), 22 N.J.R. 1554(a).

Text added at (c)2ii, 4, 5 and 7.

Amended by R.1990 d.325, effective July 2, 1990.

See: 21 N.J.R. 1654(a), 22 N.J.R. 2001(a).

Text added at (b)5xii(1) to conform to Fire Code.

Amended by R.1990 d.507, effective October 15, 1990.

See: 22 N.J.R. 2208(a), 22 N.J.R. 3214(a).

Text conformed to BOCA National Code/1990.

Amended by R.1990 d.558, effective November 19, 1990.

See: 22 N.J.R. 1969(b), 22 N.J.R. 3483(a).

Conditional exemption for hoopouses or polyhouses added.

Amended by R.1991 d.325, effective July 1, 1991.

See: 23 N.J.R. 805(a), 23 N.J.R. 2046(a).

Article 26 amended at (b)14.

Amended by R.1991 d.429, effective August 19, 1991.

See: 23 N.J.R. 1487(a), 23 N.J.R. 2501(a).

In (a), added 3. Added (c).

Amended by R.1992 d.244, effective June 15, 1992.

See: 24 N.J.R. 1147(a), 24 N.J.R. 2243(a).

Text added at (b)10v through viii.

Amended by R.1993 d.662, effective December 20, 1993.

See: 25 N.J.R. 3891(a), 25 N.J.R. 5918(a).

Amended by R.1995 d.144, effective March 20, 1995 (operative July 1, 1995).

See: 26 N.J.R. 2698(a), 26 N.J.R. 3524(a), 27 N.J.R. 1180(a).

Amended by R.1995 d.477, effective September 5, 1995.

See: 27 N.J.R. 1717(a), 27 N.J.R. 3328(a).

Added (b)2v.

Amended by R.1998 d.332, effective July 6, 1998.

See: 30 N.J.R. 1377(a), 30 N.J.R. 2421(b).

Rewrote the section.

Amended by R.2000 d.492, effective December 18, 2000.

See: 32 N.J.R. 3219(a), 32 N.J.R. 4437(b).

Rewrote (b)25.

Amended by R.2001 d.127, effective April 16, 2001.

See: 33 N.J.R. 392(a), 33 N.J.R. 1195(a).

In (a)9, added new ix and recodified former ix through xiii as new x through xiv.

Amended by R.2001 d.368, effective October 15, 2001.

See: 33 N.J.R. 1990(a), 33 N.J.R. 3673(b).

In (b)9, inserted a new ix and recodified former ix through xiv as x through xv.

Amended by R.2001 d.369, effective October 15, 2001.

See: 33 N.J.R. 2365(a), 33 N.J.R. 3674(a).

In (b), substituted "seven" for "7½ (2335 mm)" in 2vi, rewrote 10, added a new 17, and recodified former 17 through 26 as 18 through 27.

Amended by R.2002 d.215, effective July 1, 2002.

See: 34 N.J.R. 1078(a), 34 N.J.R. 2312(a).

In (b)22, inserted new ii and recodified existing ii through xvii as iii through xviii.

Administrative correction.

See: 34 N.J.R. 3771(b).

Amended by R.2003 d.187, effective May 5, 2003.

See: 34 N.J.R. 4248(a), 35 N.J.R. 1939(c).

Rewrote the section.

Administrative correction.

See: 35 N.J.R. 2864(b).

Amended by R.2003 d.351, effective September 2, 2003.

See: 35 N.J.R. 1177(a), 35 N.J.R. 4051(a).

In (b)9, added xi; recodified existing xi to xiii as xii to xiv.

Case Notes

Set back provisions of borough zoning ordinance controlled conflicting state building code provisions. *Pfeuffer v. Sculco*, 242 N.J.Super. 181, 576 A.2d 309 (A.D.1990).

5:23-3.15 Plumbing subcode

(a) Rules concerning subcode adopted are as follows:

1. Pursuant to authority of P.L. 1975, c.217, as modified by P.L. 1996, c.53, the Commissioner hereby adopts the Model Code of the National Association of Plumbing Heating Cooling Contractors, known as "The National Standard Plumbing Code/2000," as the plumbing subcode for New Jersey.

i. Copies of this code may be obtained from the sponsor at: NAPHCC, P.O. Box 6808, Falls Church, VA 22046.

2. "The National Standard Plumbing Code/2000," may be known and cited as "the plumbing subcode."

(b) The following pages, chapters, sections or appendices of the plumbing subcode are amended as follows:

1. The section entitled "Administration," comprising sections ADM 1.1 through ADM 1.13, is deleted in its entirety.

2. Chapter 1 of the plumbing subcode, entitled "Definitions," is amended as follows:

i. The definition of the term "administrative authority" is deleted in its entirety, and substitute in lieu thereof the following language, "Unless otherwise defined herein, or unless the context clearly indicates otherwise, the term "administrative authority" for purposes of the plumbing subcode, shall mean the "plumbing subcode official."

ii. The definition of the term "approved" is amended to add after the word "authority" on line 2, the words "as defined in N.J.A.C. 5:23-3.7."

iii. The definition of the term "building" is deleted, and substitute in lieu thereof, the definition of the term "building" found in N.J.A.C. 5:23-1.4.

iv. The definition of the term "building classification" is amended to delete the term "administrative authority" and substitute in lieu thereof, the term "building subcode official."

v. The term and definition of "code" are deleted.

vi. The term and definition of "family" are deleted.

vii. The term and definition of "nuisance" are deleted.

viii. Add the following new definition after the definition of Swimming Pool: Swimming Pool, Public: A swimming pool located on any property other than a one or two family residential property and including, but not limited to, swimming pools open to the use of members, residents or the public.

3. Chapter 2 of the plumbing subcode, entitled "General Regulations," is amended as follows:

- i. Section 2.4.1 is amended to delete the sentence "The provisions of this paragraph may be waived by the administrative authority."
 - ii. Section 2.4.3 is amended to delete the phrase "or is approved by the administrative authority as having a desirable and acceptable function and is of ultimate benefit to the proper and continuing functioning of the plumbing system."
 - iii. Section 2.5 is deleted in its entirety.
 - iv. Section 2.9.3 is amended to delete the phrase "building code or as required by the proper administrative authority" and substitute in lieu thereof, the term "building subcode."
 - v. Section 2.12 is amended to delete subparagraph e.
 - vi. Section 2.16 is amended to insert the number "Forty-two" in the blank space under item (a), and to insert the number "Twenty-four" in the blank space under item (b). Under item (c), delete the words "as permitted in section 3.12.1."
 - vii. Section 2.19.1 is amended to delete the blank and the words "feet of any property line of the premises, or other."
 - viii. Section 2.19.2 is amended to delete the words "the Health Department or other agency having jurisdiction" and substitute in lieu thereof "The New Jersey Department of Environmental Protection."
 - ix. Section 2.25 (h) is amended to add at the end, the words "which does not otherwise adversely affect health and safety."
4. Chapter 3 of the plumbing subcode, entitled "Materials," is amended as follows:
- i. Section 3.1.1 is amended in the heading to delete the word "minimum" and under items (a) and (b) to delete the words "Section 3.12.2" at the end and substitute in lieu thereof, the words "N.J.A.C. 5:23-3.7."
 - ii. Section 3.1.2 is amended to delete the words "at least" on line 1. Also the words "section 3.12" are deleted at the end of the first paragraph and substitute in lieu thereof, the words "N.J.A.C. 5:23-3.7."
 - iii. Section 3.1.3 is amended to delete the words "Section 3.12.2" on line 2 and in lieu thereof, substitute the words "N.J.A.C. 5:23-3.7."
 - iv. Section 3.3.8a is amended to add the following phrase: "Pressure vessels shall be designed and constructed in accordance with the requirements of American Society of Mechanical Engineers, (ASME), Rules for Construction of Pressure Vessels, Section VIII/1998. Any pressure vessel that exceeds any of the following, shall meet the requirements of ASME and shall be stamped ASME: A heat input rating of 200,000 BTU per hour; or a water temperature of 200 degrees Fahrenheit; or a nominal water capacity of 120 gallons or any other thresholds of ASME that apply."
 - v. Section 3.3.11 entitled "septic tank" is deleted in its entirety.
 - vi. Section 3.11.1 is amended to delete the phrase "approved by the Administrative authority".
 - vii. Section 3.11.2 is amended to delete the phrase "except as may be otherwise authorized by the administrative authority".
 - viii. Sections 3.12.1, 3.12.2, 3.12.3, 3.12.4, and 3.12.5 are deleted in their entirety.
5. Chapter 4 of the plumbing subcode entitled, "Joints and Connections" is amended as follows:
- i. Section 4.2.17(a) is amended to delete the phrase "or be approved by the administrative authority."
 - ii. Section 4.3.8(b)(3) is amended to delete the words "be approved by the Administrative Authority if such products are not listed or labeled" and to add the phrase "or as permitted under N.J.A.C. 5:23-3.7."
6. Chapter 5 of the plumbing subcode entitled, "Traps, Cleanouts and Backwater Valves" is amended as follows:
- i. Section 5.3.2 is amended to add the phrase "in accordance with N.J.A.C. 5:23-3.3" after the words "administrative authority" on line 2.
 - ii. Section 5.3.4 is amended to add the phrase "in accordance with N.J.A.C. 5:23-3.3" after the words "administrative authority" on line 1.
7. Chapter 6 of the plumbing subcode, entitled "Interceptors," is amended as follows:

- iv. The definition of the term "building" is deleted and substitute the definition found in N.J.A.C. 5:23-1.4.
 - v. The definition of the term "code" is deleted.
 - vi. The definition of the term "code official" is deleted, and the following language is substituted: "For the purpose of the mechanical subcode, the term "code official" shall mean the appropriate subcode official as designated in N.J.A.C. 5:23-3.4."
3. Chapter 3 of the mechanical subcode, entitled "General Regulations," is amended as follows:
- i. Section 301.1 is amended to delete the words "in accordance with Section 101.2."
 - ii. Section 301.4 is amended to delete the words "in accordance with Section 105."
 - iii. Section 301.11 is deleted.
 - iv. Section 307.1 is amended to delete "approved plumbing fixture" on line 3 and insert the following: "drywell, sump pump, floor drain, or drainage system below floor."
 - v. Section 307.2.1 is amended to add the following after the word "disposal" on line 3: "in accordance with the adopted plumbing subcode."
 - vi. Section 307.2.2 is deleted.
 - vii. Section 309 is deleted.
 - viii. Section 312 is deleted.
4. Chapter 4 of the mechanical subcode, entitled "Ventilation," is amended as follows:
- i. Section 403.2 is amended to add the following language: "Exception: Where the registered design professional demonstrates that an engineered ventilation system design will prevent the maximum concentration of contaminants from exceeding that obtainable by the rate of outdoor air ventilation determined in accordance with Section 403.3, the minimum required rate of outside air shall be reduced in accordance with such engineered system design."
5. Chapter 5 of the mechanical subcode, entitled "Exhaust Systems," is amended as follows:
- i. Section 503.1 is amended to replace the second sentence with the following: "The type and wiring methods for motors in areas that contain flammable vapors or dusts shall be in accordance with the electrical subcode."
 - ii. Section 512.1 is amended to add a sentence as follows: "This section shall not apply to radon construction techniques covered by subchapter 10 of the Uniform Construction Code."
 - iii. 513.11 is amended to replace the third sentence with the following: "Secondary power shall be from a legally required standby power source complying with the electrical subcode." Also, delete the following sentences: "Power distribution from the two sources shall be by independent routes. Transfer to full standby power shall be automatic and within 60 seconds of failure of the primary power."
 - iv. 513.12.1 is amended to delete the wording in its entirety and substitute the following: "Wiring. All wiring shall be in accordance with the electrical subcode."
6. Chapter 6 of the mechanical subcode, entitled "Duct Systems," is amended as follows:
- i. Section 602.2.1 is amended to modify Exception 3 to read: "This section shall not apply to materials exposed within plenums in one-and two-family dwellings. Wire exposed in plenums of one-and two-family dwellings shall conform to the requirements of the electrical subcode."
 - ii. Section 602.2.1.1 is deleted in its entirety and substitute the following language: "Wiring, cable and raceways installed in a plenum shall be listed and installed in accordance with the electrical subcode."
 - iii. Section 602.2.1.4 is deleted in its entirety and substitute the following language: "Combustible electrical equipment exposed within a plenum shall be listed and labeled and shall be installed in accordance with the requirements of the electrical subcode."
7. Chapter 9 of the mechanical subcode, entitled "Specific Appliances, Fireplaces and Solid Fuel Burning Equipment," is amended as follows:
- i. Section 917.2 is deleted in its entirety.
 - ii. Section 917.3 is deleted in its entirety.
8. Chapter 10 of the mechanical subcode, entitled "Boilers, Water Heaters and Pressure Vessels," is amended as follows:
- i. Section 1001.1 is amended to replace the words "installation, alteration, and repair of boilers," with the words "installation and alteration of boilers."
 - ii. Section 1003.1 is amended to add the following phase: "Pressure vessels shall be designed and constructed in accordance with the requirements of ASME "Rules for Construction of Pressure Vessels, Section VIII/1998". "
9. Chapter 11 of the mechanical subcode, entitled "Refrigeration," is amended as follows:
- i. Section 1102.2.2 is deleted.
 - ii. Section 1109 is deleted.
10. Chapter 13 of the mechanical subcode, entitled "Fuel Oil Piping And Storage," is amended as follows:
- i. Section 1301.2 is amended to add the following sentence: "Where the tank is of a size and type that is

subject to the Department of Environmental Protection rules for the installation of Underground Storage Tanks at N.J.A.C. 7:14B, those rules shall apply.”

11. Chapter 15 of the mechanical subcode, entitled “Referenced Standards,” is amended as follows:

i. Under the heading “ICC,” amend the following titles:

- (1) Delete “IEC—2000 Electrical Code.”

(2) Delete "IFC—2000 International Fire Code" and substitute the following: "BOCA National Fire Prevention Code/1996."

(3) Delete "IBC—2000 International Building Code."

(4) Delete "IEEC—2000 International Energy Conservation Code."

(5) Delete "IPC—2000 International Plumbing Code."

12. Appendix A of the mechanical subcode entitled "Combustion Air and Chimney Connector Pass-Throughs" is informative and is not part of the code.

13. Appendix B of the mechanical subcode entitled "Recommended Permit Fee Schedule," is deleted in its entirety.

(c) Single station carbon monoxide alarms shall be installed and maintained in full operating condition in the immediate vicinity of each sleeping area in any guestroom or dwelling unit located in a building of Use Group I-1, R-1, R-2, R-3 or R-4, if the building contains a fuel-burning appliance or has an attached garage. An "open parking structure," as defined in the building subcode, shall not be deemed to be an attached garage.

1. Exceptions: Guestrooms or dwelling units which do not themselves contain a fuel-burning appliance or have an attached garage, but which are located in a building with a fuel-burning appliance or an attached garage, need not be provided with single station carbon monoxide alarms provided that:

i. The guestroom or dwelling unit is located more than one story above or below any story which contains a fuel-burning appliance or an attached garage; the guestroom or dwelling unit is not connected by duct work or ventilation shafts to any room containing a fuel-burning appliance or to an attached garage; and the building is provided with a common area carbon monoxide alarm system. The individual alarms shall be located in every room adjacent to the room(s) containing a fuel-burning appliance, and in every corridor, hall or lobby adjacent to such room(s) and in the immediate vicinity of any ventilated shaft, including, but not limited to, stair shafts, elevator shafts, ventilation shafts on the story containing the fuel-burning appliance and any story within two stories above or below said story. All such common area alarm devices shall be connected to an alarm monitoring station or shall be interconnected; or

ii. The building is provided with a monitored carbon monoxide alarm system. Individual alarms shall be located in every room containing a fuel-burning appliance. All such alarms shall be connected to an alarm monitoring station that shall be staffed at all times by a person who is trained and qualified to respond so as to

protect the health and safety of building occupants in the event of the activation of one or more alarms. Carbon monoxide alarms and fire alarms may be incorporated into a common monitored system.

2. Carbon monoxide alarms shall be manufactured, listed and labeled in accordance with UL 2034 and shall be installed in accordance with the requirements of this section and NFPA 720. Carbon monoxide alarms shall be battery operated, hard-wired or of the plug-in type.

R.1984 d.314, eff. August 6, 1984.

See: 16 N.J.R. 1139(a), 16 N.J.R. 2084(b).

New rule.

Amended by R.1985 d.154, effective April 1, 1985 (operative July 1, 1985).

See: 17 N.J.R. 239(a), 17 N.J.R. 810(a).

(a)2 added; subsection (c) added.

Amended by R.1986 d.380, effective September 22, 1986.

See: 18 N.J.R. 1235(a), 18 N.J.R. 1931(a).

Substantially amended.

Amended by R.1987 d.14, effective January 5, 1987.

See: 18 N.J.R. 2083(a), 19 N.J.R. 63(a).

In (b)5iv Section M-508 was deleted and Section M-508.1 was substituted.

Amended by R.1987 d.374, effective September 21, 1987.

See: 19 N.J.R. 1024(a), 19 N.J.R. 1720(b).

Model subcode revisions.

Amended by R.1988 d.270, effective June 20, 1988.

See: 20 N.J.R. 575(a), 20 N.J.R. 1344(a).

Added (a)3 and (c).

Amended by R.1990 d.253, effective May 21, 1990.

See: 22 N.J.R. 909(b), 22 N.J.R. 1554(a).

References to 1989 Supplement added; (c)1 and 3 added.

Amended by R.1990 d.507, effective October 15, 1990.

See: 22 N.J.R. 2208(a), 22 N.J.R. 3214(a).

Text conformed to BOCA National Code/1990.

Amended by R.1991 d.429, effective August 19, 1991.

See: 23 N.J.R. 1487(a), 23 N.J.R. 2501(a).

In (a), added 3. Added new (c).

Amended by R.1992 d.183, effective April 20, 1992.

See: 24 N.J.R. 167(a), 24 N.J.R. 1475(b).

Text added at (b)7 and (c)1, deleting parts of article 16 of the mechanical subcode.

Amended by R.1993 d.662, effective December 20, 1993.

See: 25 N.J.R. 3891(a), 25 N.J.R. 5918(a).

Amended by R.1995 d.120, effective March 6, 1995 (operative July 1, 1995).

See: 26 N.J.R. 4874(b), 27 N.J.R. 894(b).

Amended by R.1999 d.259, effective August 16, 1999.

See: 31 N.J.R. 825(a), 31 N.J.R. 2330(a).

Added (c).

Amended by R.2001 d.196, effective June 18, 2001.

See: 33 N.J.R. 6(a), 33 N.J.R. 2090(a).

Rewrote (a) and (b).

Administrative correction.

See: 33 N.J.R. 3310(a).

Amended by R.2002 d.15, effective January 22, 2002.

See: 33 N.J.R. 2933(b), 33 N.J.R. 3883(a), 34 N.J.R. 521(a).

In (c), added the last sentence in the introductory paragraph, and rewrote 1.

Amended by R.2003 d.137, effective April 7, 2003.

See: 34 N.J.R. 4277(a), 35 N.J.R. 1558(c).

In (c), deleted " , or any dwelling unit of Use Group" following "R-2", and substituted " , R-3 or R-4" for "R-3 located in a building required to be registered as a multiple dwelling" in the introductory paragraph.

5:23-3.20A (Reserved)

New Rule R.1992 d.183, effective April 20, 1992.

See: 24 N.J.R. 167(a), 24 N.J.R. 1475(b).

Repealed by R.2001 d.196, effective June 18, 2001.
 See: 33 N.J.R. 6(a), 33 N.J.R. 2090(a).
 Section was "Indoor air quality subcode".

5:23-3.21 One-and two-family dwelling subcode

(a) Rules concerning the subcode are adopted as follows:

1. Pursuant to authority of P.L. 1975, c.217, as modified by P.L. 1996, c.53, the Commissioner hereby adopts the model code of the International Code Council, International Residential Code known as the "IRC/2000" as the one-and two-family dwelling subcode in New Jersey subject to the modifications stated in (c) below.

i. Copies of this code may be obtained from the International Code Council at 4051 West Flossmoor Road, Country Club Hills, Illinois 60478-5795.

ii. The IRC/2000 may be known and cited as the one-and two-family dwelling subcode.

(b) The provisions of this subcode shall apply to the construction, alteration, repair, or increase in size of detached one-or two-family dwellings, or single family townhouses, of Group R-5, of Type 5B construction that are not more than two stories or 35 feet in height and no more than 4,800 square feet in area per floor. For the purpose of applying this section, a habitable attic shall not constitute a story. A habitable attic shall be an attic which has a stairway as a means of access and egress and in which the ceiling area at a height of seven feet above the attic floor is not more than one-third the area of the next floor below.

(c) The following chapters or sections of the IRC/2000 shall be modified as follows:

1. Chapter 1, General Administration, shall be deleted in its entirety. In addition, any referenced section of Chapter 1 shall be deleted throughout the code and "the administrative provisions of the Uniform Construction Code (N.J.A.C. 5:23)" shall be inserted.

2. Chapter 2, Definitions, shall be amended as follows:

- i. The definition of "Additions" shall be deleted.
- ii. The definition of "Alteration" shall be deleted.

iii. The definition of "Approved" shall be deleted and the following shall be inserted: "Approved refers to approval by the building subcode official or other authority having jurisdiction in accordance with the regulations."

iv. In the definition of "Approved Agency," "or other authority having jurisdiction in accordance with the Uniform Construction Code" shall be inserted after "Official."

v. The definitions of "Building" shall be deleted and the definition at N.J.A.C. 5:23-3.14(b)2iv shall be inserted.

vi. The definition of "Building, Existing" shall be deleted.

vii. The definition of "Building Line" shall be deleted.

viii. The definition of "Building Official" shall be deleted and the definition at N.J.A.C. 5:23-3.14(b)2vi shall be inserted.

ix. The definition of "Existing Installations" shall be deleted.

x. The definition of "Jurisdiction" shall be deleted.

xi. The definition of "Manufactured Home" shall be deleted.

xii. The definition of "Owner" shall be deleted and the definition at N.J.A.C. 5:23-3.14(b)2viii shall be inserted.

xiii. The definition of "Permit" shall be deleted.

xiv. The definition of "Person" shall be deleted.

xv. In the definition of "Potable Water," "public health authority having jurisdiction" shall be deleted and "Public Health Drinking Water Standards or the regulations" shall be inserted.

xvi. The definition of "Repair" shall be deleted.

3. Chapter 3, Building Planning, shall be amended as follows:

i. In Section R301.2.1.1, Design criteria, "with the provisions of this code or" shall be inserted after "accordance." In addition, Item 2 shall be deleted.

ii. In Section R301.2.1.2, Internal pressure, in the exception, "in one-and two-story buildings" shall be deleted from the first sentence.

iii. Table R301.2(1), Climatic and Geographic Design Criteria, shall be amended as follows:

Table No. 301.2(1)
 CLIMATIC AND GEOGRAPHIC DESIGN CRITERIA

Ground Snow Load (lbs./sq. ft.)	Wind Speed (mph)	Seismic Design Category	Subject to Damage from Weathering	Frost Line Depth	Subject to Damage	
					Termite	Decay
20 See note 4	See fig. R301.2(4)	N/A	Severe See note 1	2 feet-6 inches (Southern Area) 3 feet-0 inches	Moderate to Heavy	Slight to Moderate

(Northern Area)
See notes 2, 3 and 4

Notes:

1. Weathering may require a higher strength concrete or grade of masonry than necessary to satisfy structural requirements of this code. The grade of masonry units shall be determined from the ASTM C34, C55, C62, C73, C90, C129, C145, C216, or C625 listed in Chapter 43.

2. The frost line depth may require deeper footings than indicated in Section R403.1.4. The jurisdiction shall fill in the frost line depth column with minimum depth of footing below finished grade.

3. New Jersey is divided into two zones: Zone 1 consists of Monmouth and Burlington Counties and all counties to the south. Zone 2 consists of Mercer and Middlesex Counties and all counties to the north.

4. The enforcing agency having jurisdiction may establish values other than the ones listed for "ground snow load," and "frost line depth" if warranted by documented local climatic and geographic conditions."

iv. In Section R301.2.2, Seismic provisions, "and single-family townhouses" shall be inserted after "Detached one-and two-family dwellings."

v. Section R303.4, Stairway illumination, shall be deleted in its entirety.

vi. Section R303.6, Required heating, shall be deleted in its entirety.

vii. In Section R308.4, Hazardous locations, Item 9 shall be deleted. In the same section, Exception 9 shall be deleted.

viii. Section R309.2, Separation required, shall be deleted and the following shall be inserted: "Private garages located beneath rooms shall have walls, partitions, floors and ceilings separating the garage from the adjacent interior spaces constructed with not less than a one-hour fire resistance rating (see N.J.U.C.C. FTO-13). Attached private garages shall be completely separated from the adjacent interior spaces and the attic area by means of 1/2-inch gypsum board or equivalent applied to the garage side."

ix. In Section R310.1, Emergency escape and rescue required, "Basements with habitable spaces and" shall be deleted. The sentence shall start with "Every."

x. In Section R314.2, Treads and risers, "7 3/4 inches (196 mm)" shall be deleted and "8 3/4 inches (210 mm)" shall be inserted. In the same section, "10 inches (254 mm)" shall be deleted and "nine inches (229 mm)" shall be inserted.

xi. In Section R314.4, Winders, "10 inches (254 mm)" shall be deleted and "nine inches (229 mm)" shall be inserted.

xii. In Section R314.6, Circular stairways, "six inches (152 mm)" shall be deleted and "nine inches (229 mm)" shall be inserted.

xiii. Section R314.7, Illumination, shall be deleted in its entirety.

xiv. Section R315.1 shall be deleted and Section 315.1, Handrails, of the 1995 edition of the Council of American Building Officials One-and Two-Family Dwelling Code (1995 CABO One-and Two-Family Dwelling Code) shall be inserted as follows: "Handrails. Handrails having minimum and maximum heights of 30

inches and 38 inches (762 mm and 965 mm), respectively, measured vertically from the nosing of the treads, shall be provided on at least one side of stairways of three or more risers. Spiral stairways shall have the required handrail located on the outside of the radius. All required handrails shall be continuous the full length of the stairs. Ends shall be returned or shall terminate the newel posts or safety terminals. Handrails adjacent to a wall shall have a space not less than 1 1/2 inches (38 mm) between the wall and the handrail.

Exceptions:

1. Handrails shall be permitted to be interrupted by a newel post at a turn.

2. The use of a volute, turnout, or starting easing shall be allowed over the lowest tread."

xv. Section R316.2, Guard opening limitations, "Required guards shall not be constructed with horizontal rails or other ornamental patterns that result in a ladder effect." shall be deleted in its entirety.

xvi. Section R317.1.1, Alterations, repairs and additions, shall be deleted in its entirety.

xvii. In Section R317.2, Power source, "Smoke alarms shall be permitted to be battery operated when installed in buildings without commercial power or in buildings that undergo alterations, repairs, or additions regulated by Section R317.1.1." shall be deleted.

xviii. In Section R321.1, Dwelling unit separation, "13R, or 13D" shall be inserted after "NFPA 13."

xix. In Section R322.1, Moisture control, Exception 3 shall be deleted.

xx. Section R325.1, Site address, shall be deleted in its entirety.

xxi. In Section R327.1.8, Manufactured housing, "and the anchor and tie-down requirements of Section AE604 and AE605 of Appendix E shall apply" shall be deleted.

4. Chapter 4, Foundations shall be amended as follows:

i. In Table R401.4.1, Presumptive Load Bearing Values of Foundation Materials, "12,000; 4,000; 3,000; 2,000; and 1,500^b" shall be deleted and "12,000; 6,000; 5,000; 3,000; and 2,000" shall be inserted.

ii. In Section R403.3.2 of the IRC/2000, Drainage, in the second sentence, "as detailed in Table 405.1" shall be deleted."

iii. In Section R404.1, Concrete and masonry foundation walls, the second sentence shall be deleted.

iv. In Section R404.4, Insulating concrete form foundation walls, the second sentence shall be deleted.

v. Sections R405, Foundation Drainage, and R406, Foundation Waterproofing and Dampproofing, shall be deleted and the text of Section 1806, Dampproofing and Waterproofing from the International Building Code (IBC)/2000 shall be inserted as follows: "R406.1 Where required. Walls or portions thereof that retain earth and enclose interior spaces and floors below grade shall be waterproofed and dampproofed in accordance with this section, with the exception of those spaces containing groups other than residential and institutional where such omission is not detrimental to the building or occupancy.

R406.1.1 Story above grade. Where a basement is considered a story above grade and the finished ground level adjacent to the basement wall is below the basement floor elevation for 25 percent or more of the perimeter, the floor and walls shall be dampproofed in accordance with Section R406.2 and a foundation drain shall be installed in accordance with Section R406.4.1. The foundation drain shall be installed around the portion of the perimeter where the basement floor is below ground level. The provisions of Sections R406.3 and R406.4.1 shall not apply in this case.

R406.1.2 Underfloor space. The finished ground level of an underfloor space such as a crawl space shall not be located below the bottom of the footings. Where there is evidence that the ground water table rises to within six inches (152 mm) of the ground level at the outside building perimeter or where there is evidence that the surface water does not readily drain from the building site, the ground level of the underfloor space shall be as high as the outside finished ground level, unless an approved drainage system is provided. The provisions of Sections R406.2, R406.3 and R406.4 shall not apply in this case.

R406.1.2.1 Floor hazard areas. For buildings and structures in flood hazard areas as established in Section R327, the finished ground level of an underfloor space such as a crawl space shall be equal to or higher than the outside finished ground level.

R406.1.3 Groundwater control. Where the groundwater table is lowered and maintained at an elevation not less than 6 inches (152 mm) below the bottom of the lowest floor, the floor and walls shall be dampproofed in accordance with Section R406.2. The design of the system to lower the groundwater table shall be based on accepted principles of engineering that shall consider, but not necessarily be limited to, permeability of the soil, rate at which water enters the drainage system, rated capacity of pumps, head against which pumps are to pump; and the rated capacity of the disposal area of the system.

R406.2 Dampproofing required. Where hydrostatic pressure will not occur, floors and walls for other than wood foundation systems shall be dampproofed in accordance with this section. Wood foundation systems shall be constructed in accordance with AFPA TR7.

R406.2.1 Floors. Dampproofing materials for floors shall be installed between the floor and the base course required by Section R406.4.1, except where a separate floor is provided above a concrete slab.

Where installed beneath the slab, dampproofing shall consist of not less than six-mil (0.006 inch; 0.152 mm) polyethylene with joints lapped not less than six inches (152 mm), or other approved methods or materials. Where permitted to be installed on top of the slab, dampproofing shall consist of mopped-on bitumen, not less than four-mil (0.004 inch; 0.102 mm) polyethylene, or other approved methods or materials. Joints in the membrane shall be lapped and sealed in accordance with the manufacturer's installation instructions.

R406.2.2 Walls. Dampproofing materials for walls shall be installed on the exterior surface of the wall, and shall extend from the top of the footing to above ground level.

Dampproofing shall consist of a bituminous material, three pounds per square yard (16N/m²) of acrylic modified cement, -inch (3.2 mm) coat of surface-bonding mortar complying with ASTM C 887, any of the materials permitted for waterproofing by Section R406.3.2, or other approved methods or materials.

R406.2.2.1 Surface preparation of walls. Prior to application of dampproofing materials on concrete walls, holes and recesses resulting from the removal of form ties shall be sealed with a bituminous material or other approved methods or materials. Unit masonry walls shall be parged on the exterior surface below ground level with not less than inch (9.5 mm) of Portland cement mortar. The parging shall be coved at the footing.

Exception: Parging of unit masonry walls is not required where a material is approved for direct application to the masonry.

R406.3 Waterproofing required. Where the groundwater investigation indicates that a hydrostatic pressure condition exists, and the design does not include a groundwater control system as described in Section R406.1.3, walls and floors shall be waterproofed in accordance with this section.

R406.3.1 Floors. Floors required to be waterproofed shall be of concrete, designed and constructed to withstand the hydrostatic pressures to which the floors will be subjected.

Waterproofing shall be accomplished by placing a membrane of rubberized asphalt, butyl rubber, or not less than six-mil polyvinyl chloride with joints lapped not less than six inches (152 mm) or other approved materials under the slab. Joints in the membrane shall be lapped and sealed in accordance with the manufacturer's installation instructions.

R406.3.2 Walls. Walls required to be waterproofed shall be of concrete or masonry and shall be designed and constructed to withstand the hydrostatic pressures and other lateral loads to which the walls will be subjected.

Waterproofing shall be applied from the bottom of the wall to not less than 12 inches (305 mm) above the maximum elevation of the ground water table. The remainder of the wall shall be dampproofed in accordance with Section R406.2.2. Waterproofing shall consist of two-ply hot-mopped felts, not less than six-mil (0.006 inch; 0.152 mm) polyvinyl chloride, 40-mil (0.040 inch; 1.02 mm) polymer-modified asphalt, six-mil (0.006 inch; 0.152 mm) polyethylene or other approved methods or materials capable of bridging nonstructural cracks. Joints in the membrane shall be lapped and sealed in accordance with the manufacturer's installation instructions.

R406.3.2.1 Surface preparation of walls. Prior to the application of waterproofing materials on concrete or masonry walls, the walls shall be prepared in accordance with Section R406.2.2.1.

R406.3.3 Joints and penetrations. Joints in walls and floors, joints between the wall and floor, and penetrations of the wall and floor shall be made watertight utilizing approved methods and materials.

R406.4 Subsoil drainage system. Where a hydrostatic pressure condition does not exist, dampproofing shall be provided and a base shall be installed under the floor and a drain installed around the foundation perimeter. A subsoil drainage system designed and constructed in accordance with Section R406.1.3 shall be deemed adequate for lowering the groundwater table.

R406.4.1 Floor base course. Floors of basements, except as provided for in Section R406.1.1, shall be placed over a floor base course not less than four inches (102 mm) in thickness that consists of gravel or crushed stone containing not more than 10 percent of material that passes through a No. 4 (4.75 mm) sieve.

Exception: Where a site is located in well-drained gravel or sand/gravel mixture soils, a dedicated drainage system is not required.

R406.4.2 Foundation drain. A drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 (4.75 mm) sieve. The drain shall extend a minimum of 12 inches (305 mm)

beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than six inches (152 mm) above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or the top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than two inches (51 mm) of gravel or crushed stone complying with Section R406.4 and shall be covered with not less than six inches (152 mm) of the same material.

R406.4.3 Drainage discharge. The floor base and foundation perimeter drain shall discharge by gravity or mechanical means into an approved drainage system that complies with the plumbing subcode.

Exception: Where a site is located in well-drained gravel or sand/gravel mixture soils, a dedicated drainage system is not required."

5. Chapter 6, Wall Construction, shall be amended as follows:

i. In Figure R602.6.1, Notching and Bored Hole Limitations for Exterior Walls and Bearing Walls, "six-16 penny nails" shall be deleted and "three-8d nails" shall be inserted.

ii. In Table R602.10.1, Wall Bracing, under the column "Seismic Design Category or Wind Speed," at Category D₁ and D₂, "less than 110 mph" shall be deleted and "less than 120 mph" shall be inserted. In addition, the fourth row of Table R602.10.1 shall be deleted in its entirety.

iii. Section R606.1.1, Professional registration not required, shall be deleted in its entirety.

iv. In Section R611.1, General, the second sentence shall be deleted.

6. Chapter 8, Roof-Ceiling Construction, shall be amended as follows:

i. Table R802.11, Required Strength of Truss or Rafter Tie-Down Connections to Resist Wind Uplift Forces^{a, b, c, d}, shall be deleted and the following shall be inserted:

"Required Strength of Truss or Rafter Tie-Down Connections to Resist Wind Uplift Forces^{a, b, c, d}
(Pounds per tie-down connection)

Design Wind Load (psf) ^d	Total Roof Width Including Overhang (feet)				
	24	28	32	36	40
20	192	224	256	288	320
30	432	504	576	648	720
40	672	784	895	1,008	1,120
50	912	1,064	1,216	1,368	1,520
60	1,152	1,344	1,536	1,728	1,920

Design Wind Load (psf)d	Total Roof Width Including Overhang (feet)				
	24	28	32	36	40
70	1,392	1,624	1,856	2,088	2,320
80	1,632	1,904	2,176	2,448	2,720
90	1,872	2,184	2,496	2,808	3,120

For SI: 1 inch = 25.4 mm, 1 foot = 304.8 mm, 1 pound per square foot = 0.0479 kN/m², 1 pound = 0.454 kg.

a. Wind uplift forces are based on 24-inch spacing of roof trusses or rafters. For spacing other than 24 inches, forces shall be adjusted accordingly.

b. Interpolation is permitted for intermediate values of wind uplift pressures and roof widths.

c. The rated capacity of approved tie-down devices is permitted to include up to a 60-percent increase for wind effects where allowed by material specifications.

d. Figure R301.2(4) and Table R301.2(2) shall be used in determining the design wind load."

7. Chapter 10, Chimneys and Fireplaces, shall be amended as follows:

i. In Section R1001.15, Chimney clearances, Exception 3, "12 inches" shall be deleted and "six inches" shall be inserted.

ii. In Figure 1001.15, Clearance from Combustibles, "12 IN. MIN." shall be deleted and "6 IN. MIN." shall be inserted.

iii. In Section R1003.12, Fireplace clearance, Exception 3, "12 inches" shall be deleted and "six inches" shall be inserted.

8. Chapter 11, Energy Efficiency, shall be deleted in its entirety.

9. Chapter 12, Mechanical Administration, shall be amended as follows:

i. Section M-1202, Existing Mechanical Systems, shall be deleted in its entirety.

10. Part VI, Fuel Gas, shall be amended as follows:

i. In Section G2402.3, Terms defined in other codes, "ICC Electrical Code, International Building Code, International Fire Code, and International Plumbing Code" shall be deleted and "electrical, building, fire protection, and plumbing subcodes" shall be inserted.

ii. Section G2403, entitled "General Definitions" shall be amended as follows:

(1) The definition "code" shall be deleted.

(2) The definition of "code official" shall be deleted and the following shall be inserted: "For the purpose of this subcode, the term 'code official' shall mean the appropriate subcode official as required by N.J.A.C. 5:23-3.4."

(3) In the definition of "labeled," "authority having jurisdiction" shall be deleted and "construction official" shall be inserted.

(4) In the definition of "listed," "authority having jurisdiction" shall be deleted and "Uniform Construction Code (N.J.A.C. 5:23)" shall be inserted.

iii. Section G2404.5, Repair, shall be deleted in its entirety.

iv. In Section G2408.1, General, the second paragraph shall be deleted in its entirety.

v. Section G2409, Clearance Reduction, shall be amended as follows:

(1) In Section G2409.4, Central heating boilers and furnaces, "G2409.4.1 through G2409.4.7" shall be deleted and "G2409.4.1 through G2409.4.5 and G2409.4.7" shall be inserted.

(2) Section G2409.4.6, Unlisted central heating furnaces, shall be deleted in its entirety.

vi. Section G2411.2, Liquefied petroleum gas storage, shall be amended as follows: "Delete in its entirety Section 3-2.5, entitled 'Installation of Containers on Roofs of Buildings' in NFPA 58, 1998 Edition. The installation of LP Gas containers on roofs of buildings shall be strictly prohibited." shall be inserted after the first sentence.

vii. Section G2413.3, Other materials, shall be deleted in its entirety.

viii. In Section G2426.5.5, Inspection of chimneys, "clear and free of obstructions" shall be deleted and "inspected in accordance with the chimney certification program as provided for in N.J.A.C. 5:23-2.20(c)" shall be inserted. In the same section, the exception shall be deleted in its entirety.

11. Part VII, Plumbing, shall be deleted in its entirety. Plumbing requirements under the scope of this subcode shall be regulated by the plumbing subcode.

12. Part VIII, Electrical, shall be deleted in its entirety. Electrical requirements under the scope of this subcode shall be regulated by the electrical subcode.

13. Part IX, Chapter 42, Referenced standards, shall be amended as follows:

i. Under the subheading, NFPA, "NFPA 13-96, Installation of Sprinkler Systems," shall be deleted and "NFPA 13-99, Installation of Sprinkler Systems; NFPA 13D-99, Installation of Sprinkler Systems in One-and Two-Family Dwellings and Manufactured Homes; and NFPA 13R-99, Installation of Sprinkler Systems in Residential Occupancies Up To and Including Four Stories in Height" shall be inserted.

14. The Appendices shall be amended as follows:

i. In Appendix A, Sizing and Capacities of Gas Piping, at Letters (e) and (d), "authority having jurisdiction" shall be deleted and "construction official" shall be inserted.

ii. Appendix D, Recommended Procedure for Safety Inspection of an Existing Appliance Installation; Appendix E, Manufactured Housing Used as Dwellings; and Appendix F, Radon Control Methods, are deleted in their entirety.

iii. In Appendix G, Section AG102.1, General, the definition of "swimming pool" shall be deleted and the following shall be inserted: "Any structure intended for swimming or recreational bathing that contains water, provided that these regulations shall not be applicable to any pool less than 24 inches (610 mm) deep or having a surface area less than 250 square feet (23.25m²). This includes in-ground, above-ground, on-ground swimming pools, hot tubs, and spas."

iv. In Appendix G, Section AG105.2, Outdoor swimming pool, Provision 9 shall be deleted in its entirety. In the same section, under Provision 10, Item 10.1 shall be deleted. Item 10.2 shall be renumbered as 10.1.

v. Appendix H, Patio Covers; Appendix I, Private Sewage Disposal; and Appendix J, Existing Buildings and Structures, shall be deleted in their entirety.

New Rule, R.1985 d.324, effective July 1, 1985.

See: 17 N.J.R. 861(c), 17 N.J.R. 1646(a).

Amended by R.1987 d.374, effective September 21, 1987.

See: 19 N.J.R. 1024(a), 19 N.J.R. 1720(b).

Model subcode revisions.

Amended by R.1988 d.388, effective August 1, 1988.

See: 20 N.J.R. 1130(a), 20 N.J.R. 2073(b).

Added (c).

Amended by R.1990 d.253, effective May 21, 1990.

See: 22 N.J.R. 909(b), 22 N.J.R. 1554(a).

References to 1989 Supplement added; (b)1ii(5), 2, 4, 8 and 9 amended; (b)5, 6 and 7 added; (c) deleted; Table R-201.2 added. Amended by R.1991 d.571, effective November 18, 1991.

See: 23 N.J.R. 2619(a), 23 N.J.R. 3444(b).

Added new (c).

Amended by R.1992 d.208, effective May 18, 1992.

See: 24 N.J.R. 680(a), 24 N.J.R. 1879(a).

Code provisions applicable to flood hazard zones clarified.

Amended by R.1993 d.662, effective December 20, 1993.

See: 25 N.J.R. 3891(a), 25 N.J.R. 5918(a).

Amended by R.1998 d.332, effective July 6, 1998.

See: 30 N.J.R. 1377(a), 30 N.J.R. 2421(b).

Rewrote the section.

Amended by R.2000 d.166, effective April 17, 2000.

See: 31 N.J.R. 4151(a), 32 N.J.R. 1376(a).

In (c)4, substituted "more pressure than would be exerted by back-fill" for "lateral pressure from soils" following "subject to" in ii, and substituted "drainage" for "designated disposal" preceding "system" and added "according to the Unified Soil Classification System, Group I Soils" at the end of iii; and inserted (c)9iv.

Amended by R.2001 d.369, effective October 15, 2001.

See: 33 N.J.R. 2365(a), 33 N.J.R. 3674(a).

In (b), inserted "that are" following "type 5B construction", "no more" preceding "than 4,800 square feet", and substituted "seven feet" for "7½ feet (2,235 mm.)".

Amended by R.2003 d.187, effective May 5, 2003.

See: 34 N.J.R. 4248(a), 35 N.J.R. 1939(c).

Rewrote the section.

5:23-3.22 Fuel gas subcode

(a) Rules concerning the subcode adopted are as follows:

1. Pursuant to authority of P.L. 1975, c.217, the Commissioner hereby adopts the model code of the International Code Council, Inc., known as the International Fuel Gas Code/2000. This code is hereby adopted by reference as the Fuel Gas Subcode for the State of New Jersey subject to the modifications stated in (b) below.

5:23-12.8 Alterations, replacements, damages, increases in size, changes in use group, minor work, ordinary repairs

(a) In complying with this chapter, calculations concerning alterations, replacements, damages, increases in size and changes in use group, in N.J.A.C. 5:23-2, shall be performed using data for entire structures. The alteration provisions applicable to the whole structure and/or calculations in N.J.A.C. 5:23-2 shall not be applied to individual elevator devices.

(b) For purposes of this subchapter, alteration of an elevator device means any change to equipment other than minor work and ordinary repair, as defined in N.J.A.C. 5:23-2.17A and 5:23-9.3. When work that includes the alteration of an elevator device has a total cost of less than 50 percent of the physical value of the building, the alteration of the elevator device shall comply only with the applicable requirements of Part XII (Alterations, Repairs, Replacements and Maintenance) of the most recent edition of ASME A17.1 referenced in the building subcode.

Amended by R.1995 d.564, effective November 6, 1995 (operative March 1, 1996).
See: 27 N.J.R. 2829(a), 27 N.J.R. 4281(b).

5:23-12.9 Certificate of compliance requirements

(a) A device shall be granted a certificate of compliance by the construction official for the time period specified based upon N.J.A.C. 5:23-12.3. No device shall be operated unless a valid certificate of compliance has been issued except for the initial period after work under a permit has been completed as per (f) below. Any violation shall be corrected before a new certificate of compliance may be issued.

(b) A temporary certificate of compliance may be issued by the construction official for a device in order to keep the device in operation on which work, as a result of violations, is being diligently performed, if the elevator subcode official finds that no hazard to the public is thereby created. A temporary certificate of compliance may be issued for no longer than 180 days, even if the device is inspected on an annual basis.

(c) The elevator subcode official shall provide written notice to the construction official whenever a temporary certificate of compliance or certificate of compliance is granted by the construction official.

(d) No certificate of compliance shall be issued for any elevator device in use on or before July 1, 1992 that is subject to these rules and is not registered with the Department in accordance with N.J.A.C. 5:23-12.4, except elevator devices in structures classified as Use Group R-3 and R-4 shall be exempt from registration. Elevator devices wholly within R-2 residences, not accessible to the general public shall also be exempt.

(e) No certificate of compliance or temporary certificate of compliance shall be issued for any elevator device, as required by this section, which has been approved to operate during the initial period, after a permit, in accordance with (f) below if the device has not been registered pursuant to this subchapter by its first routine inspection, even if a certificate of occupancy, temporary certificate of occupancy or certificate of approval has been issued.

(f) Except as otherwise provided in (e) above, a new device or an existing device which has had work done under a permit shall be issued a certificate of compliance upon the first cyclical inspection based on the following:

1. A device has been approved following the inspection and witnessing of an acceptance test, as required by N.J.A.C. 5:23-12.2, by the application of an Inspection Sticker Approval for Elevator and a recommendation by the elevator subcode official on an Elevator Subcode Technical Section form for a certificate of occupancy or approval, as the case may be.

i. The date of the approval shall begin the cycle of inspections and tests for new devices in a new building and for new devices in an existing building which did not have elevator devices previously.

ii. The date of the approval of an existing device in an existing building shall not change the device's existing cycle of inspections and tests. The cycle shall remain consistent with the inspection cycle in the building, except the device shall not be subject to the five year test before it is due as long as the acceptance test performed under the permit was a full five year test.

2. A device has been approved following the inspection process, as required for minor work by N.J.A.C. 5:23-2.17A(d)2 and 12.2, by the application of an Inspection Sticker Approval for Elevator and a recommendation by the elevator subcode official on an Elevator Subcode Technical Section form for a certificate of approval.

i. The device may operate under the approval given under the permit until the next cyclical inspection, as determined by the inspection cycle of the building, and then shall be subject to a routine or periodic inspection the same as all other elevator devices in the building.

New Rule, R.1995 d.476, effective September 5, 1995 (operative January 1, 1996).

See: 27 N.J.R. 1846(a), 27 N.J.R. 3325(b).

Amended by R.1995 d.564, effective November 6, 1995 (operative March 1, 1996).

See: 27 N.J.R. 2829(a), 27 N.J.R. 4281(b).

Amended by R.1996 d.512, effective November 4, 1996.

See: 28 N.J.R. 3697(a), 28 N.J.R. 4782(a).

5:23-12.10 Inspections in seasonal facilities

(a) For purposes of this subchapter, a "seasonal facility" is defined as a building that is open, and available for use by members of the public, employees or maintenance personnel or any occupants, for a period of not more than 184

consecutive days and is then closed and not available for such use for at least 181 consecutive days.

(b) Elevator devices in seasonal facilities shall be subject only to the applicable periodic inspections and tests (one, three and five year). Such inspections and tests shall be performed prior to the building being used by employees, maintenance personnel, members of the public or occupants. A certificate of compliance or temporary certificate of compliance shall be granted only for the time period during which the device is allowed to operate in the seasonal facility.

1. The fees for performing such inspections and witnessing tests shall be in accordance with such provisions of N.J.A.C. 5:23-12.6 as may be applicable.

(c) An owner of a building with one or more elevator devices may obtain classification of the building as a "seasonal facility" from the local enforcing agency. A request for such classification shall contain the information in (d) below and shall be signed by the owner.

(d) An application for classification of a building as a seasonal facility shall include the following information:

1. The owner's name and address, the building address, the registration number, the device identification number(s), and the date of the last inspection;

2. That the total number of consecutive calendar days per year when the building is in use by the public, employees, maintenance personnel or occupants does not exceed 184 days and that the building is then closed for such use for at least 181 consecutive calendar days;

3. That the elevator devices in the building are not accessible to members of the public, employees, maintenance personnel or building occupants during the time in which the building is closed; and

4. That the disconnects located in elevator device machine rooms and machinery spaces are, during the time in which the building is closed, in the "off" position and locked; and that the access to the keys is secured.

(e) The seasonal facility classification shall become invalid when the conditions of the classification are no longer met. The owner shall immediately notify the enforcing agency of any change in the conditions upon which the approval of classification as a seasonal facility was based.

1. Classification of a building as a seasonal facility shall not be renewed if the classification became invalid as a result of a violation of any conditions of the approval of the classification.

(f) During the period of time in which any device in seasonal facility is in operation, it shall be subject to all applicable code requirements in the same manner as any other device subject to this subchapter.

New Rule, R.1996 d.323, effective July 15, 1996 (operative January 1, 1997).

See: 28 N.J.R. 2112(a), 28 N.J.R. 3549(a).

5:23-12.11 Notice concerning accidents

(a) The construction official shall notify the Department about those accidents involving elevator devices (reported to the enforcing agency as required by the building subcode) that involve either death or personal injury requiring medical treatment by a physician other than first aid or damage to the elevator device that was either a result or cause of the accident and which affects the future safe operation of the device. For purposes of this section, "first aid" means the one time treatment or observation of scratches, cuts not requiring stitches, burns, splinters or contusions, or a diagnostic procedure, including examination and x-rays, which does not indicate any need for further medical treatment. First aid may be performed by licensed medical personnel or by other persons.

1. The construction official shall notify the Elevator Safety Unit about any accident within five working days after the accident is reported to the enforcing agency, except that accidents involving devices under the Department's jurisdiction shall be reported as soon as possible, but not later than the end of the next business day after an accident is reported to the construction official.

2. Within five working days after an accident involving a device not under the Department's jurisdiction is reported to the enforcing agency, a copy of the Accident/Incident Report form and all attachments, as indicated in the form, shall be forwarded to the Elevator Safety Unit by the construction official.

3. When a special inspection is performed by a person other than the Elevator Safety Unit subcode official, a copy of the Inspection Report shall be forwarded to the Elevator Safety Unit within five working days after the date of the special inspection.

New Rule, R.1997 d.64, effective February 18, 1997 (operative May 19, 1997).

See: 28 N.J.R. 4695(a), 29 N.J.R. 550(a).

5:23-12.12 Special safety equipment

(a) On all existing elevators, a space between the elevator hoistway door and the car door or gate shall comply with the requirements of Rule 204.4c of ASME A17.1-1990. Where the space exceeds the maximum distance, a space guard shall be installed to minimize the gap. Sight guards shall be installed along with the space guards on horizontally sliding type hoistways.

1. Freight elevators that are equipped with horizontally swinging doors, are not accessible to the general public, and are located in the factories, warehouses, garages, or similar buildings shall not be required to comply.

2. Installation of space and sight guards shall comply with all applicable requirements of ASME A17.3-1993 and shall be considered minor work within the meaning of N.J.A.C. 5:23-2.17A.

(b) In buildings containing more than one elevator device, each such device shall be identified according to ASME A17.1 referenced in the building subcode.

1. In addition, each elevator shall be identified by such a number in every elevator lobby. The identification number shall be a minimum of 1½ inches high and of a color that contrasts with the background. The number shall be permanent and shall be on or adjacent to every elevator hoistway entrance frame. By August 4, 2003, all existing elevators shall comply with this requirement.

(c) On each existing escalator, a skirt obstruction device conforming to ASME A17.1-93-95, Rule 805.1.h. and a step level device conforming to ASME A17.1-93-95, Rule 805.1.s. shall be installed by August 4, 2003.

(d) On each existing elevator, a floating (movable) platform that permits the operation of the elevator when the car door or gate is not in the closed position shall be prohibited. Use of a floating (movable) platform that exists as of February 4, 2002 on any elevator shall be discontinued by August 4, 2003.

(e) A sign stating "DO NOT USE A STANDING ESCALATOR AS A BUILDING STAIR" shall be permanently placed where it is readily visible to the general public at the top and bottom landings of an escalator. Each sign shall comply with the applicable requirements of ASME A17.1-93-95, Rule 805.2.b. This requirement shall apply to new escalator installations and to existing escalators. All existing escalators shall be required to comply with this subsection by August 18, 2004.

New Rule, R.1997 d.305, effective July 21, 1997.

See: 29 N.J.R. 2205(a), 29 N.J.R. 3249(a).

Amended by R.2002 d.43, effective February 4, 2002.

See: 33 N.J.R. 3714(a), 34 N.J.R. 732(b).

Rewrote the section.

Administrative correction.

See: 35 N.J.R. 219(c).

Amended by R.2003 d.72, effective February 18, 2003.

See: 34 N.J.R. 3672(a), 35 N.J.R. 1055(a).

Added (e).

Amended by R.2003 d.187, effective May 5, 2003.

See: 34 N.J.R. 1939(c), 35 N.J.R. 4248(a).

In (b), deleted "BOCA Rule 3003.3 and" preceding "ASME A17.1".

mented by P.L. 1997, c.336, is entitled "Optional Elevator Inspection Program" and shall be known and cited throughout this chapter as N.J.A.C. 5:23-12A. When referred to in this subchapter, it may be cited as "this subchapter."

(b) Unless otherwise specifically provided, all references to paragraphs, sections, or to provisions not specifically identified, shall be construed to refer to such paragraph or section or provision of this subchapter.

(c) This subchapter shall control all matters relating to the administration of the registration of qualified elevator device inspection firms, hereinafter referred to as "qualified firms," qualified elevator device inspectors and the elevator devices enrolled in this optional program, as defined in (d) below.

(d) For purposes of this subchapter, "elevator" or "elevator device" means a hoisting and lowering device equipped with a car or platform which moves in guides for the transportation of individuals or freight in a substantially vertical direction through successive floors or levels of a building or structure. The term shall include, without limitation, elevators, dumbwaiters, wheelchair lifts, manlifts, stairway chairlifts and any device within the scope of ASME A17.1 (Safety Code for Elevators and Escalators) or ASME A90.1 (Safety Standard for Belt Manlifts), except escalators and moving walks.

1. This definition shall not apply to any conveyor devices that are process equipment.

5:23-12A.2 Qualified elevator device inspection firms

(a) Any sole proprietorship, partnership, association or corporation that is engaged in the business of maintaining, inspecting and testing elevator devices, has at all times, as a bona fide employee, at least one qualified elevator device inspector, and carries general liability insurance in at least the amount of \$4,000,000 for each person and each occurrence to satisfy claims or judgments for property damage and/or personal injury may apply for registration with the Department as a qualified firm.

1. The application shall contain information relating to the financial integrity of the firm, as evidenced by a reviewed financial statement prepared by an independent certified public accountant.

2. The application shall contain the names and addresses and home phone numbers of all persons who hold at least a ten percent interest in the qualified firm and/or are corporate officers.

3. Each applicant for registration as a qualified firm shall disclose in the application any subsidiary or parent relationship with any other qualified firm or other entity regulated by the State Uniform Construction Code and shall further disclose all interests of any officer, partner, or stockholder of the firm in any other qualified firm or

SUBCHAPTER 12A. OPTIONAL ELEVATOR INSPECTION PROGRAM

5:23-12A.1 Title; scope; intent

(a) This subchapter of the rules, adopted pursuant to the authority of the Uniform Construction Code Act, as supple-

other entity regulated by the State Uniform Construction Code.

4. Each application shall include a sample form of the contract of full service needs to be used for the purposes of this subchapter.

(b) Upon receipt of a completed application on a form prescribed by the Department, including the information in (a) above and a nonrefundable fee of \$250.00, the Department shall issue a certificate of registration, unless the application is denied in accordance with (c) below.

1. The certificate of registration shall remain valid, unless revoked in accordance with (c) below, for two consecutive years following the date of registration; provided, however, that the certificate of registration shall become inactive for any period of time during which the firm ceases to engage in the business of maintaining, inspecting and testing elevator devices or ceases to employ at least one qualified elevator device inspector. It shall be the responsibility of the qualified firm to inform the Department within 30 days of any changes to the status of the qualified firm during the two-year registration period. It shall be the responsibility of the firm to reapply for registration at least two months prior to the renewal date to make current the information contained in the original application by submission of a completed reapplication form, as prescribed by the Commissioner.

(c) A certificate of registration may be denied or revoked if the Department determines that the firm, or any person holding an ownership interest in the firm or otherwise authorized to represent the firm, has at any time:

1. Willfully made a misstatement of material fact in an application for issuance or renewal of a registration certificate;
2. Willfully committed fraud in connection with the maintenance, inspection or testing of any elevator device;
3. Maintained, inspected or tested any elevator device in a grossly negligent manner;
4. Failed to ensure that the qualified elevator device inspectors that it employs perform their duties in accordance with the requirements of this subchapter;
5. Habitually failed to ensure the timely submission of the elevator device certification in accordance with the requirements of this subchapter;
6. Willfully violated the requirements of the State Uniform Construction Code to any substantial degree; or
7. Failed to report an accident or equipment failure as required by the building subcode and N.J.A.C. 5:23-12.11.

5:23-12A.3 Qualified elevator device inspector

(a) A candidate for certification as a qualified elevator device inspector for the inspection and testing of elevator devices enrolled under this subchapter shall pay a nonrefundable fee of \$65.00 and shall meet the following competence and experience requirements:

1. Seven years of experience consisting of one or a combination of the following:
 - i. Experience in construction, design, or supervision as a journeyman in a skilled trade currently regulated by the elevator subcode;
 - ii. Experience as an elevator inspector; or
 - iii. Experience as a construction contractor in a field of construction currently regulated by the elevator subcode; and
2. Demonstration of competence by successful completion of one of the following:
 - i. Successful completion of the examination module 6B-Elevator General of the National Certification Program for Construction Code Inspectors administered by the Chauncy Group, a subsidiary of the Educational Testing Service for the Department; or
 - ii. Possession of a current Qualified Elevator Inspector (QEI) certificate issued pursuant to ASME QEI-1-1993.

(b) The certificate shall be renewed every three years upon the submission of a renewal application, payment of a renewal fee of \$65.00 and submission of documentation of continuing education as follows:

1. Documentation of having completed 1.5 Continuing Education Units (CEUs) in a related technical subject area, as approved by the Bureau of Code Services, within the three-year period preceding the date of application. One CEU equals 10 contact hours;
2. Annual submission of a current QEI certificate; or
3. Submission of equivalent certification approved by the Bureau of Code Services.

(c) A qualified elevator device inspector, when employed by a qualified elevator device inspection firm, shall perform, and certify by signature, the inspection and tests required by this subchapter. The qualified inspector shall not inspect his or her own work; however, the qualified elevator device inspector may perform work as required under the contract of full service needs on the device he or she is inspecting at the time of the inspection and test, provided that work does not require more than one person. The maintenance and repair of a contracted device that is required at any other time under a contract of full service needs shall be performed by another individual, and not by the certifying inspector.