

NEW JERSEY STATE LIBRARY



3 3009 00555 9093

STATE
Department of Health
OF THE
State of New Jersey

RULES AND REGULATIONS FOR THE
PREPARATION AND SUBMISSION OF
DESIGNS FOR SEWER SYSTEMS, SEW-
AGE AND INDUSTRIAL WASTE TREAT-
MENT PLANTS AND WATER SUPPLIES
AND WATER TREATMENT PLANTS

C. 2

TRENTON, NEW JERSEY

1958

RULES AND REGULATIONS

The State Department of Health of the State of New Jersey, pursuant to the authority vested in it by Chapter 177, Laws of 1947, as amended by Chapter 444, Laws of 1948, hereby establishes the following rules and regulations for employment in the administration of R. S. 58:12-1 et seq., 58:11-2, 58:11-3, 58:11-10 and 58:10-17. All prior rules and regulations in these matters adopted on various dates by the Department of Health of the State of New Jersey are hereby rescinded.

STATE DEPARTMENT OF HEALTH OF THE STATE OF NEW JERSEY

DANIEL BERGSMAN, M.D., M.P.H.
State Commissioner of Health

Filed with the Secretary of State: April 1, 1958.

Effective Date: April 25, 1958.

NJ/KAB
14/551
1958

CONTENTS

Chapter	Pages
1. Instructions	5
2. General Requirements	5
3. Sewerage—General	5-8
4. Sewers—Specific	8-10
5. Pumping Stations	10-11
6. Treatment Methods Required	11
7. Treatment Plants	11-13
8. Treatment Plant Design Basis	13-14
9. Screening	14-15
10. Grit Chambers	15
11. Settling Tanks	15-17
12. Anaerobic Sludge Digestion and Sludge Disposal	17-21
13. Chemical Coagulation	21
14. Trickling Filters	22-23
15. Activated Sludge	24-26
16. Contact Aeration	26-28
17. Intermittent Sand Filters	28-30
18. Disinfection	30
19. Other Sewage Treatment Processes	31
20. Water, General	31-33
21. Well Supplies	33
22. Water Treatment Plants	33-35
23. Water Storage	36
24. Fluoridation	36

CHAPTER 1—INSTRUCTIONS

1.1. These Rules and Regulations are minimum general and specific requirements. They are intended to apply to the usual, not the exceptional conditions. They are subject to amendment and the State Commissioner of Health reserves the authority to specify more or less stringent requirements in any case as in his judgment may be in the interest of the public health.

1.2. Applicants and/or engineers are advised to confer with the Department's engineers before proceeding with a design, and, in general it is advisable to submit a preliminary plan and report before designing in detail.

CHAPTER 2—GENERAL REQUIREMENTS

2.1. *Applications*

(a) Applications for the approval of plans and specifications shall be submitted on forms provided by the Department.

(b) Applications are to be signed by the proper municipal officials, or by the owner or owners, or by the proper official (with title) of the corporation; or, if signed by an authorized agent, shall be accompanied by a certified copy of the authorization.

(c) Applications by individuals or corporations shall be approved by the municipality whose water or sewerage works may be affected.

(d) Applications for the approval of plans for sewers which would discharge to a sewerage facility not owned by the applicant shall be endorsed by the owners of the affected sewerage facility.

(e) Applications by newly constituted private utilities shall be approved by the local governing body of the municipality in which the utility is located. Such approval shall constitute a municipal franchise for the purpose of these regulations. Permits will be withheld from private utilities until they have been incorporated and until the utility has submitted written evidence that the municipal franchise has been approved by the State Public Utilities Commission.

2.2. *Engineering Data to be Submitted*

Engineer's Report—1 copy.

Detailed plans and specifications—2 sets.

"As built" plans—1 set. ("As built" plans are required only when construction is substantially different from approved plans).

CHAPTER 3—SEWERAGE—GENERAL

3.1. *Sewer System on Separate Plan*

The Department will approve plans for proposed new sewerage systems or extensions only when designed upon the separate system plan, in which all water from roofs, cellars, streets, and other areas is to be excluded; except that extensions of "combined" systems may be approved when it is demonstrated conclusively that there is no practical alternative.

3.2. *Information Required*

- (a) A general map of entire project.
- (b) An area map covering probable future tributary areas for sewer system projects.
- (c) Profiles of all sewers proposed.
- (d) Details of construction of manholes, flush tanks, siphons, and other sewer appurtenances.
- (e) Specifications for all proposed construction.
- (f) General and detail plans for treatment plants.
- (g) A comprehensive report upon the proposed system by the designing or consulting engineer.
- (h) Estimate of costs.

3.3. *General and Area Maps*

(a) *Details*

(1) Plans shall be drawn to standard scales and shall show the entire area of the project. In case there is more than one sheet all shall be bound together and a small index map supplied, showing by number the area and districts covered by the various sheets. A general plan shall accompany each application for a new sewer system or any extension or modification of any existing sewer system, unless such general plan has already been submitted.

(2) The plan shall show all existing or proposed streets and the surface elevations at all street intersections where sewer lines are proposed.

(3) Plans also shall show clearly the location of all existing sewers, either "separate" or "combined" (so indicated), the location of the treatment works, and the location of existing and proposed sewer outlets or overflows, the true or the magnetic meridian, the boundary lines, title, date and scale. The elevations of the highest known freshets or tides at the outlets and site of the treatment plant shall be given. Any area from which sewage is to be pumped shall be indicated clearly.

(b) *Symbols*

Sewers to be built at present and sewers to be constructed later shall be shown by standard conventions. Existing sanitary sewers and combined sewers shall be shown by special designations. All topographical symbols and conventions used are to be the same as those of the United States Geological Survey.

(c) *Elevations*

Elevations of the surfaces of streets shall be placed outside the street lines opposite their respective positions in the street. The elevations of sewer inverts shall be shown at street intersections, ends of lines, and wherever a change of grades occurs. The elevations of sewers shall be written close to the point to which they refer, parallel with the sewer lines and between the street lines. The elevations of the surfaces shall be shown to the nearest 0.1 foot; those of the sewer inverts to the nearest 0.01 foot.

(d) *Distances, Grades and Sizes*

The horizontal distance and stationing between manholes, grades in per cent and sewer sizes shall be shown

on all proposed sewer lines. Arrows shall be drawn to indicate the direction of flow.

(e) *Sewer Appurtenances*

All sewer appurtenances, such as manholes, flush tanks, siphons, pumping stations, etc., shall be designated on the plans by suitable symbols and referenced by a legend near the title.

3.4. *Profiles*

(a) Profiles shall indicate all manholes (manhole numbers), flush tanks, siphons, pumping stations, and, in the case of stream crossings, elevations of stream beds and normal flow lines. Figures showing the sizes and gradients of sewers; surface elevations, sewer inverts, etc., shall be shown at or between each manhole.

(b) Profiles of sewer lines shall be drawn to such standard scales as to show clearly the structural features of the sewers. Scales shall be shown upon each sheet.

(c) On each sheet of profiles shall be given, under the title, an index of the streets appearing on that sheet. Profile sheets shall be numbered consecutively.

3.5. *Details of Construction of Manholes, etc.*

(a) Detail drawings of all sewer appurtenances, such as manholes, flush tanks, inspection chambers, siphons, pumping stations, etc., shall accompany the general sewer plans.

(b) The detail plans shall be drawn to standard scales so as to show clearly the nature of the design and all details.

3.6. *Specifications*

(a) Complete specifications shall accompany the plans.

(b) Specifications previously approved and filed may be omitted for sewer extensions, provided that reference (including date of approval) to the filed specifications is made on the application blank.

3.7. *General and Detail Plans for Treatment Plants*

(a) The plans for treatment plants shall include a general plan showing the boundaries of reserve area for future extensions and all buildings within 500 feet of plant property; and, detail plans of the various units and structures which comprise a plant.

(b) The detail plans shall show longitudinal and transverse sections sufficient to explain the construction of each unit. They also shall show the distribution and drainage systems, details of automatic devices, depths of stone, gravel or sand used as filtering material, hydraulic profile through plant units, and all other information required for the clear understanding of the plans.

3.8. *The Engineer's Report*

A report by the designing or consulting engineer shall accompany all plans, except those for sewer extensions, and shall give all data upon which the design is based including:

Required Information Concerning Sewer Systems

(a) The nature and extent of the area which it is proposed to include within the present system of sewerage, and of the area which it is planned shall ultimately drain into the system, including sections not within the municipal limits.

(b) The population to be served, both present and estimated for at least twenty-five years hence, with computations and curves.

(c) The estimated per capita daily flow of sewage to be cared for.

(d) The total and per capita water consumption of the district to be served at the present time, if available.

(e) The allowance made for infiltration in the sewers.

(f) The estimated daily flow of sewage, including infiltration.

(g) The character of the sewage (whether domestic or industrial wastes or process waters, and in case of the latter, the nature and approximate quantity of the same stated in specific terms); also a breakdown of all quantities.

(h) That portion of the system to be built at the present time.

(i) The minimum grades of sewers for each size used.

(j) Distance of sewer outlet from shore and maximum and minimum depths of water at outlet.

Information Concerning Treatment Plants

(a) The character of the sewage to be treated and the method of treatment proposed.

(b) A description of the units of plants, with rates and capacities.

(c) The nature of the body of water into which the effluent will discharge, including the run-off during dry weather.

(d) The final disposal of sludge and screenings.

(e) The results expected from the treatment processes.

CHAPTER 4—SEWERS—SPECIFIC**4.1. Capacity and Design Period**

(a) All sanitary sewers, including outfalls, shall be designed to carry at least four times the estimated average flow when flowing full.

(b) The design period for the estimated flow shall be at least twenty-five years; longer periods are recommended for major projects.

(c) For sewers other than circular in cross sections, the data to be submitted shall include the geometrical shape, dimensions and hydraulic characteristics of the proposed sewer.

4.2. Materials, Minimum Grades and Velocity of Flow

(a) Sewers shall be designed with such hydraulic slope as will give a mean velocity of not less than two

feet per second when flowing full or half full, based on Kutter's or Manning's formula with $n = 0.013$ for glazed tile, concrete, brick, segmental block or cast-iron; and, with $n = 0.011$ for asbestos cement pipe or enamel lined pipe, and shall comply with the following requirements:

Pipe Diameter	Fall in feet per 100 feet of sewer	
	$n = 0.013$	$n = 0.011$
8"	.40	.24
10"	.29	.18
12"	.22	.14
14"	.17	.11
15"	.16	.10
16"	.14	.09
18"	.12	.08
20"	.10	.07
21"	.095	.063
24"	.080	.060
27"	.067	.046
30"	.058	.040
36"	.046	.031

(b) Grades greater than 10 per cent are not recommended in sewer construction.

(c) Sewers crossing streams or to be located within ten (10) feet of a stream embankment or otherwise where unusual strength is indicated, shall be of cast-iron, unless written permission to the contrary is granted by the Department.

(d) When grades lower than those specified above are proposed, an explanation and reasons for the use of such grades shall be included in the engineer's report.

4.3. *Inverted Siphons*

Inverted siphons shall be in duplicate and provision shall be made for flushing them. A velocity of 3.0 feet per second should be maintained and flow control gates in chambers should be provided.

4.4. *Joints*

(a) Joints in sewer lines constructed of vitrified clay shall be primed and formed by a fibrous packing and bitumastic compound poured hot. Standard manufactured joints for vitrified clay pipe and asbestos cement pipe may be used. Joints for cast-iron pipes should be made by fibre packing and lead or approved lead substitute poured hot. Prefabricated joints are also acceptable.

4.5. *Manholes*

(a) Manholes shall be provided at the ends of each sewer line and at intersections and at all changes in grade or alignment.

(b) Distances between manholes shall not exceed 500 feet for sizes 24 inches or less.

(c) A drop pipe shall be provided for lateral sewers entering manholes above the manhole invert wherever the difference in elevation is two feet or more.

4.6. *Outfalls*

Ocean outfalls at bathing beaches along the Atlantic coast shall be at least 1,000 feet in length from the mean low water mark. Manholes are required on the shore end of all gravity outfalls.

CHAPTER 5—PUMPING STATIONS

5.1. *General*

(a) Raw sewage shall be screened before pumping unless equipment capable of handling large sewage solids is used.

(b) When pumping stations are located at sewage treatment plants the design shall provide for stage pumping, preferably by the use of variable-speed pumps, so as to eliminate, as far as practical, surges of flow through the treatment plants.

(c) An auxiliary source of power shall be provided for electrically driven pumps.

(d) Automatic sound alarms, operating independently of the station power, shall be installed to give warning of high water, power failure, or breakdown. Such alarm system shall extend by wire to the police station or other location where competent assistance can be obtained in emergency.

(e) Adequate light, ventilation, and a supply of fresh water shall be provided at all pumping stations.

5.2. *Pumps*

(a) At least two pumps, each designed to handle total peak flows, shall be provided. If more than two pumps are provided their capacities shall be such that, upon failure of the largest pump, the others will handle the peak flows. When ejectors are provided as the method of raising sewage; two compressor units are required, and shall be so interconnected that the duplicate unit will commence operation in the event of failure of the one in use.

(b) Pumps shall be installed in dry wells; submerged pumps will not be permitted.

(c) Pump specifications shall include standard repair tools and accessories.

(d) Force main velocities shall not be less than 2 ft./second at normal pumping rates.

5.3. *Dry Wells and Wet Wells*

(a) Dry and wet wells shall be provided with adequate means of entrance, ventilation, and drainage.

(b) Dry wells shall provide sufficient space for accessibility for the repair and removal of pumps.

(c) The capacity of a wet well should not exceed ten minutes in flow at the average dry weather rate.

(d) The floors of wet wells shall slope toward pump suction to prevent solids accumulation.

5.4. *Electrical Equipment*

(a) Electric motors shall be so located as to be protected from flooding.

(b) Electric motors and electrical power equipment should not be installed in subsurface chambers; where installation in such a location is necessary the motors and equipment shall be of the explosion-proof and damp-proof type.

(c) All electrical equipment and work shall comply with Fire Underwriters' regulations for the location involved.

CHAPTER 6—TREATMENT METHODS REQUIRED

6.1. *General*

(a) Treatment shall be provided for all domestic sewage before discharge to waters of the State. The minimum degree of sewage or industrial waste treatment shall be as specified by the Department. Effective sedimentation is the minimum treatment method recognized by the Department. The Department does not recognize fine screens, magnetite filters or so-called "rapid sand filters" as treatment methods.

(b) The type of treatment in addition to its adequacy shall take into consideration the topography of the plant site, operating costs, effects of industrial wastes, and the probable quality of supervision the plant will receive.

6.2. *New Treatment Methods*

(a) Designs for new treatment methods or for methods not included in these rules and regulations shall be accompanied by detailed data on full scale tests under competent supervision.

(b) The Department may approve such installations as experimental if the applicant is fully aware of the experimental nature of the proposal.

(c) The Department reserves the right to disapprove new treatment methods if in its opinion such denial is in the interest of the public health.

6.3. *Basis of Design of Industrial Waste Treatment Plants*

(a) No specific design criteria for industrial waste treatment plants are included due to the diversity and complexity of the subject. However, the general requirements relative to submission of detailed plans, specifications and engineer's report shall apply.

(b) Each industrial waste treatment plant will be considered on its individual merits and in relation to the over-all stream pollution control program of the New Jersey State Department of Health. It is recommended that Department engineers be consulted prior to preparation of the final design.

CHAPTER 7—TREATMENT PLANTS

7.1. *General*

Treatment plants shall be located as far from existing structures as practical, preferably not closer than 500 ft. from any dwelling. They shall be placed above maximum flood levels and be accessible by an adequate road. The plant layout shall be designed with a view toward ease of operation, safety and accessibility.

7.2. *Operating Building*

A suitable operating building shall be provided. The building shall be heated, ventilated and lighted. Office space, workshop, laboratory, and storage should be provided.

7.3. *Sanitary Facilities*

Facilities including drinking water, toilet and lavatory shall be provided. A shower is recommended.

7.4. *Laboratory Equipment*

All plants shall be equipped with adequate laboratory equipment commensurate with the degree of treatment. Minimum equipment shall include:

3—Imhoff cones.

Comparator with pH and chlorine discs.

12—300 ml bottles for relative stability tests.

7.5. *Maintenance Equipment*

Adequate equipment shall be furnished for plant operation to include squeegees, skimmer, sludge sounder, hoses and tools for mechanical work and for ground maintenance. A portable pump shall be provided.

7.6. *Water Supply*

(a) An adequate supply of water under pressure shall be installed.

(b) Taps supplying nonpotable water shall be clearly labeled "Unfit for Drinking."

7.7. *Grading*

Treatment plant sites shall be graded, and drains installed to prevent wash into tanks, basins or filters and to prevent erosion. Landscaping is recommended.

7.8. *Safety Features*

Plants shall be equipped with necessary safety features to include railings around tanks, and around the curtilage of the property, handrails at stairs or steps, flame traps at all gas outlets, and adequate ventilation of enclosures. Warning signs shall be posted in hazardous locations. A First Aid Kit shall be provided.

7.9. *Emergency Power*

Dual sources of power shall be provided where temporary discharge of inadequately treated sewage would endanger public health or cause serious damage.

7.10. *Alarm System*

(a) An alarm system shall be provided for all treatment plants wherein 24-hour supervision is not provided and wherein discharge of inadequately treated sewage would endanger public health or cause serious damage.

(b) The alarm system shall extend by wire to the police station or other location where competent assistance can be obtained in emergency.

7.11. *Electrical Work*

All electrical work shall conform to the National Electric Code. Fixtures in hazardous locations shall be of the explosion-proof type.

7.12. *Measuring and Recording*

Means for continuous measuring, indicating and recording of the sewage flows shall be installed.

7.13. *By-Passes*

(a) Direct plant by-passes which allow raw sewage to be discharged directly to a watercourse shall not be installed except when such are necessary to protect plant equipment, and only by special permission of the Department. Provision for the sealing of such by-passes shall be made.

(b) Unit by-passes shall be provided to enable any of the treatment units to be dewatered. This requirement shall not apply if two or more duplicate treatment units are installed, and where it is possible to divert the entire flow of incoming sewage through any of them.

7.14. *Dewatering*

Means shall be provided for dewatering all treatment units for inspection and maintenance.

CHAPTER 8—TREATMENT PLANT DESIGN BASIS

8.1. *Design Period*

Treatment units shall be designed for population and sewage flow anticipated not less than ten (10) years after completion of construction. A longer design period should be used where future economies are indicated.

8.2. *Design Flow*

(a) Sewage treatment plants for a new sewer system shall be designed for an average domestic flow, including infiltration, of not less than 100 gallons per capita per 24-hour period, plus industrial waste volume. The total flow so obtained shall be defined as the Design Flow, and is hereinafter so referred to in these regulations.

(b) Where a sewer system is already in existence, actual gauging shall be used as a basis, plus an allowance for future increase in sewage flow.

8.3. *Design Loading*

(a) The design of the various units of a sewage treatment plant shall be based on the design flow as defined in 8.2(a), except that when total daily flow is to be received at the plant in a lesser period than 24 hours, units shall be designed on a basis of the actual average hourly flow.

(b) Unless accurate data justifying a lesser design are submitted, the hydraulic design of piping, channels, flumes, and pumps shall be based on not less than 250 per cent of design flow.

(c) Where recirculation is employed, additional flow from this source shall be added.

(d) Organic loading shall be based upon a minimum 5-day B.O.D. content of 250 p.p.m. for domestic sewage, to which shall be added B.O.D. values for industrial wastes.

CHAPTER 9—SCREENING

9.1. *General*

(a) All sewage treatment plants shall be provided with means for screening or comminuting coarse material in the sewage.

(b) Operation of mechanically cleaned devices should be continuous or automatically controlled.

9.2. *Bar Screens*

(a) Bars of nonmechanical screens preceding treatment plants shall be spaced so that the maximum clearance between bars is not greater than $1\frac{1}{2}$ inches and not less than 1 inch.

(b) Clear openings for mechanically cleaned screens may be as small as $\frac{3}{8}$ of an inch.

(c) Coarse screens preceding mechanically cleaned screens or comminutors may be greater than given under (a).

(d) At sewage pumping stations, bar screens shall be at least 1 inch smaller than the solid size which can be handled by the pump.

(e) Motors shall be of the type suitable for operation in a damp atmosphere if placed below ground.

(f) The screening chamber shall be designed to provide a velocity of not less than two (2) feet per second and not more than three (3) feet per second.

(h) Hand-cleaned screens, except for emergency use, shall be inclined from 30° to 45° from horizontal.

9.3. *Screenings*

(a) Adequate facilities shall be provided for removal, handling and disposal of screenings. A platform shall be provided at the top of hand-raked screens. Satisfactory containers shall be provided for removal of screenings.

(b) Means shall be provided for drainage of screenings, both on the platform and in containers.

(c) Where screen chambers are located substantially below grade, a suitable hoist shall be provided.

(d) Screen chambers shall be adequately ventilated. Where required forced draft fans shall be installed.

9.4. *Comminution*

(a) Comminuting devices shall have slots not less than $\frac{1}{4}$ inch wide and be designed to cut or shred material below the surface of the sewage. The capacity of each unit shall be adequate to handle peak flows.

- (b) A by-pass screen shall be provided.
- (c) Gates shall be provided to isolate each comminutor channel, and provision shall be made for the removal of mechanisms for repair and maintenance.

CHAPTER 10—GRIT CHAMBERS

10.1. *General*

(a) Grit chambers shall be provided at all treatment plants receiving combined sewage.

(b) A grit chamber should be provided at those plants receiving separate sanitary wastes.

(c) Grit chambers receiving combined sewage shall have duplicate hand-cleaned units or a single mechanically cleaned unit with by-pass. Mechanically cleaned chambers are recommended. A single hand-cleaned chamber with by-pass is acceptable for plants receiving separate sanitary wastes.

10.2. *Design*

(a) Grit chamber channels and flumes shall be designed to produce velocities of not less than 0.5 foot per second and not greater than 1.0 foot per second. Detention shall be adequate to deposit grit coarser than 0.20 millimeters.

(b) All mechanically cleaned grit chambers shall be provided with means for washing the grit either below the surface of the sewage or directly above the flow.

(c) Mechanically equipped chambers shall be equipped with screw or bucket elevators to remove grit from channels to ground level or to a hoist. Containers shall be provided for hand-cleaned chambers, and means of hoisting containers to a truck or other conveyance.

CHAPTER 11—SETTLING TANKS

11.1. *General*

(a) Tanks shall be provided with two or more independent compartments.

(b) Channels shall be designed to maintain a velocity of 1 foot per second at 50 per cent of design flow.

(c) Baffling shall be provided to dissipate inlet velocity and diffuse flow equally across the cross section of the tank.

Baffles shall also be provided to retain scum in primary tanks. Scum troughs are recommended, preferably of the tilting type. Scum troughs shall not be used as the sole means of effluent baffling.

(d) Weirs shall be adjustable.

(e) The minimum slope of the side walls of sludge hoppers shall be 1.7 vertical to 1 horizontal.

(f) Means shall be provided for dewatering all tanks.

(g) Upward flow type settling tanks are not recommended.

11.2. *Nonmechanical Settling Tanks*

The use of nonmechanical settling tanks is not recommended except for installations too small to warrant use of mechanical sludge collectors.

11.3. *Single Story Settling Tanks (without separate sludge digestion)*

Single story settling tanks without separate sludge digestion tanks will not be permitted except by special permission of the Department. When this method of treatment shall have been approved by the Department the following shall apply:

- (a) Two or more units shall be provided.
- (b) The capacity of settling tank units, exclusive of sludge capacities, shall be at least eight (8) hours, based on design flow. The total sludge capacities of all units shall be two (2) cubic feet per capita.
- (c) The depth below the water line shall be not less than six (6) feet, nor more than twelve (12) feet.
- (d) Scum boards shall be provided at inlet and outlet ends of each unit. The design of inlets and outlets should provide for uniform distribution.

11.4. *Imhoff Tanks*

- (a) The detention period shall not be less than two and one-half hours based on design flow.
- (b) Surface settling rates shall not exceed 600 gallons per square foot per day at design flow.
- (c) Bottom slopes of flow-through chamber shall not be less than 1.4 vertical to 1.0 horizontal, and shall be smooth.
- (d) The slot opening shall be at least eight (8) inches wide measured on the sloping bottom.
- (e) The slot overlap shall be eight (8) inches minimum measured on a horizontal plane.
- (f) Tanks shall be provided with at least 18 inches of freeboard. The water level shall not be more than 24 inches below the walkways or operating level.
- (g) Gas vents shall not be less than 18 inches wide and not less than 20 per cent of the total superficial tank area.
- (h) Means shall be provided for reversal of flow.
- (i) The inlets and outlets shall be so designed as to equally distribute the sewage flow among and through the tanks.

11.5. *Mechanically Cleaned Settling Tanks*

- (a) Primary tanks shall have a surface settling rate not exceeding 600 gallons per square foot per day for the design flow, and a minimum water depth of six (6) feet and a maximum depth of ten (10) feet.
- (b) Settling tanks shall be so designed as to prevent septicity.
- (c) Mechanical means shall be provided for collecting sludge and scum, except in very small installations.

(d) Inlets shall be designed to dissipate inlet velocity promptly, to diffuse the flow, and to prevent short-circuiting.

(e) Adjustable outlet weirs shall be provided.

(f) Minimum length of flow from inlet baffles to outlet shall be ten (10) feet.

(g) Final settling tanks shall be designed according to the following:

<i>Type Treatment</i>	<i>Depth (feet)</i>	<i>Maximum Surface Settling Rate</i>	<i>Minimum Detention Period</i>
Standard Rate			
Trickling Filter	6 to 7	1,000 gals./s.f./day	1.0 hrs.
High Rate			
Trickling Filter	8 to 9	800	1.8 "
Activated Sludge (2.0 m.g.d. and less)	8 to 9	800	1.8 "
Activated Sludge (Over 2.0 m.g.d.)	10 to 11	1,000	1.8 "
Contact Aeration (Multisurface oxidation)	10 to 13	1,000	1.5 "

11.6. *Other Types*

The use of combined units employing settling will be given consideration only where full-scale units have been in operation for a sufficient period of time to provide data covering efficiency and operating costs and to assure that mechanical and maintenance problems have been worked out. Experimental units will be approved only when the municipality or industry has been fully advised as to the experimental nature and is agreeable to its installation.

CHAPTER 12—ANAEROBIC SLUDGE DIGESTION AND SLUDGE DISPOSAL

12.1. *General*

(a) Except as provided in article 7.8 the Department does not examine plans as to fire and explosive hazards, heat controlling equipment, or safety devices.

(b) Supernatant liquor should be returned to the raw sewage except at activated sludge plants, and all plants utilizing air as a method of biological treatment.

(c) The minimum diameter of all sludge pipes shall be eight (8) inches for gravity flow and six (6) inches for sludge pumping, unless written permission to the contrary is granted by the Department.

(d) A fresh-water hydrant near sludge digestion tanks is recommended.

12.2. *Imhoff Tanks*

(a) The upper limit for computing sludge storage shall be the plane 18" below the tank slot. Storage for

separate systems shall not be less than three (3) cubic feet per capita and not less than four (4) cubic feet per capita for combined systems. Additional allowance shall be made for secondary sludge if resettled in the Imhoff tank.

(b) A net static head of six (6) feet shall be provided for gravity withdrawal, and two (2) feet if sludge is pumped. Valves shall be provided for each hopper and these shall be placed outside of the tank for accessibility. Entrance to sludge withdrawal lines shall be designed to prevent clogging and pipes shall be sloped so that they will drain.

12.3. *Separate Sludge Digestion Tanks*

General

(a) Two or more units shall be provided except where a lagoon or open tank is available for emergency use, and where piping or pumps are available for the use of emergency facilities.

(b) The proportion of depth to area shall be such as to allow for the formation of a reasonable depth of supernatant liquor.

(c) Bottom slope of tanks shall not be less than three (3) inches per foot toward withdrawal piping unless tank is equipped with sludge collection mechanism.

(d) At least two access manholes of adequate size shall be provided in the top of digester in addition to the gas dome.

(e) Inlet piping of rectangular tanks shall be at the opposite end from overflow piping. In circular tanks the raw sludge inlet shall be at a point at least equal to the radius of the tank from overflow or supernatant drawoffs. In the case of multiple tanks, provision shall be made to direct raw sludge to each tank.

(f) An emergency overflow shall be provided. Provision shall be made for sampling of supernatant, and for the removal of supernatant slowly over an extended period.

(g) Means shall be provided for sampling of digested sludge. Digested sludge withdrawal piping shall extend from the center and bottom of circular tanks and from the effluent end of rectangular tanks. Means shall be provided for backflushing digested sludge withdrawal piping. Adequate transfer piping shall be provided. An access manhole in the side wall of the tank is recommended.

(h) Provision shall be made for circulation of sludge within the digester.

12.4. *Capacity*

Separate sludge digestion capacity shall be as follows:

<i>Type of Plant</i>	<i>Cubic Feet per Capita</i>	
	<i>Heated</i>	<i>Unheated</i>
Primary	2 to 3	4 to 6
Primary plus standard filter....	2.5 to 3	4 to 6
Primary plus high rate filter ..	3 to 4	5 to 7
Contact aeration (multisurface oxidation)	3 to 4	5 to 7
Chemical coagulation	4 to 5	6 to 8
Activated sludge	4 to 6	8 to 10

The capacities may be increased if industrial wastes are to be considered, and may be reduced if the sludge is dewatered. Volumes should be computed on the basis of the bottom sloping up 30 degrees from the horizontal withdrawal piping unless mechanical sludge collection is employed. Additional capacity shall be provided where garbage solids are to be included.

12.5. Gas Collection

(a) Waste gas burners shall be provided for excess gas in plants designed for a population of 2,000 or larger. These shall be placed at least 25 feet away from structures if placed at ground level, or may be located on roofs of buildings provided they are sufficiently remote from digestion tanks. Waste gas burners shall be equipped with pilot lights and means for igniting manually. In plants designed for a lesser population than 2,000, adequate deodorizing equipment shall be provided at points of gas release.

(b) All enclosures containing gas piping or apparatus shall be equipped with forced draft ventilation either of the wind-driven or motor-operated type. If of the motor type the design shall be such that the motor does not come in contact with gases.

(c) Boilers utilizing gas shall be located in a separate enclosure having adequate means of ventilation.

12.6. Digester Heating

(a) The use of hot water coils as a method of heating is not recommended unless means are provided for removing and maintaining the coils. Coils if used shall be of wrought or cast iron. Preference should be given to means of external heating by means of a heat exchanger.

Heating capacity shall be adequate to maintain sludge at 85° F. to 95° F. at all times.

(b) Thermometers shall be provided to show temperatures of sludge in the digester, and the sludge going to and from the heat exchanger. Thermometers shall also be provided to show the temperature of the water going to and from the heating coils or heat exchanger.

(c) An auxiliary fuel shall be provided, such as oil or commercial gas.

12.7. Sludge Pumps

(a) A minimum of two duplicate sludge pumps shall be provided.

(b) The capacity of each pump for handling raw sludge shall be such as to remove sludge from hoppers of settling or concentration tanks in not less than one hour nor more than two hours. Pump capacity shall be adjustable.

(c) Plunger pumps are preferred for handling raw sludge.

(d) A minimum positive head of 24 inches shall be provided at the suction side of centrifugal pumps and is desirable for all types of pumps. Maximum suction lift of plunger pumps shall be 10 feet.

(e) Unless sampling facilities are otherwise provided, quick opening valves shall be installed at sludge pumps. The size of valve and piping should be at least 1 inch.

(f) Pressure gauges shall be provided on the discharge line of sludge pumps to denote pumping and to indicate unusual discharge heads due to clogging.

12.8. Sludge Dewatering

Drying Beds

(a) The following table of requisite areas applies to domestic sewage, the sludge of which is digested by anaerobic method. Where industrial wastes are to be handled, a suitable increase should be made.

Type of Treatment	Area in sq. ft./cap.	
	Open Beds	Covered Beds
Primary with Digestion	1.50	} 60% area of open beds
Standard Rate Filter	1.75	
High Rate Filter	1.75	
Contact Aeration (multisurface oxidation)	1.75	
Activated Sludge	2.00	
Chemical Precipitation	2.25	

(b) Design

(1) Not less than two beds or compartments shall be provided.

(2) Gravel shall be 12 inches deep with top at least 6 inches above underdrains. It shall be graded, with the top layer consisting of at least 3 inches of gravel or crushed stone $\frac{1}{8}$ to $\frac{1}{4}$ inch in size.

(3) Depth of sand shall be at least 6 inches and have an effective size of 0.30 to 0.50 millimeters and a uniformity coefficient not greater than 5.0.

(4) Underdrains shall be of bell and spigot vitrified clay tile pipe, porous tile or perforated pipe. Lateral drains shall be at least 4 inches in diameter laid with open joints. Burlap or similar material shall be provided around joints. They shall be spaced not more than 8 feet apart o.c.

(5) Walls shall be watertight and extend 15 to 18 inches above and at least 12 inches below the sand surface. Walls shall be at least 6 inches above the surrounding ground elevation to prevent soil from washing on to beds.

(6) Means shall be provided to facilitate removal of dried sludge from drying beds.

(7) Influent piping shall terminate at least 12 inches above the sand surface and be arranged to drain to drying beds. Splash slabs shall be provided.

(8) Sludge bed effluents shall be treated.

12.9. Shallow Lagoons

The use of lagoons for the drying of digested sludge is permissible provided:

(a) The soil is reasonably porous and the bottom of the lagoon is at least 18 inches above the maximum ground water plane.

(b) The area provided shall be at least double that specified for open drying beds.

12.10. *Vacuum Filtration*

Vacuum filters shall be in duplicate unless storage for thirty (30) days' accumulation of sludge is provided. Duplicate installations shall include duplicate appurtenances, including conditioning equipment, conveyors, etc.

Capacity shall be sufficient to process the sludge so that there will be no accumulation from day to day. The engineer's report shall give complete data upon filter capacity, sludge volume to be handled, conditioning method and equipment, chemical storage and disposal of sludge cake.

CHAPTER 13—CHEMICAL COAGULATION

13.1. *Consideration of Method*

This method of sewage treatment shall be considered as a degree of treatment intermediate between those commonly known as sedimentation, and sedimentation plus oxidation. In no case shall it be considered as a substitute for oxidation.

13.2. *Requirements*

(a) Coagulants shall be applied to the sewage in liquid form proportional to the sewage flow.

(b) A chamber or mixing tank for the rapid and thorough mixing of the sewage and coagulant(s) shall be provided. The detention period shall be not less than one (1) minute based on design flow. A means for thorough mixing consisting of power-driven paddles, propellers, or diffused air, shall be provided.

(c) Two or more flocculation tanks providing a combined detention period of between twenty (20) and thirty (30) minutes shall be provided. Diffused air or paddles shall provide continuous agitation of the full content of the tanks. Slow rotary motion should be provided for in the flocculation tanks. Independent controls for each tank shall be provided.

(d) Sedimentation Tanks—same as 11.5.

(e) Sludge Digestion—same as 12.4 and 12.8.

(f) Drains shall be provided to dewater all tanks.

13.3. *Equipment*

(a) Adequate automatic control of pumps shall be provided.

(b) An auxiliary source of power for the electrically driven mechanism shall be provided.

(c) Devices shall be installed to give warning of breakdown of mechanical equipment.

(d) The automatic control of apparatus feeding chemicals for coagulation shall include equipment to provide variation in chemical dosage with variation in sewage flow.

(e) Detailed information, including capacity, construction and operation of the proposed equipment, shall be submitted.

CHAPTER 14—TRICKLING FILTERS

14.1. *General*

(a) *Applicability*—Trickling filters of the "standard rate" or "high rate" type may be used for the treatment of sewage and industrial wastes amenable to purification by biological processes.

(b) Filters shall be preceded by effective preliminary treatment.

(c) Filters shall be followed by duplicate, individually controlled, and mechanically cleaned settling tanks.

14.2. *Design*

(a) Reduction in 5-day B.O.D. in primary settling tanks shall be considered as not exceeding 35% for filter design criteria.

(b) When the average 5-day B.O.D. of the raw sewage exceeds 325 p.p.m., trickling filter treatment is not recommended unless two stages of filters with or without intermediate sedimentation are provided, or unless the primary sedimentation is supplemented by an additional method of treatment such as chemical coagulation.

(c) The sewage shall be distributed as uniformly as possible so that at least 95% of the surface area receives sewage directly.

(d) Distribution devices may be actuated by twin syphons, pumps, or by gravity discharge from preceding treatment plant units.

(e) The filter medium shall be crushed trap rock having uniform physical properties. The upper 18 inches shall have a loss, by the 20 cycle sodium sulphate test, of less than 10% and the balance shall pass the 15 cycle test. Percentage of wear shall not exceed 20 after 500 revolutions of the Los Angeles Rattler Test as determined by the current A.S.T.M. Standard, Designation No. C-131.

The medium shall be approximately cubical in shape, free from dust, clay, sand or fine material, and of a size to pass a four-inch screen and be retained on a two-inch screen. Material shall be screened or forked, if necessary, to remove fines and shall be so placed as to avoid breaking the underdrains.

(f) The underdrainage system shall cover the entire floor. Inlet openings into the underdrains shall have an unsubmerged gross combined area equal to at least 5% of the surface area of the filter.

Lateral underdrains shall have a minimum slope of one per cent. Main underdrain and effluent channels shall be designed to provide a velocity of not less than 2 feet per second.

The entire underdrainage system shall be designed to permit free passage of air, and be of such size that not more than 50 per cent of cross-sectional area will be submerged during operation of the filter at the maximum rate. Provision shall be made for flushing lateral underdrains from the main drain or a peripheral head channel.

14.3. *Standard Rate Filters*

(a) The volume of sewage to be treated by standard rate filters shall not exceed 14,400 gallons per day per thousand cubic feet (630,000 gallons per acre foot) of filtering medium, nor shall the average rate of organic loading exceed 15 lbs. of 5-day B.O.D. per thousand cubic feet (0.4 lbs. per cubic yard) per day.

(b) The average rate of application during dosing periods shall not exceed 22 gallons per thousand cubic feet of medium (950 gallons per acre foot) per minute. The time intervals between dosing cycles to the filter should generally not exceed five minutes at design flow.

(c) The minimum depth of filtering medium at any point in the filter, measured from the top of the underdrains to the surface of the medium, shall not be less than six (6) feet, and the maximum depth shall not exceed nine (9) feet.

(d) Temporary means for *Psychoda* fly control, such as provisions for backflooding and filter flushing, are desirable.

14.4. *High Rate Filters*

(a) Organic loading to high rate filters shall not exceed 67 lbs. of 5-day B.O.D. per thousand cubic feet (1.8 lbs. per cubic yard) of filter medium per day.

(b) The minimum depth of filtering medium at any point in the filter, measured from the top of the underdrains to the surface of the medium, shall not be less than five (5) feet.

(c) The filter retaining walls shall not extend more than three (3) inches above the filtering medium to prevent ice formation from interfering with free distributor movement.

(d) High rate trickling filters shall be equipped with rotary distributors. Flushing devices shall be provided at the outer end of each distributor arm.

(e) Provision shall be made for controlled recirculation to maintain a continuous application rate of not less than 230,000 gallons per thousand square feet (10 million gallons per acre), per day. Devices shall be provided to record flows to the filter, and of the recirculated effluent.

(f) The number and capacities of the recirculating pumps shall be such that the conditions of (d) and (e) of this regulation can be met if the largest pump for each point of return is out of service.

14.5. *Double Filtration*

Under conditions where treatment of unusually strong sewage is necessary and two-stage filtration is adopted, the intermediate settling tanks may be designed to provide a detention period of one hour based upon design flow.

CHAPTER 15—ACTIVATED SLUDGE

15.1. *General*

(a) *Applicability*—The activated sludge process may be used where the sewage entering the aeration tanks is amenable to biological treatment.

(b) Design data outlined herein are presumed to achieve a removal of 90 per cent or more of B.O.D. and suspended solids susceptible to treatment from sewage of normal characteristics, and do not apply where only partial removals are intended.

(c) Plans for plants contemplating abnormal concentrations of sewage, unusual aeration period, or special equipment or arrangements, will be reviewed on their merits and may be conditionally approved for construction upon presentation of appropriate supporting data demonstrating the efficacy of the design for specific project.

15.2. *Settling Tanks*

(a) A skimming tank, or equivalent, shall be provided for sewage which contains excessive oil or grease.

(b) The installation shall provide a minimum of two preliminary settling tanks having a total capacity to provide not more than one-hour detention period based upon design flow.

(c) Final settling tanks shall be provided in multiple units capable of independent operation, and shall be constructed to provide approximately a two-hour detention period based upon design flow.

(d) Mechanical means shall be provided for the collection and removal of sludge from all settling tanks.

(e) Upward flow settling tanks are not recommended, but if provided the vertical rise shall not exceed two inches per minute.

15.3. *Preaeration*

If the incoming sewage is very stale, preaeration of the presettled sewage is recommended before the admixture of returned sludge.

15.4. *Aeration Tanks*

(a) Multiple units, capable of independent operation, shall be provided for all installations.

(b) Total required detention period of aeration tanks, based upon 125 per cent of design flow, shall not be less than 6 hours. However, if provision is made for the reaeration of the returned sludge before admixture with the presettled sewage, a lesser detention period in the aeration tanks will be considered. In general, the greater the return sludge aeration period, the less the required mixed liquor detention period.

(c) Surface mechanical aeration alone will not be permitted.

(d) The dimensions and proportions of the independent units shall be such as to maintain the effective utilization of air and the prevention of unaerated sections.

(e) Liquid depths of not less than ten, nor more than fifteen feet, shall be provided.

(f) Means shall be provided to minimize the production of foam in the aeration tanks.

15.5. *Inlets and Outlets*

(a) All inlets and outlets shall be equipped with suitable devices for controlling the flow to each tank unit and to withdraw any unit from service. Velocity between bays or around baffles shall not exceed 0.5 ft./sec.

(b) Channels and pipes shall be designed to provide self-cleansing velocities, or shall be equipped with mechanical devices for keeping solids in suspension continuously.

15.6. *Measuring Devices*

Devices shall be provided for indicating rates of flow of presettled effluent, return sludge, air to each tank unit, and total volume of wasted sludge. Preferably, these devices shall also totalize and record as well as indicate flows.

15.7. *Air Supply*

(a) Aeration capacity shall be at least 1.5 cubic feet per gallon of incoming raw sewage plus the capacity required for reaeration of returned sludge.

(b) Blowers shall be in multiple units and of such capacity that full operation requirements can be met with the largest unit out of service.

(c) Blower capacity required to deliver air to channels, sludge pumps, foam-control pumps, or similar demands shall be in addition to that required for tank aeration as specified in 15.7(a).

(d) The air diffuser system shall be capable of delivering 150 per cent of normal requirements, which ordinarily may be considered as 1,000 cu. ft. per pound of B.O.D. to be removed from the influent sewage.

(e) Air filters shall be such as to continuously maintain air supply having dust content of not more than 0.5 mg. per 1,000 cu. ft.

(f) It is recommended that each blower be equipped with a silencer.

15.8. *Air Diffusers and Control Valves*

(a) Aeration plates, tubes or jets shall be designed for easy cleaning, and shall be so designed as to maintain an even distribution of air finely dispersed throughout the aeration tanks.

(b) Individual assembly units of diffusers shall have a substantially uniform pressure loss and shall be equipped with control valves with indicator markings.

15.9. *Sludge Handling Equipment*

(a) Return activated sludge pumps or air lifts shall have variable combined capacity, capable of pumping at least 25 per cent of the design flow with the largest single unit out of service.

(c) Blower capacity required to deliver air to sludge pumps, foam-control pumps, or similar demands shall be in addition to that required for tank aeration as specified in 16.5(a).

(d) The air diffuser system shall be capable of delivering 150 per cent of normal requirements.

(e) Air filters shall be such as to continuously maintain air supply having dust content of not more than 0.5 mg. per 1,000 cu. ft.

(f) It is recommended that each blower be equipped with a silencer.

16.6. *Air Diffusers*

(a) Air diffusion tubes shall be designed and be of such porosity as to maintain an even distribution of air finely dispersed throughout the aeration tank.

(b) Individual assembly units of diffusers shall have a substantially uniform pressure loss and shall be equipped with control valves with indicator markings.

(c) The number of assembly units and the porosity of diffuser tubes shall be such that so far as practicable they maintain a self-cleansing velocity of air.

16.7. *Sludge Removal*

(a) Each settling tank shall be provided with means for the removal of sludge.

(b) Sludge from the preliminary settling tank shall be transferred to the digester. Sludge from the other units of the plant may be returned to the incoming sewage.

16.8. *Sludge Digestion*

(a) The general provisions contained in Chapter 12 relative to sludge digesters shall apply, when anaerobic sludge digesters are provided.

(b) Supernatant liquor from anaerobic sludge digesters shall be treated before being returned to the main aeration units.

16.9. *Controls*

(a) Unless it is intended that continuous 24-hour per day supervision be provided, automatic controls for blowers and sludge lifts shall be installed.

(b) In addition to the aforementioned automatic controls, provisions shall also be made for the manual operation of the various facilities.

CHAPTER 17—INTERMITTENT SAND FILTERS

17.1. *General*

(a) At least two filter units shall be provided.

(b) Sod and similar coverings to intermittent sand filters are prohibited.

17.2. *Loading*

(a) With acceptable primary treatment of normal sewage, volumetric loading shall not exceed 3,400 gallons

per thousand square feet (150,000 gallons per acre) per day. For stronger sewage the rate of filtration shall be proportionately lower.

(b) Organic loading of 5-day B.O.D. shall not exceed 3.8 lbs. per thousand square feet (165 lbs. per acre) per day.

(c) For chemical coagulation and sedimentation the loading shall not exceed 9,200 gallons per thousand square feet (400,000 gallons per acre) per day.

(d) For standard or high rate trickling filters or activated sludge followed by secondary settling tanks, the loading shall not exceed 11,500 gallons per thousand square feet (500,000 gallons per acre) per day.

(e) For schools, camps, and institutions, not having a full-time operating staff, loading should not exceed 2,300 gallons per thousand square feet (100,000 gallons per acre) per day for primary tank effluent.

17.3. *Medium*

(a) Clean graded gravel, shall be placed in at least three layers over the entire floor of the bed and around the underdrains and to a depth of at least 6 inches. Grading for the three layers shall be $1\frac{1}{2}$ " to $\frac{3}{4}$ ", $\frac{3}{4}$ " to $\frac{1}{4}$ " and $\frac{1}{4}$ " to $\frac{1}{8}$ ".

(b) Underdrains shall have maximum spacing not exceeding eight (8) feet o.c. and shall be at least four inches in diameter, or of equivalent area.

(c) Pipes shall be laid with open joints with a space of approximately $\frac{1}{4}$ inch between ends. A single layer of muslin, cheese cloth or burlap, shall be wrapped around each joint. Tar paper or other waterproof material shall not be used.

(d) Sand with an effective size of 0.3 to 0.6 mm. and a uniformity coefficient of not more than 3.5 shall be provided to a depth of at least 30 inches. The sand shall be free from clay, loam or silt.

17.4. *Dosing*

(a) A dosing tank or its equivalent having a maximum detention period of three hours based upon design flow shall be provided.

(b) The dosing tank volume shall be such that any filter bed will be covered to a maximum depth of four (4) inches with each dose.

(c) Siphons shall have a discharge capacity, at minimum head, at least 100 per cent in excess of the maximum rate of inflow to the dosing tank, and at average head, at least 1 cu. ft. per second per 5,000 sq. ft. of each filter bed.

17.5. *Distribution*

(a) Troughs or piping used for distribution of the settled sewage over the filter surface shall be so located that the maximum lateral travel is not more than 10 feet. Provision shall be made at each discharge port for adjustment of the flow.

(b) Splash slabs shall be provided at each point of discharge.

(c) A drain opening from troughs or discharge piping shall be provided.

17.6. *Earth Base*

The earth base of the filters shall be sloped to the trenches in which the underdrains are laid.

CHAPTER 18—DISINFECTION

18.1. *General*

(a) Chlorination devices shall be of the solution feed type, installed in duplicate or with duplicate essential parts.

(b) Installations which are to be merely replacement of equipment will be approved without the submission of plans but an application and specifications (in duplicate) shall be submitted.

(c) Chlorinating devices shall be placed in separate rooms with outside entrance only and provided with suitable ventilation. The doors shall open outward. Provisions for heating during the winter season are required. A suitable gas mask shall be provided and maintained in good operating condition. The gas mask shall be stored in an accessible location outside the chlorine room.

(d) The chlorine contact period in tanks or their equivalent, shall be at least one-half ($\frac{1}{2}$) hour, based on the design flow. Contact tanks shall be baffled.

(e) Provisions shall be made for the thorough mixing of the disinfectant and the sewage before discharge to the chlorine contact tank.

(f) Scales shall be provided for determining loss of weight of chlorine, and, a suitable comparator for measuring residual shall also be provided.

(g) If hypochlorite feeders are provided, duplicate solution tanks (crocks) each having at least thirty-six hours storage capacity are required.

18.2. *Capacity of Chlorinators*

(a) For disinfection, the capacity of chlorinators shall be adequate to produce a residual of 2.0 ppm in the final effluent. For normal domestic sewage the following minimum dosing capacity shall be required:

<i>Type Treatment</i>	<i>Dosage (Based on Design Average Flow)</i>
Raw Sewage	30 ppm
Primary Sedimentation Effluent ..	20 ppm
Trickling Filter Plant Effluent ...	15 ppm
Contact Aeration (Multisurface Oxidation)	15 ppm
Activated Sludge Plant Effluent ..	10 ppm
Sand Filter Effluent	10 ppm

CHAPTER 19—OTHER SEWAGE TREATMENT PROCESSES

19.1. The use of treatment processes other than those listed in these regulations will be considered on the merit of the process involved.

CHAPTER 20—WATER, GENERAL

Instructions and general requirements under Chapters 1 and 2 are applicable to design of water supplies and water treatment plants.

20.1. Information Required

(a) A general plan of the institution, municipality or district to be supplied.

(b) If a surface supply, a map of the watershed; if from wells or collecting galleries, a map showing their location.

(c) General and detailed plans of water treatment plants.

(d) General and detailed plans of wells and collecting galleries.

(e) Specifications for treatment plants, wells and collecting galleries, and their appurtenances.

(f) A comprehensive report upon the proposed works by the designing or consulting engineer.

(g) Estimate of costs.

20.2. Maps to be Submitted

(a) *Surface Supplies*—A small scale map showing all details that may influence the quality of the water at the intake, such as sewage treatment plants, industrial plants, roads, etc.

(b) *Wells and Collecting Galleries*—A large scale map showing the location of the wells or galleries, the dwellings, septic tanks, cesspools and streams within five hundred (500) feet of the well field or galleries, the storm and sanitary sewer lines, as well as type of construction passing over or near the wells and galleries, and other sanitary features.

20.3. General and Detail Plans of Treatment Plants

(a) Plans for treatment plants shall include: A general plan upon which the reserve areas, or future extension shall be shown; the general layout of the various units of the processes, together with the piping system, surface elevations of the various units, and the normal elevation and the highest known floodwater elevation of the stream.

(b) The detail plans shall show, if the water is from a surface source, details of the intake pipe, crib, screen, etc., and complete details of each unit of the works, including mixing chambers, collecting and piping systems, methods of applying chemicals, rate controllers,

loss of head gauges, washing arrangements, pumps, special devices, etc., and size and depth of stone, gravel and sand used for filtering material.

20.4. *General and Detail Plans of Wells and Collecting Galleries*

(a) The general plan shall show the layout of the plant together with the pipelines and land reserved for future development or the protection of the supply, the surface elevations and the elevations of the various units of the plant. The plan for the galleries, and, if the wells are adjacent to a stream, for the well, shall show the low water and maximum high water elevations of the stream if tidal, and if the stream is not tidal, the normal elevation and highest known floodwater elevations. The location and type of construction of the toilets at the plant shall be shown, together with the location and type of construction of the sewer lines leading from them.

(b) The detail plans for the wells shall show the depth, size and construction of each well, including the depths of casings and the type of strainer and seals to be used, wellheads and head seals, sampling taps, the location of the ground strata through which the well is driven, the details of the pumping station, including equipment, collecting basins, special devices, etc., and all pipelines with appurtenances at the well field and pumping station together with the connections to the water distribution system.

(c) The detail plans for collecting galleries shall show the depth, size and construction of the galleries, all details such as manholes, size of pipes, valves, etc. The plans shall show the details of the pumping station including pumping equipment, and all pipelines with appurtenances at the galleries and pumping station, together with the connections to the water distribution system, and, a sampling tap.

20.5. *Engineer's Report*

A report by the designing or consulting engineer shall accompany all plans for a new water supply, or any extension or modification of any water supply, or water treatment plant. The report shall contain the following information:

(a) *Water Consumption and Population*

The present population to be served should be stated and the estimated population to be served and water consumption ten (10) and twenty-five (25) years hence, with computations and curves.

(b) *The Source of Supply*

If from a surface source, the results of the chemical and bacteriological examinations of the raw water shall be included. The area, population and a description of the watershed shall be given, the sources of pollution, including privately and publicly owned sewage treatment plants discharging effluents into the source of supply and plants discharging industrial wastes, and the protective measures to be installed or enforced for the protection of

the supply, such as patrol, fishing and bathing regulations, etc. If from an underground source, information shall be given upon the various strata and, based on the results of analysis, or other reliable information regarding water from similar sources, the probable quantity and quality of the supply.

(c) *Description of Pumping Equipment*

A description shall be given of the pumping equipment, the method of connecting the pumps with well, suction lines, etc.

(d) *Treatment*

The method of treatment and a description of the units of the system must be given together with the rate of operation of each unit of the system; if chemicals are to be applied the nature and quantity to be used of each, with the description of the appliances for adding the same to the water. A description should be given of all conditions peculiarly characteristic of the water or locality which in any manner affect the design or operation of the system; a description of all special appliances used and any special methods of maintenance or operation of the plant.

CHAPTER 21—WELL SUPPLIES

21.1. *General Requirements*

(a) Subsurface construction shall be such as to prevent the entrance of contaminating material, through casing joints, to the well structure. The annular space between the excavation line and the outside of the well casing should be filled in such a manner as to prevent surface water or shallow ground water from running down the outside of the casing and thence into the well or into the water-bearing strata.

(b) The wellhead and top of casing shall be so designed as to permit placing an adequate seal to prevent contamination from surface sources.

(c) Sampling taps shall be provided on the discharge from each well.

(d) Detailed drawings of the casing work are required.

CHAPTER 22—WATER TREATMENT PLANTS

22.1. *General*

(a) Flow recording devices shall be installed.

(b) A laboratory is desirable and may be required for large plants. Laboratory analyses may be specified by the State Department of Health, according to the character of the treatment plant design. The laboratory shall be equipped for such analyses in accordance with the latest edition of the "Standard Methods for the Examination of Water and Sewage" as prepared, approved and published jointly by the American Public Health Association and the American Water Works Association.

(c) Provisions shall be made so that samples at each step in the treatment process can be obtained.

(d) The return to the system of any water used in and about the plant for any purpose, which might in any way become contaminated, will not be permitted.

(e) Means shall be provided for disinfecting new mains, tanks, basins, filters and other equipment in accordance with the latest recommended procedures of the American Water Works Association.

(f) If the rules and regulations do not strictly apply to plans for any new processes and/or equipment, said plans will be examined on the basis of conservative design factors, provided sufficient data are furnished on which the new processes and/or equipment may be examined.

22.2. *Filtration—Surface Supplies*

Slow Sand

(a) At least two units are required, each capable of supplying the entire demand. If more than two are proposed, this requirement is waived, provided that when one filter is out of service, the other units are of sufficient size to supply the necessary amount of water at the proper rate.

(b) The rate shall not exceed 4,500,000 gallons per acre per day.

(c) The effective size of the sand shall be between .25 and .45 millimeters; the uniformity coefficient not over 2.0.

(d) The depth of sand shall be not less than thirty-six (36) inches.

(e) At least twelve (12) inches of graded gravel shall be placed over underdrains.

(f) Enclosures for filters are desirable and will be required in northern sections of the State.

(g) Disinfection as a posttreatment is required.

(h) Each filter unit shall be provided with a rate of flow meter and a loss of head gauge and should contain a rate controller.

(i) Means shall be provided for cleaning and scraping the filters, placing sand and washing the sand, if sand is to be reused.

Rapid Filters (Gravity or Pressure Types)

(a) At least two units are required, each capable of supplying the entire demand. If more than two are proposed, this requirement is waived, provided that when one filter is out of service, the other units are of sufficient size to supply the necessary amount of water at the proper rate.

(b) The rate shall not exceed 125,000,000 gallons per acre per day (2 gallons per square foot per minute) unless otherwise approved by the State Department of Health.

(c) Filter media may be sand or anthracite coal, placed on gravel, anthracite coal, or porous filter bottoms. At least 30 inches of fine media shall be used; if sand, it shall have an effective size, between .30 and .50 milli-

meters, with the uniformity coefficient of not over 1.6; if anthracite coal, the effective size may be up to .65 millimeters. If the fine media is supported on graded gravel, at least 12 inches of the graded gravel shall be used, the upper two inches of which shall have effective size of between two and three millimeters.

(d) Rate of flow and loss of head indicators and rate controllers are required.

(e) Wash water shall be filtered and chlorinated water.

(f) Adequate mixing and flocculation shall precede the settling basins in the coagulation process. The over-all detention time for rapid mixing, coagulation and settling shall be not less than three hours.

(g) Provisions shall be made for prechlorination and postchlorination.

22.3. Iron Removal

(a) Engineering data for iron removal plants shall be submitted in the same manner as for other water purification plants.

(b) If units as covered by the rules and regulations for water treatment are to be installed, they shall be designed in accordance with the provisions thereof. Special units or installations shall not expose the water to contaminants and will be examined on the basis of their satisfying accepted or tried principles and practices.

22.4. Disinfection

(a) Installations which are to be merely replacement of equipment will be approved without the submission of plans but an application and specifications (in duplicate) shall be submitted.

(b) Gas chlorinating devices shall be placed in rooms with outside entrance only, and provided with suitable ventilation. The door shall open outward. Provision for heating during the winter season is required. A suitable gas mask shall be provided and maintained in good operating condition. The gas mask shall be stored in an accessible location outside the chlorine room.

(c) Chlorinating equipment shall be in duplicate or spare parts shall be provided to guarantee no interruption in the delivery of a properly chlorinated water.

(d) Where chlorine cylinders are required, scales shall be provided for determining the loss of weight of chlorine.

(e) If hypochlorite feeders are provided duplicate solution tanks (crocks) shall be provided, each to have a capacity of forty-eight (48) hours supply of hypochlorite solution.

(f) A suitable comparator for measuring residual chlorine shall be provided.

(g) If ammonia is added, the ammonia system shall be separated from the chlorine system so that the ammonia and chlorine gases will not mix.

(h) If chlorine dioxide treatment is used the same requirements for the installation as for chlorine above apply.

CHAPTER 23—WATER STORAGE**23.1. Storage**

(a) Storage facilities shall be described in detail in the engineer's report.

(b) Plans and specifications will be required on standpipe and elevated storage tanks, particularly with respect to features of sanitary significance such as covers, vents, overflows, and access hatches.

(c) Provision shall be made to preclude the entrance of material likely to result in the contamination of the water in storage.

CHAPTER 24—FLUORIDATION**24.1. Objective**

The technical objective of the fluoridation process is to maintain a fluoride ion concentration of at least one part per million, and not more than one and four-tenths (1.4) parts per million, in the water delivered to consumers.

24.2. Equipment

(a) Fluorine compounds shall be added at as many points in water supply systems as are necessary to insure that all water being distributed to the consumer will have the proper concentration of fluoride ion.

(b) Equipment for the feeding of fluorine compounds may be of the solution or dry feed type depending upon the compound to be used and the size of the installation.

(c) Feeding equipment which permits wide variations in the amount of fluorine compound added will not be approved.

24.3. Safety

(a) Respirators of a type approved by the U. S. Bureau of Mines shall be provided for all persons handling dry fluorine compounds.

(b) Rubber gloves shall be provided for all persons handling fluorine compounds.

(c) Adequate means for the control of dust shall be provided where dry fluorine compounds are to be handled. If dust collecting or mechanical equipment is deemed necessary for specific feeders, such equipment shall be required.

(d) Powdered or granulated fluoride compounds used in the fluoridation process shall be dyed or tinted in such manner that they will or may not be confused with any other compound or substance used at the water plant.

(e) Rooms in which fluorine compounds are to be stored or handled shall be secured against entrance by unauthorized persons.

(f) Waste liquids or sludge containing fluorine compounds shall be disposed of by such means as may be approved by the Department.