1. Systems shall be authorized only in those municipalities which have adopted an ordinance that is in conformance with the requirements of this Part and has been certified by the Commission pursuant to N.J.A.C. 7:50-3.

The manufacturer of the alternate design pilot program treatment system has submitted to the Executive Director and the Executive Director has approved:

i. Detailed specifications and an engineering design for the system. Separate specifications and designs may be submitted for systems serving an individual dwelling and for community on-site systems. These specifications and designs may only be approved by the Executive Director if they are determined to be consistent with the description of the relevant technology contained in the report prepared by Anish R. Jantrania, Ph.D., P.E., M.B.A. entitled "Performance Expectations for Selected On-site Wastewater Treatment Systems," dated December, 2000, incorporated herein by reference, and available at the principal office of the Commission. Subsequent to that approval, manufacturers may submit modified specifications or engineering designs for the system which may then be utilized if the Executive Director determines the modifications are consistent with the originally approved specifications and engineering design and the modified system will be at least as effective as the originally approved system;

ii. A description of the automatic dialing system required in (a)6ii below, and a description of how and when that system will function;

iii. A monitoring protocol that ensures that sufficient data will be obtained to enable a determination of whether the technology complies with the two ppm nitrogen requirement and the water quality standards contained in N.J.A.C. 7:50-6, Part VIII. For each system being monitored, the protocol will provide at a minimum that the effluent will be sampled at least quarterly for a period of at least three years and that at least the following parameters will be analyzed: total nitrogen, nitrate-nitrogen, nitrite-nitrogen, ammonia-nitrogen, total kjeldahl nitrogen and chlorides;

iv. An operation and maintenance manual;

A sample warranty and maintenance contract; v. and

vi. A sample deed notice that is consistent with (a)6viii below.

3. Subject to being increased during the pilot program based on the results of a hearing conducted pursuant to (a)5 below, each Ashco RFS III system shall be located on a parcel containing at least 1.5 acres for each dwelling unit that will be served by the system and each FAST, Cromaglass, Bioclere or Amphidrome system shall be located on a parcel containing at least one acre for each dwelling unit that will be served by the system.

5. The Executive Director shall submit an annual report to the Commission describing installation, maintenance and performance data for each technology. The Executive Director also shall submit an interim report to the Commission if it is determined there is a significant installation, maintenance or performance issue with one or more technologies that needs to be addressed before the issuance of the next annual report. Copies of each annual and interim report shall be provided to each manufacturer and agent of a technology that is discussed in that report. If it is determined in a report either that a manufacturer or its agent is not adhering to any of the requirements of this pilot program or that any one of the technologies, based on maintenance or installation issues or on an evaluation of all the monitoring results for that technology under this pilot program, is not meeting the minimum water quality standards in N.J.A.C. 7:50-6.83 or the two parts per million total nitrogen requirement in (a)6x below on all lots smaller than 3.2 acres or on lots smaller than a particular size because the effluent exiting the system is higher than was anticipated in establishing the lot sizes in (a)3 above, then any subsequent local approvals for a development that is proposing use of said technology shall be determined to raise a substantial issue and shall be reviewed by the Commission pursuant to the provisions set forth in N.J.A.C. 7:50-4.31 through 4.42. Notice of any hearing scheduled pursuant to this paragraph and any subsequent determination on the application made by the Executive Director or the Commission pursuant to N.J.A.C. 7:50-4.31 through 4.42 shall be provided to the manufacturers of said system and any agent designated by said manufacturer. The annual or interim report issued by the Executive Director shall be part of the hearing record in any hearing conducted pursuant to this paragraph.

6. Conditions for use of alternate design pilot program treatment systems are as follows:

i. No more than 10 alternate design pilot program septic systems utilizing the same technology shall be installed in the development of any parcel if those systems are each serving one single family dwelling;

ii. Each system shall be equipped with automatic dialing capability to the manufacturer, or its agent, in the event of a mechanical malfunction. The manufacturer or its agent shall report to the Executive Director each such malfunction within five days of its occurrence, describing the nature of the mechanical malfunction, the measures taken to correct the malfunction and the success of those measures. Periodic dialing or some other fail safe mechanism shall be provided to ensure against unauthorized disconnections;

Supp. 7-18-05

iii. Each system shall be designed and constructed so that samples of effluent leaving the alternate design pilot program septic system can be readily taken to confirm the performance of the technology;

iv. The manufacturer or its agent shall be responsible for providing resources for the collection and analysis of effluent samples in accordance with the protocol approved pursuant to (a)2iii above. The samples shall be taken from each system that is installed unless the manufacturer or agent of a particular technology demonstrates, and the Executive Director concurs, that samples from a specified representative number of systems of that technology will provide sufficient information to enable an evaluation of that technology. Each sample shall be analyzed by a New Jersey certified laboratory and the results of each analysis shall be reported to the Executive Director by the manufacturer or its agent within five days of receipt from the certified laboratory. The manufacturer or its agent shall also submit to the Executive Director a guarterly evaluation of all monitoring conducted prior to that evaluation;

v. The manufacturer or its agent shall certify to the Commission and the local board of health that installation of each system has been properly completed and shall include in the certification the cost of the installation and a description of any problem encountered during the installation;

vi. The manufacturer or its agent shall provide to each owner an operation and maintenance manual approved pursuant to (a)2iv above;

vii. Each system shall be covered by a five-year warranty and a minimum five-year maintenance contract that cannot be cancelled and is renewable and which includes a provision requiring that the manufacturer or its agent inspect the system at least once a year and undertake any maintenance or repairs determined to be necessary during any such inspection or as a result of observations made at any other time, including when effluent monitoring occurs or that is identified based on the results of any effluent monitoring. Said warranty and maintenance contract shall be consistent with the sample warranty and maintenance contract approved pursuant to (a)2v above. In addition to complying with the reporting requirements of N.J.A.C. 7:9A-3.4(b) concerning system malfunctions, the manufacturer or agent shall report to the Executive Director and local board of health on all necessary maintenance and repairs within 10 days and shall report to the Executive Director and local board of health semi-annually as to the inspections conducted during the preceding six months including a description of any maintenance and repairs that were undertaken and the success of those measures and their costs;

viii. The property owner shall record with the deed to the property a notice consistent with the sample deed notice approved pursuant to (a)2vi above that identifies the technology, acknowledges the owner's responsibility to operate and maintain it in accordance with the manual required in (a)6vi above, and grants access, with reasonable notice, to the local board of health, the Commission and its agents for inspection and monitoring purposes. The recorded deed shall run with the property and shall ensure that the maintenance requirements are binding on any owner of the property during the life of the system and that the monitoring requirements are binding on any owner of the property during the time period the monitoring requirements apply pursuant to this pilot program or any subsequent regulations adopted by the Commission that apply to said system;

ix. The manufacturer or its agent shall make available for inspection by the Commission or its agents, upon reasonable notice, all records relating to each system installed in the Pinelands pursuant to this pilot program;

x. By July 5, 2003 and every six months thereafter until the conclusion of the pilot program, each manufacturer or its agent shall submit to the Executive Director a report which includes the number of systems installed during the previous six months and since the beginning of the pilot program, a discussion of any installation problems and what has been done to address those problems, an analysis and evaluation of the monitoring results to date and a discussion of any operational or maintenance issues, including the number of systems requiring maintenance or repairs and the nature and success of such maintenance and repairs, and the number of times the automatic dialing system was set off and the reasons for each such occurrence; and

xi. The system complies with the requirements of N.J.A.C. 7:50-6.84(a)4i through v.

(b) The property owner shall not be held liable for poor system performance if the system has been properly operated and maintained.

- New Rule, R.2002 d.247, effective August 5, 2002.
- See: 34 N.J.R. 722(a), 34 N.J.R. 2804(b).
- Public Notice: Ashco-A-Corporation, RFSIII Wastewater Treatment System.
- See: 35 N.J.R. 2750(b).
- Public Notice: Amphidrome® Treatment System.
- See: 35 N.J.R. 4135(b).
- Ascho-A-Corporation, RFSIII Gravity Dosing Treatment System.
- See: 35 N.J.R. 4136(a).
- Public Notice: Approval of Aquapoint, Inc, Bioclere ™ Treatment System.
- See: 36 N.J.R. 221(c).
- Public Notice: Approval of Cromaglass ® Treatment System.
- See: 36 N.J.R. 1238(a).
- Petition for Rulemaking.
- See: 37 N.J.R. 1237(a), 2707(a).