



Christine Todd Whitman  
*Governor*

State of New Jersey  
Department of Community Affairs  
Division of Codes and Standards  
PO Box 802  
Trenton, New Jersey 08625-0802



Harriet Derman  
*Commissioner*

BULLETIN NO.

95-1

Date: **September 1995**

Subject: **Flammable and Combustible  
Liquid Storage Tanks**

Over the past six years, the Department of Community Affairs has issued a number of bulletins on flammable and combustible liquid storage tanks. Each of these bulletins addressed a specific issue related to these tanks. This bulletin consolidates all of these issues into one bulletin for convenient reference.

This bulletin is divided into four parts (95-1A, 1B, 1C, and 1D). Each part deals with either the installation or removal/abandonment of certain types of tanks. The bulletin primarily deals with underground tanks, though procedures for abandoning above-ground tanks are included in part 1B.

For all residential heating-oil tanks and other heating-oil tanks less than 2,001 gallons [Uniform Construction Code (UCC) regulated], part 1A for installation and part 1B for removal/abandonment are applicable.

For commercial heating-oil tanks 2,001 gallons and over, waste-oil tanks, and gasoline tanks of any size (UCC and New Jersey Department of Environmental Protection regulated), part 1C for installation and part 1D for removal/abandonment are applicable.

BULLETIN