

Emergency power loads; Section 604.2.17, Group I-3 occupancies; Section 604.2.18, Airport traffic control towers; Section 604.2.19, Elevators; Section 604.2.19.1, Manual transfer; Section 604.2.19.2, One elevator; Section 604.2.19.3, Two or more elevators; and Section 604.2.19.4, Venting.

xvii. New Section 604.3.1.1, Testing, shall be inserted as follows, "604.3.1.1 Testing: Required emergency lighting systems, including exit signs, shall be tested for proper operation for a minimum of 30 seconds every month. An annual test shall be conducted for at least 1 hour. Equipment shall function properly for the duration of these tests."

xviii. New Section 604.3.1.2, Battery system, shall be inserted as follows, "604.3.1.2 Battery system. Where battery systems or unit equipment are involved, including batteries utilized for starting, control or ignition in auxiliary engines, routine maintenance shall be provided in accordance with the manufacturer's specifications."

xix. New Section 604.3.1.3, Emergency generators, shall be inserted as follows, "604.3.1.3 Emergency generators. Required emergency generators shall be tested at least annually in accordance with the manufacturer's specifications under anticipated load conditions.

1. Transition test. A transition test shall be conducted annually to ensure that the transfer time from normal power to emergency power is 10 seconds or less.

2. Fuel supply. Where internal combustion engines are utilized as the prime mover for an emergency generator, an on-site fuel supply shall be provided sufficient for not less than 2 hours full-demand operation of the system."

xx. In Section 605.1, Abatement of electrical hazards, "ICC Electrical Code" shall be deleted and "electrical subcode of the Uniform Construction Code" shall be inserted. After "used," "All electrical wiring, devices, appliances and other equipment shall be maintained in accordance with the provisions of the New Jersey Uniform Construction Code Electrical Subcode and this subchapter." shall be inserted.

xxi. In Section 605.3, Working space and clearance, Exception, 1, after "allowed by," "the ICC Electrical Code" shall be deleted and "the Uniform Construction Code." shall be inserted.

xxii. In Section 605.4, Multiplug adapters, "the ICC Electrical Code" shall be deleted and "the electrical subcode of the Uniform Construction Code" shall be inserted.

xxiii. In Section 605.9, Temporary wiring, "the ICC Electrical Code" shall be deleted and "the electrical subcode of the Uniform Construction Code" shall be inserted.

xxiv. New Section 605.11, Unused equipment, shall be inserted as follows, "605.11 Unused equipment. All unused fixtures, circuits, wiring and electrical devices or fixtures shall be removed or properly secured in place and maintained."

xxv. In Section 606.1, Scope; Section 606.2, Refrigerants; Section 606.3, Refrigerant classification; Section 606.4, Change in refrigerant type; Section 606.6.1, Periodic testing; and Section 606.8, Refrigerant detector, "the International Mechanical Code" shall be deleted and "the mechanical subcode of the Uniform Construction Code" shall be inserted.

xxvi. In Section 606.7, Emergency signs, "International Mechanical Code" shall be deleted and "mechanical subcode of the Uniform Construction Code" shall be inserted.

xxvii. In Section 606.16, Electrical equipment, "the International Mechanical Code" shall be deleted and "the mechanical subcode of the Uniform Construction Code" shall be inserted. "The ICC Electrical Code" shall be deleted and "the electrical subcode of the Uniform Construction Code" shall be inserted. In the Exception, "Section 1106.3.20 of the International Mechanical Code" shall be deleted and "the mechanical subcode of the Uniform Construction Code" shall be inserted.

xxviii. In Section 607.3, Elevator keys, after "fire department," "and shall be in compliance with N.J.A.C. 5:70-2.23, Elevator key lock boxes." shall be inserted.

xxvix. In Section 608.4, Room design and construction, "the International Building Code" shall be deleted and "the building subcode of the Uniform Construction Code" shall be inserted.

xxx. In Section 608.6.1, Room ventilation, "the International Mechanical Code" shall be deleted and "the mechanical subcode of the Uniform Construction Code" shall be inserted.

xxxi. In Section 608.8, Seismic protection, "the International Building Code" shall be deleted and "the building subcode of the Uniform Construction Code" shall be inserted.

xxxii. In Section 608.9 Smoke detection, "installed" shall be deleted and "maintained" shall be inserted.

xxxiii. In Section 609.1, General, "including those in mobile enclosed units" shall be inserted after "exhaust hoods" and "comply" shall be deleted and "be maintained in accordance" shall be inserted. Also, "the International Mechanical Code" shall be deleted and "the mechanical subcode of the Uniform Construction Code and NFPA 96" shall be inserted.

xxxiv. In Section 609.2, Where required, "Where required" shall be deleted and the text of the section shall be deleted and the following text shall be inserted, "609.2 Maintenance. Commercial kitchen exhaust systems shall be cleaned to remove deposits of residue and

grease in the system at intervals specified in the cleaning schedule required to be submitted in accordance with 609.2.1. Thorough cleaning of ducts, hoods and fans shall require scraping, brushing or other positive cleaning methods."

xxxv. New Section 609.2.1, Cleaning schedule, shall be inserted as follows, "609.2.1 Cleaning schedule. Where a cleaning schedule is not on file, the fire official shall require a schedule to be submitted, indicating the method of cleaning and the time intervals between cleanings."

7. Chapter 7, Fire-Resistance-Rated Construction, shall be amended as follows:

i. In Section 703.2, Opening protectives, the following text shall be inserted after the word "inoperable" "Door stops, wedges and other unapproved hold-open devices shall be prohibited."

ii. In Section 703.2.2, Hold-open devices and closers, the following text shall be inserted before the first sentence starting with the word "hold-open," "Approved self-closing". The following text shall be inserted following the second sentence after the word "position," "Where it is desired to keep the doors open, an automatic-closing device actuated by automatic fire detectors shall be provided in accordance with the building subcode of the Uniform Construction Code."

iii. In Section 704.1, Enclosure, the words "Table 704.1" shall be deleted and the following text shall be inserted, "the construction code in effect at the time of construction or N.J.A.C. 5:70-4 as applicable."

iv. Table 704.1, Vertical Opening Protection Required shall be deleted.

8. Chapter 8, Interior Finish, Decorative Materials And Furnishings, shall be amended as follows:

i. In Section 803.1, General, the text of the section following "803.1 General." shall be deleted in its entirety and the following shall be inserted, "The interior finish and trim shall be maintained in accordance with the requirements of N.J.A.C. 5:23, the Uniform Construction Code or N.J.A.C. 5:70-4 the Uniform Fire Code, Fire Safety Code as applicable. Any interior finish or trim installed without a permit issued in accordance with N.J.A.C. 5:23, the Uniform Construction Code, shall be removed."

ii. In Section 803, Interior Wall and Ceiling Finish and Trim in Existing Buildings, the following sections shall be deleted: 803.1.1, Classification; 803.2, Stability; 803.3, Interior finish requirements based on occupancy; 803.4, Fire retardant coatings; 803.5, Textiles; 803.5.1, Textile wall coverings; 803.5.1.1, Method A. test protocol Textiles; 803.6, 803.6.1, Expanded vinyl wall or ceiling coverings, General; and 803.6.2, Compliance alternative.

iii. Table 803.3, Interior Wall And Ceiling Finish Requirements By Occupancy, shall be deleted in its entirety.

iv. In Section 803.7.1, Combustibility characteristics, the following shall be deleted, "in Section 2603.9 of the International Building Code" and the following shall be inserted, "the building subcode of the Uniform Construction Code."

v. In Section 803.7.2, Thermal barrier, the following shall be deleted, "Section 2603.4 of the International Building Code", and the following shall be inserted, "the building subcode of the Uniform Construction Code".

vi. Section 804, Interior Wall and Ceiling Trim in New and Existing Buildings, shall be deleted in its entirety.

vii. In Section 805, Upholstered Furniture And Mattresses In New And Existing Buildings, the following text shall be deleted, "In New And Existing Buildings."

viii. In Section 806, Decorative Vegetation In New And Existing Buildings, the following text shall be deleted, "In New And Existing Buildings."

ix. In Section 806.1.1, Restricted occupancies, the following text shall be deleted, "Group A, E, I-1, I-2, I-3, I-4, M, R-1, R-2, R-4" and the following text shall be inserted, "all". In Section 806.1.1, Restricted Occupancies, Exception, 1. The following text shall be deleted, "in Groups A, E, M, R-1 and R-2." In Section 806.1.1, Restricted Occupancies, Exception 2, the following text shall be deleted, "in Group R-2 occupancies" and the word "individual" shall be added after the word "within."

x. In Section 806.3, Obstruction of Means of Egress, after "vegetation," the "and the decorative vegetation shall not be placed near any stairway or elevator shaft" shall be inserted.

xi. New Section 806.6, Show windows, shall be inserted as follows, "806.6 Show windows. "Decorative vegetation and wreaths shall not be used for decorative purposes in show windows or other parts of buildings in such a quantity as to constitute a fire hazard unless such material is flameproofed in an approved manner."

xii. New Section 806.7, Under-tree decorations, shall be inserted as follows, "806.7 Under-tree decorations. No flammable decorations, combustible tree skirts or decorative gift packages may be placed on or under or around decorative vegetation. This restriction does not apply to decorative vegetation displayed in a sprinklered building."

xiii. New Section 806.8, Holiday wreaths, shall be inserted as follows, "806.8 Holiday wreaths: Holiday wreaths shall be permitted in any building but such

every structure shall be responsible for the safety of all persons in, or occupying, such premises with respect to the adequacy of means of egress therefrom.”

x. In Section 1003.2, Ceiling height, the text of the section shall be deleted and the following shall be inserted, “Egress plan. Where required by Section 404.2, a plan complying with Section 404.3 shall be submitted to the fire official and an approved copy shall be kept on the premises of assembly occupancies.”

xi. In Section 1003.3, Protruding objects, the text of the section shall be deleted and the following shall be inserted, “Occupant load.: The occupant load for structures shall be maintained pursuant to the New Jersey Uniform Construction Code provisions in effect at the time of construction. The occupant load for structures constructed under standards in force prior to adoption of the New Jersey Uniform Construction Code shall be calculated in accordance with N.J.A.C. 5:70-4.11(f)3.”

xii. In Section 1003, General Means of Egress, the following sections shall be deleted in their entirety: Section 1003.3.1, Headroom; Section 1003.3.2, Free standing objects; Section 1003.3.3, Horizontal projections; and Section 1003.3.4, Clear width.

xiii. In Section 1003.4, Floor surface, the text of the section shall be deleted and the following shall be inserted, “Posting of occupant load. An assembly occupancy shall be posted with an approved legible sign in contrasting colors conspicuously located near the main point of egress from the room or space stating the number of occupants permitted within such space. The number of occupants permitted shall be in accordance with the current certificate of occupancy issued pursuant to the New Jersey Uniform Construction Code for structures constructed and occupied under the provisions of that code, and shall be in accordance with N.J.A.C. 5:70-4.11(f)3. for structures constructed under standards in force prior to adoption of the New Jersey Uniform Construction Code for which structures no such certificate of occupancy has subsequently been issued.”

xiv. In Section 1003.5, Elevation change, the text of the section shall be deleted and the following shall be inserted, “Overcrowding. A person shall not permit overcrowding or admittance of any person beyond the approved occupant load. The fire official, upon finding overcrowded conditions or obstructions in aisles, passageways or other means of egress, or upon finding any condition which constitutes a hazard to life and safety, shall cause the occupancy, performance, presentation, spectacle or entertainment to be stopped until such a condition or obstruction is corrected and the addition of any further occupants prohibited until the approved occupant load is reestablished.”

xv. In Section 1003.6, Means of egress continuity, the text of the section shall be deleted and the following

shall be inserted, “Operator responsibility. The operator or the person responsible for the operation of an assembly or educational occupancy shall check egress facilities before such building is occupied to determine compliance with this chapter. If such inspection reveals that any element of the required means of egress cannot be accessed, is obstructed, locked, fastened or otherwise unsuited for immediate utilization, admittance to the building shall not be permitted until necessary corrective action has been completed.”

xvi. Section 1003.7, Elevators, escalators and moving walks, shall be deleted in its entirety.

xvii. Section 1004, Occupant Load, shall be deleted in its entirety.

xviii. Section 1005, Egress Width, shall be deleted in its entirety.

xvix. In Section 1006.1, Illumination required, Exceptions, “in Groups R-1, R-2 and R-3 of 3. and 4. Sleeping units of Group I occupancies” shall be deleted.

xx. In Section 1006, Means of Egress Illumination, the following sections shall be deleted in their entirety: Section 1006.2, Illumination level, Section 1006.3, Illumination emergency power, Section 1006.4, Performance of system.

xxi. Section 1007, Accessible Means of Egress, shall be deleted in its entirety.

xxii. Section 1008.1, Doors, the following shall be deleted, “Means of egress doors shall meet the requirements of this section. Doors serving a means of egress section shall meet the requirements of this section and Section 1017.2.”

xxiii. In Section 1008, Doors, Gates and Turnstiles, the following sections shall be deleted in their entirety, Section 1008.1.1, Size of doors; Section 1008.1.1.1, Projections into clear width; Section 1008.1.2, Door swing; Section 1008.1.3, Special doors; Section 1008.1.3.1, Revolving doors, Table 1008.1.3.1, Revolving door speeds; Section 1008.1.3.1.1, Egress component; Section 1008.1.3.1.2, Other than egress components; Section 1008.1.3.2, Power operated doors; Section 1008.1.3.3, Horizontal sliding doors; and 1008.1.3.4, Access controlled egress doors.

xxiv. Section 1008.1.3.5, Security grilles, the following text shall be deleted, “In Groups B, F, M and S,” and “Where two or more means of egress are required, not more than one half of the exits or exit access doorways shall be equipped with horizontal sliding or vertical security grilles.”

xxv. In Section 1008, Doors, Gates and Turnstiles, the following sections shall be deleted in their entirety: Section 1008.1.4, Floor elevation; Section 1008.1.5,

Landings at doors; Section 1008.1.6, Thresholds; and Section 1008.1.7, Door arrangement.

xxvi. In Section 1008.1.8, Door operations, "Except as specifically permitted by this section" shall be deleted.

xxvii. Section 1008.1.8.2, Hardware height shall be deleted in its entirety.

xxviii. New Section 1008.4, Locks permitted, shall be inserted as follows, "Locks permitted. Locks or fasteners shall not be installed on egress doors, except in accordance with the following conditions:

1. In mental, penal or other institutions where the security of inmates is necessary, in which case properly trained supervisory personnel shall be continuously on duty and approved provisions shall be made to remove occupants safely in case of a fire or other emergencies.

2. In problem security areas, special-purpose door alarms or locking devices shall be approved prior to installation. Manually operated edge or surface-molded flush bolts shall be prohibited.

3. Where the door hardware is in compliance with the Uniform Construction Code."

xxvix. New Section 1008.5. Special performance features, shall be inserted as follows, "Special performance features. All hardware systems or assemblies utilized in the operation of a door, including special performance features, shall be inspected for proper operation. The inspection shall determine that the hardware operates as required by this code."

xxx. New Section 1008.6, Panic hardware, shall be inserted as follows, "Panic hardware. All doors equipped with latching devices serving rooms or spaces with an assembly or educational occupancy with an occupant load greater than 100 shall have the approved panic hardware maintained in compliance with the construction code in effect at the time of first occupancy."

xxxi. New Section 1008.7, Closing, shall be inserted as follows "Closing. All fire doors shall comply with Section 703."

xxxii. The following sections shall be deleted in their entirety: Section 1008.1.8.3 Locks and latches; Section 1008.1.8.5, Unlatching; and Section 1008.1.8.6 Delayed egress locks.

xxxiii. In Section 1008.1.8.7, Stairway doors, Exception 2 "the International Building Code" shall be deleted and "the building subcode of the Uniform Construction Code" shall be inserted.

xxxiv. In Section 1008, Doors, Gates and Turnstiles, the following sections shall be deleted in their entirety: Section 1008.1.9, Panic and fire exit hardware; Section

1008.2, Gates; Section 1008.2.1, Stadiums; Section 1008.3, Turnstiles; Section 1008.3.1, High turnstile; and Section 1008.3.2, Additional door.

xxxv. In Section 1009, Stairways, the following sections shall be deleted in their entirety: Section 1009.1, Stairway width; Section 1009.2, Headroom; Section 1009.3, Stair treads and risers; Section 1009.3.1, Winder treads; Section 1009.3.3, Profile; Section 1009.4, Stairway landings; Section 1009.5, Stairway construction; Section 1009.5.2, Outdoor conditions; Section 1009.5.3, Enclosures under stairways; Section 1009.6, Vertical rise; Section 1009.7, Curved stairways; Section 1009.8, Spiral stairways; Section 1009.9, Alternating tread devices; Section 1009.9.1, Handrails of alternating tread devices; Section 1009.9.2, Treads of alternating tread devices; Section 1009.10, Handrails; Section 1009.11, Stairway to roof; Section 1009.11.1, Roof access; and Section 1009.11.2, Protection at roof hatch openings.

xxxvi. In Section 1010, Ramps, the following sections shall be deleted in their entirety: Section 1010.1, Scope; Section 1010.2, Slope; Section 1010.3, Cross slope; Section 1010.4, Vertical rise; Section 1010.5, Minimum dimensions; Section 1010.5.1, Width; Section 1010.5.2, Headroom; Section 1010.5.3, Restrictions; Section 1010.6, Landings; Section 1010.6.1, Slope; Section 1010.6.2, Width; Section 1010.6.3, Length; Section 1010.6.4, Change in direction; Section 1010.6.5, Doorways; Section 1010.7, Ramp construction; Section 1010.7.1, Ramp surface; Section 1010.7.2, Outdoor conditions; Section 1010.8, Handrails; Section 1010.9, Edge protection; Section 1010.9.1, Curb, rail, wall or barrier; Section 1010.9.2, Extended floor or ground surface; and Section 1010.10, Guards.

xxxvii. In Section 1011.1, Where required, the text of the section shall be deleted and the following shall be inserted, "Exit signs. All means of egress shall be indicated with approved "Exit" signs where required by the construction code in effect at the time of first occupancy or N.J.A.C. 5:70-4 et seq., as applicable. All "Exit" signs shall be maintained visible, and all illuminated exit signs shall be illuminated at all times the structure is occupied. Supplemental internally illuminated directional signs, when necessary, shall be installed in accordance with the technical requirements of the Uniform Construction Code indicating the direction and way of egress."

xxxviii. In Section 1011.2, Illumination, the text of the section shall be deleted and the following shall be inserted, "Information signs. A sign shall be provided at each floor landing in all interior stairways more than three stories above grade, designating the floor level above the floor of discharge. All elevator lobby call stations on all floor levels shall be identified by approved signs in accordance with the requirements for new buildings in the Uniform Construction Code. Exception: The emergency sign shall not be required for

xxiv. 2404.16.1, General, “International Fuel Gas Code” shall be deleted and “fuel gas subcode of the Uniform Construction Code” shall be inserted.

xxv. In Section 2404.16.2, Location of containers, in the first sentence, “or on the exterior perimeter of a canopy” shall be inserted after “outside.”

xxvi. Section 2404.16.2.1, “Containers 500 gallons or less, The following text shall be deleted “500 gallons or less. Portable LP gas containers with a capacity of 500 gallons (1893 L) or less shall have a minimum separation between the container and structure not less than 10 feet (3048 mm).” The following text shall be inserted after “Containers,” “LP-gas containers shall be located a minimum of 5 feet from any heat producing appliance.”

xxvii. Section 2404.16.2.2 shall be deleted.

xxviii. In Section 2404.21, Vegetation removal, “30 feet (9144 mm)” shall be deleted and “20 feet” shall be inserted.

xxix. In Section 2404.22, Waste material, in the first sentence, “30 foot (9144 mm)” shall be deleted and “20 foot” shall be inserted.

25. Chapter 25, Tire Rebuilding and Tire Storage, shall be amended as follows:

i. Section 2501.2, Permits, shall be deleted in its entirety.

ii. In Section 2503.1, Construction, “the International Building Code” shall be deleted and “the construction code in effect at the time of construction” shall be inserted.

26. Chapter 26, Welding and Other Hot Work, shall be amended as follows:

i. Section 2601.2, Permits, shall be deleted in its entirety.

ii. In Section 2602, Definitions, the definition of “hot work permits” shall be deleted in its entirety. In the definition of “hot work program,” in the first sentence, “permitted” shall be deleted before “program,” “and issue permits for” shall be deleted before “hot work,” and “or” shall be deleted after “personnel.” In addition, in the definition of “responsible person,” in the second sentence, “permits” shall be deleted and “approvals” shall be inserted and “permit” shall be deleted before “program.”

iii. In Section 2603.1, General, “and NFPA 51B” shall be inserted at the end of the sentence after “chapter.”

iv. In the title of Section 2603.3, “permit” shall be deleted. In addition, the text of the definition shall be deleted and the following shall be inserted: “Hot work approvals issued by a responsible person under a hot

work program shall be available for review by the fire official at the time the work is conducted and for 48 hours after the work is complete.”

v. In Section 2603.4, Qualifications of operators, in the first sentence, “A permit” shall be deleted. The sentence shall begin with “Approval.”

vi. In Section 2604.3, Area reviews, at the end of the second sentence, “in accordance with Section 105.6” shall be deleted.

vii. In Section 2606.4, Emergency disconnect, in the second sentence, “the ICC Electrical Code” shall be deleted and “the electrical subcode of the Uniform Construction Code” shall be inserted.

27. Chapter 27, Hazardous Materials—General Provisions, shall be amended as follows:

i. Section 2701.1.1, Waiver, shall be deleted in its entirety.

ii. In Section 2701.2.2.2, Health hazards, new Item 3 shall be inserted as follows: “3. Radioactive materials.”

iii. In Section 2701.5, Permits, “Sections 105.6 and 105.7” shall be deleted and “Subchapter 2 of the Uniform Fire Code” shall be inserted.

iv. In Section 2701.5.1, Hazardous Materials Management Plan, in the first sentence, “or life hazard use registration” shall be inserted after “permit.”

v. In Section 2701.5.2, Hazardous Materials Inventory Statement (HMIS), in the first sentence, “or life hazard use registration” shall be inserted after “permit.”

vi. In Section 2701.6.2, Permanently out-of-service facilities, in the first sentence, “required” shall be inserted before “permit” and “or life hazard use registration” shall be inserted after “permit.” In addition, in the second sentence, “and life hazard use facilities” shall be inserted after “permittees.”

vii. In Section 2702, Definitions, a definition for “radioactive material” shall be inserted as follows: “Radioactive Material. Any material or combination of materials that spontaneously emit ionizing radiation.”

viii. In Table 2703.1.1(1), Maximum allowable quantity per control area of hazardous materials posing a physical hazard, in footnotes p.3 and p.4, “International Fuel Gas Code” and “International Mechanical Code” shall be deleted and “fuel gas subcode of the Uniform Construction Code” and “mechanical subcode of the Uniform Construction Code,” respectively, shall be inserted.

ix. In Table 2703.1.1(2), Maximum Allowable Quantity per Control Area of Hazardous Materials Posing a Health Hazard^{a,b,c,j}, and Table 2703.1.1(4),

Maximum Allowable Quantity per Control Area of Hazardous Materials Posing a Health Hazard in an Outdoor Control Area^{a,b,c}, the following text shall be inserted as the fourth row of table 2703.1.1(2) under “Material,” “Storage^d,” “Use-Closed Systems^d,” and Use-Open Systems^d” Add footnote “k. Maximum dosage allowed in any single whole-body short term (1 hour or

less) exposure.” the following text shall be inserted as the fourth row of table 2703.1.1(4) under “Material,” “Storage,” “Use-Closed Systems,” and Use-Open Systems” Add footnote “h. Maximum dosage allowed in any single whole-body short term (1 hour or less) exposure.”

TABLE 2703.1.1(2)

MATERIAL	STORAGE SYSTEM ^d	USE-CLOSED SYSTEM ^d	USE-OPEN SYSTEM ^d
“Radioactive ^k ”	25 REM unsealed source 100 REM sealed source	100 REM sealed source	25 REM sealed source

k. Maximum dosage allowed in any single whole body short term (1 hour or less) exposure.”

TABLE 2703.1.1(4)

MATERIAL	STORAGE SYSTEM	USE-CLOSED SYSTEM	USE-OPEN SYSTEM
“Radioactive ^h ”	25 REM unsealed source 100 REM sealed source	100 REM sealed source	25 REM sealed source

h. Maximum dosage allowed in any single whole body short term (1 hour or less) exposure.”

x. In Section 2703.2.8, Seismic protection, “the International Building Code” shall be deleted and “the building subcode of the Uniform Construction Code” shall be inserted.

xi. In Section 2703.7.3, Industrial Trucks, “ICC Electrical Code” shall be deleted and “electrical subcode of the Uniform Construction Code” shall be inserted.

xii. In Section 2703.8.1, Buildings, in the first sentence, “maintained as” shall be inserted before “constructed.” In addition, “International Building Code” shall be deleted and “building subcode of the Uniform Construction Code” shall be inserted.

xiii. In Section 2703.8.3.1, Construction requirements, “maintained as” shall be inserted before “separated.” In the same section, “Section 706 of the International Building Code” shall be deleted and “the building subcode of the Uniform Construction Code” shall be inserted. In addition, “Section 711 of the International Building Code” shall be deleted and “the building subcode of the Uniform Construction Code” shall be inserted.

xiv. In Section 2703.8.3.2, Percentage of maximum allowable quantities, “Table 2703.8.3.2” shall be deleted and “the Uniform Construction Code” shall be inserted.

xv. In Section 2703.8.3.3, Number, “Table 2703.8.3.2” shall be deleted and “the Uniform Construction Code” shall be inserted.

xvi. In Section 2703.8.3.4, Fire-resistance rating requirements, in the first sentence, “Table 2703.8.3.2” shall be deleted and “the Uniform Construction Code” shall be inserted. In addition, the second sentence and the exception shall be deleted in their entirety.

xvii. In Section 2703.8.4.1, Construction, in the second sentence, “the International Building Code based on the occupancy group into which it has been classified” shall be deleted and “building subcode of the Uniform Construction Code” shall be inserted.

xviii. In Section 2703.8.4.2, Ventilation system, in the second sentence, “the International Mechanical Code” shall be deleted and “the mechanical subcode of the Uniform Construction Code” shall be inserted.

xvix. In Section 2703.8.5.2, Ventilation, in the third sentence, “the International Mechanical Code” shall be deleted and “the mechanical subcode of the Uniform Construction Code” shall be inserted.

xx. In Section 2703.8.6.2, Ventilation, in the third sentence, “the International Mechanical Code” shall be deleted and “the mechanical subcode of the Uniform Construction Code” shall be inserted.

xxi. In Section 2703.8.7.1, Construction, “ICC Electrical Code” shall be deleted and “electrical subcode of the Uniform Construction Code” shall be inserted.

xxii. In Section 2703.9.4, Electrical wiring and equipment, “the ICC Electrical Code” shall be deleted and “the electrical subcode of the Uniform Construction Code” shall be inserted.

xxiii. In Section 2703.9.5, Static accumulation, after “charge,” “in accordance with NFPA 77” shall be inserted at the end of the sentence.

xxiv. In Section 2703.9.9, Shelf storage, in the first sentence, “the International Building Code” shall be deleted and “the building subcode of the Uniform Construction Code” shall be inserted.