

i. Exception: If verification of the installation of an excess flow valve is provided by the gas utility, vehicle impact barriers shall not be required.

12. Where work, other than ordinary maintenance or minor work, is being performed on an elevator, the elevator shall be equipped to operate with a standardized fire service key.

(f) In buildings of Groups I-1, R-1, R-2, R-3, R-4 or R-5 containing a fuel burning appliance or having an attached garage, carbon monoxide alarms shall be installed in accordance with the mechanical subcode. (Fire)

(g) All materials and methods used shall comply with the requirements specified in N.J.A.C. 5:23-6.8, Materials and methods.

1. For repair work undertaken as part of a reconstruction project, materials like those existing may be used. There is no limit to the amount of repair work which may be undertaken.

2. Exception: Windows may be replaced with windows like those existing without meeting the size requirements of the building subcode.

i. In sleeping rooms below the fourth story in occupancies of Groups R or I-1, where new window openings are being created or the size of window openings is being changed, at least one window shall:

(1) Be operable;

(2) Have a sill height of not more than 44 inches;

(3) Have a width of at least 20 inches, a height of at least 24 inches and a minimum total area of 5.7 square feet measured from head to sill and from side to side.

(4) New window openings in sleeping rooms shall not be required to meet these requirements in buildings where the sleeping room is provided with a door to a corridor having access to two remote exits or in buildings equipped throughout with an automatic sprinkler system.

ii. Basement windows in buildings of Group R-2 shall comply with the requirements of N.J.A.C. 5:23-6.26(b)3 where the window serves as the second means of egress from the dwelling unit.

3. Replacement handrails and guardrails shall comply with Sections 1003.3.3.11, 1003.3.4.7 and 1003.2.12 of the building subcode, respectively. Where 50 percent or more of a handrail or guardrail on a flight or on a level is replaced, then this shall be considered a complete replacement and shall comply with the referenced sections of the building subcode. The repair or replacement of less than 50 percent of a handrail or guardrail shall be permitted to match the existing handrail or guardrail. (Building)

(h) All new building elements, as listed in N.J.A.C. 5:23-6.9, shall comply with the requirements of that section.

(i) The basic requirements of this subchapter for the applicable group shall be met within the work area(s). Attendant work outside the work area(s) shall not make the building less conforming with the basic requirements than it was when the reconstruction was undertaken.

1. Where the building currently exceeds the basic requirements, the extent to which it exceeds shall not be reduced unless the building also exceeds the requirements of the corresponding subcode of the UCC. In this case, the extent of compliance with the basic requirements may be reduced, but not below the requirements of the corresponding subcode of the UCC. Existing fire alarm, automatic sprinkler and standpipe systems shall not be removed without replacement and shall be maintained in operating condition.

(j) The supplemental requirements of this subchapter for the applicable group shall be met wherever the extent of the work is such that the trigger accompanying each requirement is met or exceeded.

(k) In a building required by the barrier free subcode to be accessible, where the space reconstructed is a primary function space, an accessible path of travel to the space shall be provided up to the point at which the cost of providing accessibility is disproportionate to the cost of the overall project; a cost is disproportionate if it exceeds 20 percent of the cost of the work. (Building)

1. The accessible path of travel shall include, but not be limited to, an accessible parking space, an accessible exterior route, an accessible building entrance, an accessible interior route to the reconstructed area, accessible restrooms, accessible drinking fountains, and accessible telephones serving the reconstructed primary function space. Priority shall be given to providing an accessible entrance or accessible restrooms where possible.

2. In determining disproportionate cost, the following materials may be deducted from the overall cost of the project:

i. Windows, hardware, operating controls, electrical outlets and signage;

ii. Mechanical systems, electrical systems, installations or alterations of fire protection systems or abatement of hazardous materials; or

iii. The repair or installation of roofing, siding, or other exterior wall facade.

3. Where the work consists solely of the reconstruction of materials or systems listed in (k)2 above, the path of travel requirements shall not apply.

4. Where the work is for the primary purpose of increasing the accessibility of the building or tenancy, the

requirement to further improve the path of travel shall not apply.

5. Where it is technically infeasible to comply with the technical standards of ICC/ANSI A117.1-1998, the work must comply to the maximum extent feasible.

Amended by R.2000 d.492, effective December 18, 2000.

See: 32 N.J.R. 3219(a), 32 N.J.R. 4437(b).

In (c), rewrote 2 and added 4; in (d), added 5; in (e), amended the N.J.A.C. reference in 5, rewrote 8iii, and substituted "Section 250-140" for "Section 250-60" in 8v.

Amended by R.2002 d.5, effective January 7, 2002.

See: 33 N.J.R. 3392(a), 34 N.J.R. 267(a).

In (d), added new 6; in (e), added new 11.

Amended by R.2003 d.137, effective April 7, 2003.

See: 34 N.J.R. 4277(a), 35 N.J.R. 1558(c).

Deleted (e)11; added a new (f); recodified former (f) through (j) as (g) through (k).

Amended by R.2003 d.218, effective May 19, 2003.

See: 35 N.J.R. 29(a), 35 N.J.R. 2209(a).

Rewrote the section.

Administrative correction.

See: 35 N.J.R. 4861(a).

Amended by R.2004 d.145, effective April 5, 2004.

See: 35 N.J.R. 5190(a), 36 N.J.R. 1758(a).

Deleted references to use preceding references to group throughout and substituted references to automatic sprinkler for references to fire suppression throughout; in (g)2ii, amended the N.J.A.C. reference.

Amended by R.2004 d.468, effective December 20, 2004.

See: 36 N.J.R. 1858(b), 36 N.J.R. 5711(a).

In (e), added 11.

Amended by R.2005 d.4, effective January 3, 2005.

See: 36 N.J.R. 4049(a), 37 N.J.R. 47(a).

Added (e)12.

5:23-6.8 Materials and methods

(a) The following requirements shall be met for materials and installation methods for all items that are part of the applicant's proposed project for all categories of work other than repair as defined in N.J.A.C. 5:23-6.3.

1. Where sections listed below reference other sections not listed below, those sections shall apply within that limited context.

(b) Building and Fire Protection Materials and Methods: The following sections of the building subcode (N.J.A.C. 5:23-3.14) shall constitute the building and fire protection materials and methods requirement for this subchapter:

1. The following sections of Chapter 5 entitled "General Building Height and Areas":

i. Section 505 shall apply to newly constructed "Mezzanines";

2. The following sections of Chapter 7 entitled "Fire-Resistance-Rated Construction":

i. Subsections 703.2, 703.3, 703.4;

ii. Subsection 704.2.1, 704.2.2, 704.2.3, 704.4, 704.13, 704.14;

iii. Subsections 705.3, 705.8, 705.9, 705.10, 705.11;

iv. Section 706.6, 706.7, 706.8, 706.9;

v. Section 707.7, 707.8, 707.9, 707.10, 707.13.2;

vi. Subsections 708.2, 708.6, 708.7, 708.8, 708.9;

vii. Subsections 709.2, 709.5, 709.6, 709.7, 709.8;

viii. Subsections 710.2, 710.5, 710.6, 710.7;

ix. Section 711;

x. Section 712;

xi. Subsections 714.2.5, 714.2.6, 714.2.7, 714.2.8, 714.2.9, 714.3.1, 714.3.2, 714.3.3, 714.3.4, 714.3.5, 714.3.6, 714.3.8, 714.3.9;

xii. Subsections 715.2, 715.3, 715.4, 715.7;

xiii. Subsections 716.2.1, 716.3.1;

xiv. Subsections 717.2, 717.4, 717.5;

xv. Section 718;

xvi. Section 719; and

xvii. Section 720;

3. All of Chapter 8 entitled "Interior Finishes" except 802;

4. All of Chapter 9 entitled "Fire Protection Systems" except 901, 902, 903.2, 904.2, 905.3, 906.2, 908.1, 908.2, 910.2, 911;

5. The following sections of Chapter 10 entitled "Means of Egress":

i. Subsection 1003.2.10.2, 1003.2.10.4, 1003.2.10.5;

ii. Subsections 1003.2.12.1, 1003.12.2;

iii. Subsections 1003.3.1.3.1, 1003.3.1.3.2, 1003.3.1.3.3, 1003.3.1.3.4, 1003.3.1.3.5, 1003.3.1.8; and

iv. Subsections 1003.3.3.11.1, 1003.3.3.11.2, 1003.3.3.11.3, 1003.3.3.11.4, 1003.3.3.11.5, 1003.3.3.11.6;

6. The following sections of Chapter 12 entitled "Interior Environment":

i. Section 1202.4.2 shall apply to new sources of contaminants; and

ii. Section 1209;

7. All of Chapter 14 entitled "Exterior Walls" except 1401, 1402, 1403.2;

8. All of Chapter 15 entitled "Roof Assemblies and Rooftop Structures" except 1501.1, 1502.0, 1503.4, 1503.5;

9. All of Chapter 16 entitled "Structural Design," except 1601, 1604, 1608, 1609, 1610, 1611, 1612, 1614, shall apply to new or replaced structural members. The referenced sections of Chapter 16 shall not be used to analyze any existing structural members, except as otherwise provided by this subcode;

10. All of Chapter 18 entitled "Soil and Foundations" except section 1801, 1802, 1803, 1804, 1805, 1806;

i. Additionally, the following section of 1806 shall be included as part of Material and Methods: 1806.2.1, 1806.2.2, 1806.3.1, 1806.3.2, 1806.3.3, 1806.4.1, 1806.4.2, 1806.4.3;

11. All of Chapter 19 entitled "Concrete" except 1901, 1092;

12. All of Chapter 20 entitled "Aluminum";

13. All of Chapter 21 entitled "Masonry";

14. All of Chapter 22 entitled "Steel";

15. All of Chapter 23 entitled "Wood";

16. All of Chapter 24 entitled "Glass and Glazing";

17. All of Chapter 25 entitled "Gypsum Board and Plaster";

18. All of Chapter 26 entitled "Plastic"; and

19. For the applicability of Chapter 30 entitled "Elevators and Conveying Systems," refer to (g) below, Elevator Devices.

(c) Plumbing Materials and Methods: The following sections of the plumbing subcode (N.J.A.C. 5:23-3.15) shall constitute the plumbing material and method requirements for this subchapter:

1. All of Chapter 2 entitled "General Regulations" except 2.19 and 2.24:

i. Section 2.19 for mandatory connections to the public water supply and sewer shall apply when existing septic or water supply facilities are no longer suitable for use as determined by the local health inspector, and public facilities are available within the meaning of 2.19.

2. All of Chapter 3 entitled "Materials."

3. All of Chapter 4 entitled "Joints and Connections."

4. All of Chapter 5, entitled "Traps, cleanouts and backwater valves."

5. Chapter 6, entitled "Interceptors" except sections 6.1.1, 6.1.7, 6.3.1 and 6.4.1:

i. Section 6.1.1, 6.3.1, 6.4.1 for when interceptors are required shall not apply. However, when new fixtures, or devices are installed that will produce wastes that need to be separated, an interceptor shall be required.

6. Chapter 7, entitled "Plumbing Fixtures, Fixture Fittings and Plumbing Appliances" except section 7.21 and table 7.21.1.

7. Chapter 8 entitled "Hangers and Supports."

8. Chapter 9 entitled "Indirect Wastes Piping and Special Waste."

9. Chapter 10 entitled "Water Supply and Distribution" except for sections 10.3, 10.6.5, 10.8.1, 10.14 and 10.15.9:

i. Water shall be supplied so that fixtures within a building are provided with an adequate supply of water so that they are functional.

ii. Section 10.6.5 shall apply to all newly-installed or completely replaced water services.

iii. Section 10.8.1 shall apply, where there is not sufficient pressure for proper functioning of fixtures, a water pressure booster system shall be required.

iv. Section 10.14 for sizing water distribution systems shall apply when the proposed work will impose additional loads on the system. Where the proposed work does not increase or decreases the load on the existing system, no increase in size shall be required. All new piping associated with the installation of additional fixtures shall comply with the sizing requirements of Chapter 10.

10. All of Chapter 11, entitled "Sanitary Drainage Systems" except 11.2.2, 11.2.3, 11.5, and 11.6:

i. Section 11.2.3 for sizing building sewers shall apply when the proposed work will impose additional loads on the sewer. Where the proposed work does not increase or decreases the load on the existing system, no increase in size shall be required.

ii. Section 11.5 for sizing drainage systems shall apply when the proposed work will impose additional loads on the system. Where the proposed work does not increase or decreases the load on the existing system, no increase in size shall be required. All new piping associated with the installation of additional fixtures shall comply with the sizing requirements of 11.5.

iii. Section 11.6 for sizing offsets in drainage systems shall apply when the proposed work will impose additional loads on the system. Where the proposed work does not increase or decreases the load on the existing system, no increase in size shall be required.

11. All of Chapter 12, entitled "Vents and Venting" except 12.3.1, 12.3.2 and 12.16:

i. Section 12.3.1 for locations where vent stacks are required shall apply where new stacks are being installed;

ii. Section 12.3.2 "Relief Vents for Stacks having Ten or More Branch Intervals" shall apply only when new stacks of ten or more branch intervals are being installed; and

iii. Section 12.16 for size and length of vents shall apply when new vents are being installed.

12. All of Chapter 13 entitled "Storm Water Drainage" except 13.1.1, 13.1.2, 13.1.6, 13.1.7, 13.1.10.1, 13.4.3, 13.6.1, 13.6.2:

i. Section 13.1.1 for where storm water drains are required shall apply only when new roofs, paved areas, yards, courts and courtyards are created.

ii. Section 13.1.2 "Storm Water Drainage to Sewer Prohibited" shall not be applied to existing connections to the sewer. This section shall only prohibit the connection of new storm water drains to a sanitary sewer that is prohibited from accepting such discharge.

iii. Section 13.1.6 "Areaway Drains" shall apply only to newly created, open, below grade areaways where storm water can accumulate.

iv. Section 13.1.7 "Window Well Drains" shall apply only to newly created window wells.

v. Section 13.1.10.1 for sizing roof drains, as amended in N.J.A.C. 5:23-3.15, shall apply only where additional roof area is to be drained or where other circumstances increase the load on existing roof drains.

vi. Section 13.4.3 "Combining Storm with Sanitary Drainage" shall not be applied to existing connections to the sewer. This section shall only require that newly installed sanitary and storm sewers be separate.

vii. Section 13.6.1 for sizing of "Vertical Conductors and Leaders" shall only apply when the proposed work will impose additional loads on the system. Where the proposed work does not increase or decreases the load on the existing system, no increase in size shall be required.

viii. Section 13.6.2 "Size of Horizontal Storm Drain Piping" shall only apply when the proposed work will impose additional loads on the system. Where the proposed work does not increase or decreases the load on the system, no increase in size shall be required.

13. All of Chapter 14 entitled "Special Requirements For Health Care Facilities."

14. All of Chapter 15 entitled "Tests and Maintenance."

15. Section 16.1.7 of Chapter 16 entitled "Regulations Governing Individual Sewage Disposal Systems for Homes and Other Establishments Where Public Sewage Systems Are Not Available."

16. All of Chapter 18 entitled, "Mobile Homes & Travel Trailer Park Plumbing Standards."

(d) Electrical Materials and Methods. The following sections of the electrical subcode (N.J.A.C. 5:23-3.16) shall constitute the electrical materials and methods requirements for this subchapter:

1. Section 90.7, entitled "Examination of Equipment for Safety" of the Introduction, Article 90;

2. All of Chapter 1 entitled "General" except Sections 110.8 Wiring Methods, 110.26 Spaces About Electrical Equipment (600 Volts, Nominal, or less), 110.32 Work Space About Equipment (over 600 Volts, Nominal) and 110.33 Entrance and Access to Work Space;

3. All of Chapter 2 entitled "Wiring and Protection" except Sections 210.52 Dwelling Unit Receptacle Outlets, 210.60 Guest Rooms, 210.62 Show Windows, 210.63 Heating, Air Conditioning, and Refrigeration Equipment Outlet, 210.70 Lighting Outlets Required and 210.11 Branch Circuits Required;

4. All of Chapter 3 entitled "Wiring Methods";

5. All of Chapter 4, entitled "Equipment for General Use" except Section 404.8 Accessibility and Grouping (switches) and Section 408.8 Clearances (switchboards and panelboards);

6. All of Chapter 5, entitled "Special Occupancies;"

7. All of Chapter 6, entitled "Special Equipment;"

8. All of Chapter 7, entitled "Special Conditions;" and

9. All of Chapter 8 entitled "Communications Systems."

10. Existing working clearances, clear space, access and entrance dimensions to working spaces, illumination, headroom clearances, and location of overcurrent protection devices shall be allowed to remain without modification.

(e) Mechanical Materials and Methods: The following sections of the mechanical subcode (N.J.A.C. 5:23-3.20) shall constitute the mechanical materials and methods requirements for this subchapter:

1. All of Chapter 3, entitled "General Regulations" except 301.2, 301.7, 301.8, 301.13, 301.16, 303.5, 303.6, 303.7, 306, 307.2.3, 309 and 312;

2. All of Chapter 4, entitled "Ventilation" except 402 and 403;

3. All of Chapter 5, entitled "Exhaust Systems" except 502, 509, 510, and 513;

i. Section 509 shall apply to newly installed or replaced commercial food heat-processing appliances and Type I hoods;

ii. Section 510 shall apply to newly introduced sources of hazardous exhaust;

4. All of Chapter 6, entitled "Duct Systems" except 602 and 604;

i. Section 602 shall apply to newly-constructed plenums. Modifications to existing plenums, such as installation of new building, electrical or plumbing materials inside the plenum, increasing air flow rate within the plenum, etc. shall not require the plenum to comply with the construction requirements for new plenums. However, newly-installed materials within the plenum shall be consistent with material requirements of 602;

5. All of Chapter 7, entitled "Combustion Air";

6. All of Chapter 8, entitled "Chimneys and Vents";

7. All of Chapter 9, entitled "Specific Appliances, Fireplaces and Solid Fuel-Burning Equipment";

8. All of Chapter 10, entitled "Boiler, Water Heaters and Pressure Vessels";

9. All of Chapter 11, entitled "Refrigeration";

10. All of Chapter 12, entitled "Hydronic Piping" except 1204;

11. All of Chapter 13, entitled "Fuel Oil Piping and Storage" except 1305.1;

i. Section 1305.1 shall apply when the work being performed increases the load on the system such that the existing pipe does not meet the size required by code. Existing systems that are modified shall not require resizing as long as the load on the system is not increased and the system length is not increased even if the altered system does not meet code minimums; and

12. All of Chapter 14, entitled "Solar Systems."

(f) Fuel Gas Materials and Methods: The following sections of the fuel gas subcode (N.J.A.C. 5:23-3.22) shall constitute the fuel gas materials and methods requirements for this subchapter:

1. All of Chapter 3, entitled "General Regulations" except 301.2, 301.6, 301.11, 301.12, 303.7, and 306;

2. All of Chapter 4, entitled "Gas Piping Installations" except 401.8 and 402.3;

i. Sections 401.8 and 402.3 shall apply when the work being performed increases the load on the system such that the existing pipe does not meet the size required by code. Existing systems that are modified shall not require resizing as long as the load on the system is not increased and the system length is not increased even if the altered system does not meet code minimums;

3. All of Chapter 5, entitled "Chimneys and Vents"; and

4. All of Chapter 6, entitled "Specific Appliances."

(g) Barrier Free Materials and Methods: The requirements of ICC/ANSI A117.1-1998 shall constitute the barrier free materials and methods requirements for this subchapter

and shall apply to work projects in all buildings other than buildings of Group R-2, R-3, R-4 or R-5 containing fewer than four dwelling units or buildings of Group U.

1. Exception: Where full compliance is technically infeasible, compliance shall be achieved to the maximum extent feasible.

2. For toilet or bathing facilities, at least one of each type of fixture shall be accessible. Where six or more toilet stalls are provided, in addition to a wheelchair accessible stall, at least one ambulatory accessible stall shall be provided.

i. Exception: Nonpublic toilet rooms for individual use may be adaptable.

3. Limited exceptions to the accessibility requirements for theatres and auditoriums are permitted as follows:

i. Where fixed seating is provided and it is technically infeasible to provide integrated accessible seating, accessible seating may be clustered.

ii. When a facility contains more than one performing area and it is technically infeasible to make all performing areas accessible, the provision of one accessible performing area shall be accepted as meeting the requirement for providing access to performing areas.

4. In buildings of Group M, where fitting room partitions are installed or moved, five percent of the fitting rooms, but not less than one, shall comply.

(h) Residential Materials and Methods: The following sections of the residential subcode (N.J.A.C. 5:23-3.21) shall constitute the residential materials and methods requirements for this subchapter:

1. The following sections of Chapter 3, entitled "Building Planning";

i. Section 307.2;

ii. Section 308;

iii. Section 318;

iv. Section 320;

v. Section 323; and

vi. Section 324;

2. The following sections of Chapter 4 entitled "Foundations":

i. Section 402; and

ii. Section 407;

3. The following sections of Chapter 5 entitled "Floors":

i. Sections 502.1, 502.8, 502.11, 502.12.1;

ii. Sections 503.2.1, 503.2.3, 503.3.1, 503.3.3;

- iii. Sections 504.1, 504.3; and
- iv. Sections 505.2.1, 505.2.2, 505.2.3, 505.2.4, 505.3.5, 505.3.6;
- 4. The following sections of Chapter 6 entitled "Wall Construction":
 - i. Sections 602.1, 602.2, 602.6, 602.8.1;
 - ii. Sections 603.2.1, 603.2.2, 603.2.3, 603.2.4, 603.3.4, 603.3.5;
 - iii. Sections 604.1, 604.3;
 - iv. Section 605;
 - v. Section 606.1, 606.14;
 - vi. Section 607.1;
 - vii. Section 608.1;
 - viii. Section 609.1;
 - ix. Sections 610.1, 610.2, 610.3;
 - x. Section 611.1;
 - xi. Section 612.1; and
 - xii. Section 613.1;
- 5. All of Chapter 7 entitled "Wall Covering";
- 6. The following sections of Chapter 8, entitled "Roof-Ceiling Construction":
 - i. Section 802.1, 802.7, 802.10;
 - ii. Section 803.2.1;
 - iii. Sections 804.2.1, 804.2.2, 804.2.3, 802.2.4, 804.3.5, 804.3.6; and
 - iv. Section 805.1;
- 7. The following sections of Chapter 9 entitled "Roof Assemblies":
 - i. Section 902.1;
 - ii. Section 903.1;
 - iii. Section 904;
 - iv. Section 905;
 - v. Section 906; and
 - vi. Section 907; and
- 8. All of Chapter 10 entitled "Chimneys and Fireplaces."
 - (i) Elevator Devices Materials and Methods: The following sections of the elevator subcode (N.J.A.C. 5:23-12) shall constitute the elevator device materials and methods requirements for this subchapter:
 - 1. All of ASME A17.1 Part XII except Section 1206 as referenced by the adopted building subcode.

2. The following sections of Chapter 30 of the building subcode: Section 3002.1.2—"Hoistway Enclosures, Hardware" and Section 3005.3—"Conveying Systems, Conveyors."

3. The requirements of ASME A17.1 Rule 102.2(c)4, as referenced by the adopted building subcode, when an automatic sprinkler system is provided in an elevator hoistway, machine room and/or machinery space.

(j) Manufactured Home Materials and Methods: The following sections of the manufactured home subcode (N.J.A.C. 5:23-3.19) shall constitute the manufactured home materials and methods requirements for this subcode:

1. All of Part 3280 of Title 24 of the Code of Federal Regulations except 3280.1, 3280.5, 3280.6, 3280.7, and 3280.8.

Amended by R.1999 d.424, effective December 6, 1999.
See: 31 N.J.R. 2428(a), 31 N.J.R. 4001(c).

In (b), inserted a reference to fire protection materials the introductory paragraph, inserted 4i and 4ii, inserted a new 5iii, and recodified former 5iii and 5iv as 5iv and 5v; and in (c), changed chapter 5 reference in 4, substituted a reference to section 7.21 for a reference to 7.24 in 6, substituted a reference to section 11.2.3 for a reference to 11.2.2 in 10i, changed chapter 14 reference in 13, and changed section 16.1.7 reference in 15.

Administrative correction.

See: 32 N.J.R. 688(a).

Amended by R.2000 d.492, effective December 18, 2000.

See: 32 N.J.R. 3219(a), 32 N.J.R. 4437(b).

In (b), rewrote 15 and 21; in (d), rewrote 2 through 4; and added (h).

Amended by R.2002 d.5, effective January 7, 2002.

See: 33 N.J.R. 3392(a), 34 N.J.R. 267(a).

In (b), added new 5vi.

Amended by R.2003 d.218, effective May 19, 2003.

See: 35 N.J.R. 29(a), 35 N.J.R. 2209(a).

Rewrote the section.

Amended by R.2004 d.145, effective April 5, 2004.

See: 35 N.J.R. 5190(a), 36 N.J.R. 1758(a).

Deleted references to use preceding references to group throughout; in (b), substituted "906.1" for "906" in the introductory paragraph of 4 and inserted "1003.3.1.3.1" in 5iii; in (i), substituted a reference to automatic sprinkler for a reference to fire suppression in 3.

Administrative correction.

See: 36 N.J.R. 2490(b).

Amended by R.2005 d.82, effective March 7, 2005.

See: 36 N.J.R. 4222(a), 37 N.J.R. 771(a).

In (b), substituted "906.2" for "906.1" in the introductory paragraph of 4, and deleted i, substituted "1614" for "1613" in 9; in (c), deleted "and" following "108.1" and inserted "and 10.15.9" following "10.14" in 9.

5:23-6.9 New building elements

(a) When the rehabilitation of an existing building creates or includes any building element of a type listed in this section, then the new element shall comply with the requirements for such an element established by this section.

1. The installation of a floor system which did not previously exist, shall be constructed utilizing the live load requirements as specified in Section 1607 of the building subcode, or with Section R301.4 of the one-and two-family dwelling subcode, as applicable.