

5:23-7.4 Nonresidential buildings and buildings of Use Group R-1

(a) Nonresidential buildings, and buildings of Use Group R-1, shall provide accessibility as follows:

1. Small buildings, defined as those with a total gross enclosed floor area of less than 10,000 square feet, shall be required to have at least one accessible entrance on the ground (or first) floor and accessible interior building features on all floors. Small buildings shall not be required to have elevator(s) to provide a vertical accessible route between floors.

i. Regardless of the total square footage of the building, buildings that are three or more stories with any floor of 3,000 square feet or more shall be required to have elevator(s) to provide a vertical accessible route between floors;

ii. Regardless of the square footage of the buildings or floors, buildings of two or more stories that are owned and occupied by public entities shall provide a vertical accessible route between floors;

iii. Regardless of the square footage of the buildings or floors, buildings of two or more stories that house public transit stations or airport passenger terminals shall provide a vertical accessible route between floors;

iv. Regardless of the square footage of the buildings or floors, buildings of two or more stories that house the professional offices of health care providers shall provide a vertical accessible route between floors; and

v. Regardless of the square footage of the buildings or floors, buildings of two or more stories that house shopping centers or shopping malls shall provide a vertical accessible route between floors.

(1) For the purposes of applying this requirement, a shopping center or shopping mall shall mean a building or a series of buildings on a common site, under common ownership or control, or developed as one project or as a series of related projects housing five or more sales or rental establishments.

2. Large buildings, defined as those with a total gross enclosed floor area of 10,000 square feet or more, shall provide the accessible building features required of small buildings in (a)1 above. In addition, large buildings shall be required to have elevator(s) to provide a vertical accessible route between floors.

3. For the purposes of applying these provisions, buildings separated by firewalls with penetrations intended for human passage shall not constitute separate buildings.

4. Except as provided in (a)1 above, floors or mezzanines of less than 3,000 square feet shall not be required to be served by an elevator, but shall otherwise meet the requirements of this subchapter.

i. Where facilities for employees, including rest rooms, lunch rooms, and lockers, and public facilities, including rest rooms and drinking fountains, are provided on the floor or mezzanine, and where there is no vertical accessible route, the facilities provided on the floor or mezzanine must also be provided on the accessible level.

ii. A limited use limited application elevator that complies with ANSI/ASME A17.1b-1995, Part 25 may be used to provide a vertical accessible route to the floor or mezzanine provided that the travel distance of the device does not exceed 25 feet.

5. The following provisions shall apply to a nonresidential building required to be accessible, whether a large building or a small building:

i. An accessible route available to the general public shall not pass through kitchens, storage rooms, or similar spaces.

ii. In buildings, facilities, or portions thereof that primarily serve children, variations shall not be required to adjust accessible dimensions to make building features suitable for children.

(1) However, in such buildings, accessible facilities that comply with the provisions of this subchapter for use by adults shall be provided.

New Rule, R.1999 d.105, effective April 5, 1999.

See: 30 N.J.R. 2972(a), 31 N.J.R. 852(a).

Former N.J.A.C. 5:32-7.4, Recreation: exceptions, recodified to N.J.A.C. 5:23-7.17.

Amended by R.2002 d.350, effective November 4, 2002.

See: 34 N.J.R. 626(a), 34 N.J.R. 3772(a).

Rewrote the section.

5:23-7.5 Residential buildings other than Use Group R-1

(a) Buildings of Use Group R-2, R-3, or R-4 with four or more dwelling units in a single structure shall comply with the provisions of this subchapter.

1. When being applied to a dwelling unit, the terms "accessible" and "adaptable" shall be interchangeable and shall mean that the dwelling unit has an accessible entrance; and accessible interior route into and throughout the dwelling unit, including maneuvering space at doors; and required clear floor spaces and reach ranges in all rooms. The dwelling unit shall have either the adaptable features specified in (d) below in the kitchen and bathroom or a fully accessible kitchen and bathroom as provided in the ICC/ANSI 117.1-1998 standard.

2. All common use facilities, including, but not limited to, recreational facilities, laundry areas, mail boxes, meeting rooms, and club houses, provided within the building or on the site must comply with the provisions of this subchapter.

(b) Except as provided at N.J.A.C. 5:23-7.3(b), all dwelling units in elevator-serviced buildings shall comply with the provisions of this subchapter.

1. In an elevator-serviced building, whether a dwelling unit is single story or multi-story, the entry level of each dwelling unit shall have an accessible entrance, an accessible route into and throughout the entry level of the dwelling unit, an adaptable kitchen, and one adaptable toilet and bathing facility on the accessible route.

i. An interior vertical accessible route shall not be required within a multi-story dwelling unit.

(c) In a building without elevator service, each ground floor dwelling unit shall be required to have an accessible entrance, an accessible route into and throughout the entry level of the dwelling unit, an adaptable kitchen, and one adaptable toilet and bathing facility on the accessible route.

1. For the purpose of applying this requirement, the ground floor shall mean, in a building containing dwelling units, the first floor with a dwelling unit or portion of a dwelling unit, regardless of whether that floor is at grade. A building may have more than one ground floor.

2. In a building without elevator service and with a building entrance that serves more than one dwelling unit, all multi-story dwelling units with a ground floor entrance shall be accessible as provided in (b) above.

(d) In addition to the adaptable features in ICC/ANSI A117.1, the following building features in a dwelling unit may also be considered adaptable:

1. The threshold for a shower compartment (ICC/ANSI A117.1, Section 608.7) may be adaptable as long as the shower threshold can be made accessible with minimal expense and effort.

2. The mirror height (ICC/ANSI A117.1, Section 1002.11.4) may be adaptable as long as adjusting the mirror can be accomplished with minimal expense and effort.

3. Kitchen cabinets mounted above the kitchen counters (ICC/ANSI A117.1, Section 1002.14) may be mounted at a standard height as long as remounting the kitchen cabinets can be accomplished with minimal expense and effort.

4. Windows (ICC/ANSI A117.1, Section 1002.13) shall be an adaptable feature.

(e) In an accessible dwelling unit, an accessible route shall be permitted to pass through the kitchen.

(f) Assisted living facilities that are designated as Use Group I-2 for purposes of building subcode and fire protection subcode compliance shall be considered as Use Group R-2 for the purposes of accessibility.

(g) When any dwelling unit, regardless of whether it is exempt from the provisions of this subchapter, includes a B use or an M use, any portion used for the B use or M use shall comply with the provisions of this subchapter.

1. This shall include, but not be limited to, parking, sidewalk, entrance, hallway, and those portions of the dwelling unit, interior or exterior, available to or used by customers or clients, including toilet facilities.

New Rule, R.1999 d.105, effective April 5, 1999.

See: 30 N.J.R. 2972(a), 31 N.J.R. 852(a).

Former N.J.A.C. 5:32-7.5, Recreation: route of travel, recodified to N.J.A.C. 5:23-7.18.

Amended by R.2002 d.256, effective August 5, 2002.

See: 33 N.J.R. 4184(a), 34 N.J.R. 2787(a).

Rewrote the section.

Amended by R.2002 d.350, effective November 4, 2002.

See: 34 N.J.R. 626(a), 34 N.J.R. 3772(a).

Rewrote the section.

5:23-7.6 Exterior accessible route

(a) Every site containing one or more buildings required by this subchapter to be accessible shall have at least one accessible route which shall provide access to and between buildings and facilities on the same site that are also required to be accessible.

1. Exterior accessible routes may include parking access aisles, curb ramps, walks, or ramps.

2. Where the natural and undeveloped contour of the land exceeds the slope required for an accessible route and it is technically infeasible to alter the land contour, a vehicular route may be provided as an alternate accessible route.

3. An accessible route within a site shall be provided from public transportation stops, accessible parking and accessible passenger loading zones, and public streets or sidewalks to the building entrance served.

4. Entrances to buildings or spaces in buildings that are not required to be accessible shall not be required to be on an accessible route.

5. Unless it is the only building entrance, a loading or service entrance shall not be required to be on an accessible route.

New Rule, R.1999 d.105, effective April 5, 1999.

See: 30 N.J.R. 2972(a), 31 N.J.R. 852(a).

Former N.J.A.C. 5:32-7.6, Recreation: pools, recodified to N.J.A.C. 5:23-7.19.

5:23-7.7 Accessible building entrances

(a) For buildings or structures required by this subchapter to be accessible, at least 50 percent of the entrances, but not fewer than one entrance, shall be accessible and shall comply with this subchapter.