

CHAPTER 18

LIQUEFIED PETROLEUM GAS

Authority

N.J.S.A. 34:1-20, 34:1A-3(e) and 21:1B-2.

Source and Effective Date

R.2000 d.269, effective June 5, 2000.
See: 32 N.J.R. 738(a), 32 N.J.R. 2425(a).

Executive Order No. 66(1978) Expiration Date

Chapter 18, Liquefied Petroleum Gas, expires on June 5, 2005.

Chapter Historical Note

Chapter 18, Rentals, was adopted as R.1970 d.86, effective July 21, 1970. See: 2 N.J.R. 47(b), 2 N.J.R. 71(a).

Chapter 18, Rentals, was repealed by R.1980 d.234, effective May 30, 1980. See: 12 N.J.R. 170(c), 12 N.J.R. 388(a).

Chapter 18, Uniform Fire Code, was adopted as new rules by R.1985 d.66, effective February 19, 1985. See: 16 N.J.R. 3339(b), 17 N.J.R. 394(a).

Subchapter 4, Fire Safety Code, was adopted as R.1986 d.214, effective June 16, 1986. See: 17 N.J.R. 1161(a), 18 N.J.R. 1260(b).

Pursuant to Executive Order No. 66(1978), Chapter 18, Uniform Fire Code, was readopted as R.1990 d.72, effective January 4, 1990. See: 21 N.J.R. 3344(a), 22 N.J.R. 337(b).

Subchapter 3, State Fire Prevention Code, was repealed and Subchapter 3, State Fire Prevention Code, was adopted as new rules by R.1992 d.105, effective March 2, 1992. See: 23 N.J.R. 3554(a), 24 N.J.R. 740(a).

Pursuant to Executive Order No. 66(1978), Chapter 18, Uniform Fire Code, was readopted as R.1995 d.58, effective January 3, 1995. See: 26 N.J.R. 4258(a), 27 N.J.R. 878(b).

Pursuant to Reorganization Plan No. 002-1998, Chapter 18, Uniform Fire Code, was recodified as N.J.A.C. 5:70, effective July 1, 1998. See: 30 N.J.R. 1347(a), 30 N.J.R. 2644(a).

Chapter 18, Liquefied Petroleum Gas, was originally codified in Title 12 as Chapter 200, Liquefied Petroleum Gas. Chapter 200 was filed and became effective prior to September 1, 1969. Pursuant to Executive Order No. 66(1978), Chapter 200 expired on May 15, 1985.

Chapter 200, Liquefied Petroleum Gas, was adopted as new rules by R.1985 d.403, effective August 5, 1985. See: 17 N.J.R. 1379(a), 17 N.J.R. 1899(a).

Pursuant to Executive Order No. 66(1978), Chapter 200, Liquefied Petroleum Gas, was readopted as R.1990 d.436, effective August 3, 1990. Subchapter 5, API 2510 Installations, was adopted as new rules and former Subchapter 5, Submittal of Plans or Project Data Report, was recodified as Subchapter 6, Submittal of Plans or Project Data Report, by R.1990 d.436, effective September 4, 1990. See: 22 N.J.R. 1984(a), 22 N.J.R. 2744(a).

Pursuant to Executive Order No. 66(1978), Chapter 200, Liquefied Petroleum Gas, was readopted as R.1995 d.391, effective June 23, 1995. See: 27 N.J.R. 1950(a), 27 N.J.R. 2694(b).

Subchapter 7, Violations, Administrative Penalties and Hearings, was adopted as R.1997 d.220, effective May 19, 1997. See: 29 N.J.R. 836(a), 29 N.J.R. 2463(b).

Pursuant to Reorganization Plan No. 002-1998, Chapter 200 of Title 12, Liquefied Petroleum Gas, was recodified as N.J.A.C. 5:18, effective July 1, 1998. See: 30 N.J.R. 1347(a), 30 N.J.R. 2644(a).

Pursuant to Executive Order No. 66(1978), Chapter 18, Liquefied Petroleum Gas, was readopted as R.2000 d.269, effective June 5, 2000. See: Source and Effective Date. See, also, section annotations.

CHAPTER TABLE OF CONTENTS

SUBCHAPTER 1. GENERAL PROVISIONS

- 5:18-1.1 Purpose and scope
- 5:18-1.2 Applicability and jurisdiction
- 5:18-1.3 Compliance
- 5:18-1.4 Registration
- 5:18-1.5 Inspection of LPG systems by the Bureau
- 5:18-1.6 Container markings
- 5:18-1.7 Reporting emergency situations
- 5:18-1.8 through 5:18-1.10 (Reserved)

SUBCHAPTER 2. DEFINITIONS

- 5:18-2.1 Definitions

SUBCHAPTER 3. NFPA NO. 58 SYSTEMS

- 5:18-3.1 Standards adopted by reference
- 5:18-3.2 Container markings
- 5:18-3.3 Container storage
- 5:18-3.4 Distributing points, distributing plants and industrial plants
- 5:18-3.5 Standby and peak shaving plants
- 5:18-3.6 Cylinder exchange cabinets
- 5:18-3.7 Unsafe container or system

SUBCHAPTER 4. NFPA NO. 59 SYSTEMS

- 5:18-4.1 Standards adopted by reference
- 5:18-4.2 Container markings
- 5:18-4.3 Container storage
- 5:18-4.4 Fencing
- 5:18-4.5 Fire protection

SUBCHAPTER 5. API 2510 INSTALLATIONS

- 5:18-5.1 Standards adopted by reference
- 5:18-5.2 Container markings
- 5:18-5.3 Container storage
- 5:18-5.4 Fencing
- 5:18-5.5 (Reserved)

SUBCHAPTER 6. RELEASE OF PLANS OR SUBMITTAL OF NOTICE OF LP-GAS INSTALLATION AND APPROVAL OF NEW LP-GAS SYSTEMS

- 5:18-6.1 Submittal of plans
- 5:18-6.2 Release of plans
- 5:18-6.3 Approval of new LP-Gas system
- 5:18-6.4 Submittal of notice of LP-Gas installation

SUBCHAPTER 7. VIOLATIONS, ADMINISTRATIVE PENALTIES AND HEARINGS

- 5:18-7.1 Violations/penalties
- 5:18-7.2 Hearings
- 5:18-7.3 Correction of violations

SUBCHAPTER 8. ANNUAL ASSESSMENTS

- 5:18-8.1 Amount of annual assessment
- 5:18-8.2 Payment of annual assessment
- 5:18-8.3 Forms

SUBCHAPTER 9. QUALITY CONTROL AND MAINTENANCE AUDITS

- 5:18-9.1 Registration of LPG bulk and industrial plants
- 5:18-9.2 Quality control manual and records
- 5:18-9.3 Pressure vessel maintenance, repair and alteration
- 5:18-9.4 Certificates of operation and audits

SUBCHAPTER 10. LICENSING

- 5:18-10.1 Licenses required
- 5:18-10.2 Application for licensure; fees
- 5:18-10.3 Employee certification
- 5:18-10.4 (Reserved)
- 5:18-10.5 Suspension and revocation of licenses and certifications and alternative sanctions

APPENDIX A. AVAILABILITY OF STANDARDS AND PUBLICATIONS REFERRED TO IN THIS CHAPTER

APPENDIX B. BUREAU OF CODE SERVICES

SUBCHAPTER 1. GENERAL PROVISIONS

5:18-1.1 Purpose and scope

(a) The purpose of this chapter is to provide minimum standards for liquefied petroleum gas systems for the preservation of health and safety of the general public.

(b) This chapter shall apply to the design, construction, location, installation, maintenance and operation of liquefied petroleum gas systems.

(c) The following pertain to existing LP-Gas systems:

1. LPG systems within the scope of this chapter which were installed in accordance with the rules in effect at the time of installation may be continued in service unless the continued operation of such systems constitutes a serious and substantial threat to health and safety.

2. Existing systems shall be registered with the Bureau if required by N.J.A.C. 5:18-1.4 and containers shall be marked in accordance with N.J.A.C. 5:18-1.6.

(d) This chapter shall not apply to the following:

1. The transportation of liquefied petroleum gases over the highways in intrastate or interstate commerce;

2. Liquefied petroleum gas vapor piping inside of buildings; or

3. Portable cylinders of not more than 40 pounds when used as intended for outdoor cooking purposes.

Amended by R.1990 d.436, effective September 4, 1990.
See: 22 N.J.R. 1984(a), 22 N.J.R. 2744(a).

Deleted old N.J.A.C. 12:200-1.1, "Title and Citation." Recodified from N.J.A.C. 12:200-1.2 and 1.3, making 1.2 new 1.1(a) and 1.3(a)-(c) as new 1.1(b)-(d). In new N.J.A.C. 12:200-1.1(d)2, added group R-3 occupancies and "one and two family residential." In (d)3, added "vapor" to describe piping and deleted language, "... that is downstream of final stage regulation and outside ...," and replaced with "inside" of buildings.

Amended by R.2001 d.141, effective May 7, 2001.

See: 32 N.J.R. 3917(a), 33 N.J.R. 746(a), 33 N.J.R. 1399(d).

In (d), inserted "R-4" following "R-3" in 2, added new 3 and recodified former 3 and 4 as 4 and 5.

Recodified from N.J.A.C. 5:18-1.2 amended by R.2003 d. 200, effective May 19, 2003.

See: 35 N.J.R. 7(a), 35 N.J.R. 2187(a).

Rewrote (b); deleted former (c) and recodified former N.J.A.C. 5:18-1.2 as (c); rewrote (d).

5:18-1.2 Applicability and jurisdiction

(a) The issuance of permits for, and the inspection of, new liquefied petroleum gas vapor delivery systems of 2,000 gallons or less aggregate water capacity shall be the responsibility of the local construction official and plumbing sub-code official, as set forth in N.J.A.C. 5:23-3.4. The local construction official shall also be responsible for handling unsafe structures as set forth in N.J.A.C. 5:23-2.32.

(b) The issuance of permits for, and the inspection of, new liquefied petroleum gas systems of vapor delivery greater than 2,000 gallons aggregate water capacity and all liquid withdrawal systems shall be the responsibility of the Bureau.

(c) In addition to compliance with the requirements of this chapter, liquefied petroleum gas systems of over 2,000 gallons aggregate water capacity, or individual containers of over 1,000 gallons water capacity, shall be subject to registration and to annual inspection by the fire official, as set forth in the Uniform Fire Code, N.J.A.C. 5:70-2.4B and 2.5.

(d) Cylinder exchange cabinets shall be subject to inspection by the fire official, in accordance with section F-3605.0 of the Fire Prevention Code, N.J.A.C. 5:70-3.

(e) In addition to compliance with the requirements of this chapter, LPG systems at locations identified as fill plants shall be subject to inspection by the local fire official, in accordance with section F-3609.0 of the Fire Prevention Code, N.J.A.C. 5:70-3.

(f) LP-Gas facilities including producers, bulk plants and industrial plants of 10,000 gallons water capacity or more, gas utility plants, marine or pipeline terminals or tank farms shall comply with and shall be inspected in accordance with the quality control program outlined in N.J.A.C. 5:18-9.

Recodified from N.J.A.C. 12:200-1.7 by R.1990 d.436, effective September 4, 1990.

See: 22 N.J.R. 1984(a), 22 N.J.R. 2744(a).

Prior N.J.A.C. 12:200-1.2 was "Purpose," which was recodified to N.J.A.C. 12:200-1.1.

New Rule, R.2003 d.200, effective May 19, 2003.

See: 35 N.J.R. 7(a), 35 N.J.R. 2187(a).

Former N.J.A.C. 5:18-1.2, Existing installations, recodified to N.J.A.C. 5:18-1.1(c).

5:18-8.1 Amount of annual assessment

Beginning July 1, 2001 and in every State fiscal year thereafter, there shall be an annual assessment levied upon liquefied petroleum gas in the amount of one-fifteenth of one cent per gallon.

5:18-8.2 Payment of annual assessment

(a) The owner of liquefied petroleum gas immediately prior to odorization shall be responsible for the payment of the assessment on the volume of liquefied petroleum gas at the time of import or odorization, whichever is earlier.

(b) All assessments shall be payable to "Treasurer, State of New Jersey" and shall be remitted to the Bureau of Code Services, PO Box 816, Trenton, NJ 08625-0816 on a quarterly basis on or before the 25th day of the month following the end of the quarter.

(c) A penalty of five percent shall be added to all payments received by the Bureau after the 25th day of the month following the end of the quarter.

(d) In addition to the penalty imposed under (c) above, interest at an annual rate of 12 percent shall be added to all payments received by the Bureau 30 days or more after the 25th day of the month following the end of the quarter.

Amended by R.2003 d.200, effective May 19, 2003.
See: 35 N.J.R. 7(a), 35 N.J.R. 2187(a).

5:18-8.3 Forms

(a) The following forms, which are incorporated by reference as Appendix B of this chapter, shall be used for the purposes indicated:

1. Remittance Report (LPG-1);
2. Odorizer or Importer Registration (LPG-2);
3. Load Exemption: Certificate of LPG Destined for Export (LPG-3);
4. LPG Usage Report (LPG-4);
5. Assessment Refund Request (LPG-5); and
6. Odorization Report for Terminal Operators (LPG-6)

SUBCHAPTER 9. QUALITY CONTROL AND MAINTENANCE AUDITS

Authority

N.J.S.A. 21:1B-2, 9 and 15.

Source and Effective Date

R.2003 d.200, effective May 19, 2003.
See: 35 N.J.R. 7(a), 35 N.J.R. 2187(a).

5:18-9.1 Registration of LPG bulk and industrial plants

(a) The owner or operator of a LP-Gas facility, including producers, bulk plants and industrial plants of 10,000 gallons water capacity or more, gas utility plants, marine or pipeline terminals or tank farms, shall register with the Bureau on forms provided by the Bureau.

(b) The registration shall include information as to all locations at which odorized or unodorized LP-Gas is stored or sold by the business, whether at the facility or elsewhere.

5:18-9.2 Quality control manual and records

(a) The owner or operator of a facility required to be registered pursuant to N.J.A.C. 5:18-9.1 shall prepare, maintain and follow a quality control manual which shall, at a minimum, include the following:

1. A cover sheet indicating the full name of the owner and operator and the street address of the facility;
2. An organization chart detailing the lines of communication and authority and identifying the individual, who shall be a senior company official, who is responsible for implementation of the quality control manual;
3. A complete site plan for each registered facility and a process flow diagram that illustrates piping, valves, equipment, and emergency shutdowns of the facility;
4. A description of a training program for LPG handling and safety approved by the Bureau of Code Services. The training program shall meet the following requirements:
 - i. There shall be ongoing training for all individuals involved in the operation and maintenance of LPG equipment; and
 - ii. All training shall be consistent with national standards for LPG safety training and with this chapter;
5. Standard operating procedures (SOP) and checklists for each facility in order to ensure, at a minimum, safe operation. Any such SOP or checklist shall include, where applicable, but not be limited to, the following:
 - i. Filling, refilling and/or venting containers;
 - ii. Delivery of LPG to any location. A checklist shall be provided to each driver and, when requested, to the Bureau inspector, to ensure that proper procedures, as required by this chapter, are followed;
 - iii. Evacuation of cylinders;
 - iv. Emergency procedures;
 - v. Accident reporting and documentation;
 - vi. Installation guidelines and standards for every type of container;
 - vii. Repair or reconditioning of vessels; and

viii. Testing, repair and maintenance of pressure relief valves and other control or flow devices;

6. Documentation of compliance with the NJDEP Risk Management Program, if applicable, including details specific to the following:

- i. Plant safety information, including hazard review scenarios with both normal and emergency shutdown procedures;
- ii. System operating procedures;
- iii. Employee training;
- iv. Maintenance procedures and programs;
- v. Compliance audits;
- vi. Plant fire safety analysis; and
- vii. Incident investigations;

7. Documentation assuring that only acceptable materials are used for new, existing or replacement systems and that all required materials are properly identified when received; and

8. Nonconformance reports documenting all conditions not conforming to this chapter and ensuring that any problems identified through procedures, controls, inspections, specifications or testing are effectively corrected and documented.

(b) The owner or operator of a facility shall maintain a file system for equipment inspection records, which shall list, by number and such abbreviated description as may be necessary for identification, each ASME pressure vessel covered by these rules, the date of the last inspection of the vessel, and the approximate date for the next inspection.

(c) The owner or operator of a facility shall maintain the following records for the times specified:

1. Manufacturer's data reports of new and used pressure vessels: life of the vessel;
2. All documentation of repairs: life of the vessel;
3. Reports of training: term of employment;
4. Reports of nonconformance: five years; and
5. All results of nondestructive examination tests and other tests and all repair or alteration documentation: life of the vessel.

(d) The Bureau shall have free access to the records of the facility maintained under (a), (b), and (c) above.

5:18-9.3 Pressure vessel maintenance, repair and alteration

Any pressure vessel code item shall be maintained, repaired and altered in accordance with the original code of construction, the National Board Inspection Code, the applicable ASME code and this chapter.

5:18-9.4 Certificates of operation and audits

(a) The owner or operator of a facility required to be registered pursuant to N.J.A.C. 5:18-9.1 shall be audited by the Bureau triennially after a satisfactory initial audit.

(b) Upon successful completion of an initial audit, the Bureau shall issue a site-specific certificate of operation, which shall be valid for three years.

(c) The certificate of operation shall indicate that the facility is in compliance with all applicable requirements of this chapter and shall be posted at a conspicuous location within the facility where it may be inspected by representatives of the Bureau and members of the public.

(d) In the event that an audit is not successful, an owner or operator shall be given 30 days to address all identified deficiencies. Subsequent audits shall be made as necessary in order to verify compliance with all applicable requirements.

1. The owner or operator may apply for, and the Bureau may grant, an extension of time to address deficiencies if the Bureau finds that such extension is needed, that the owner is making a good faith effort to correct deficiencies and that there is no threat to public health or safety.

(e) Failure to remove any violations found as a result of an audit made by the Bureau shall result in issuance of a written notice to abate the violations. Correction of violations shall be done in accordance with N.J.A.C. 5:18-7.3.

SUBCHAPTER 10. LICENSING

Authority

N.J.S.A. 21:1B-2, 9 and 15.

Source and Effective Date

R.2003 d.200, effective May 19, 2003.
See: 35 N.J.R. 7(a), 35 N.J.R. 2187(a).

5:18-10.1 Licenses required

(a) No person, firm or corporation shall engage in the business of marketing LP-Gas within the State of New Jersey without being licensed to do so by the Bureau.

(b) A license issued by the Bureau shall be valid for a period of 36 months.

(c) No license shall be issued to any person, firm or corporation that does not maintain general liability insurance in an amount of not less than \$5,000,000 per occurrence.

(d) No license shall be issued to any person, firm or corporation that markets LP-Gas and does not maintain either an adequate storage capacity for customers or contract(s) with other marketers to provide LP-Gas.

(e) Retention and reissuance of a license shall be contingent upon satisfactory completion of all audits required pursuant to this chapter.

5:18-10.2 Application for licensure; fees

(a) An application for licensure shall be submitted on a form provided by the Bureau and shall include the following information:

1. The name of the business;
2. The names, addresses and telephone numbers of the officers, directors, partners or proprietors of the business;
3. The activities having to do with LP-Gas in which the business is engaged in the State of New Jersey;
4. Proof of insurance as required by N.J.A.C. 5:18-10.1(c);
5. The location(s) at which or from which each such activity is conducted and the LP-Gas storage capacity at each such location or information on contracts with other marketers to provide LP-Gas;
6. Emergency contact information in conformance with N.J.A.C. 5:18-1.7;
7. A listing of all persons employed by the business who are in any way engaged in handling LP-Gas, together with the locations at which they work and Certified Employee Training Program (CETP) of the National Propane Gas Association certifications held by them;
8. A statement indicating whether or not the business, or any officer, director, partner or proprietor of the business, has at any time within the previous ten years been the subject of any order or finding of violation by any governmental entity with regard to the business or any other LP-Gas business or has been convicted of any crime or of any offense involving the business or any other LP-Gas business; and
9. A certification that the information set forth in the application is complete and correct.

(b) Each application for a license shall be accompanied by a fee in the amount of \$100.00. Checks shall be made payable to "Treasurer, State of New Jersey."

5:18-10.3 Employee certification

(a) Any employee of a marketer licensed pursuant to N.J.A.C. 5:18-10.1 handling LP-Gas shall obtain Certified Employee Training Program (CETP) of the National Propane Gas Association certification for Book One, "Basic Principles and Practices," within three months of the date of hiring or of the effective date of these regulations, whichever is later. Such employee shall obtain CETP certification for Book Two, "Propane Delivery," Book Three, "Plant Operations," and Book Four, "Distribution System Operations," within 21 months of the date of hiring or of the effective date of these regulations, whichever is later.

(b) Licensees shall maintain records of employee certification and shall make those records available to the Bureau upon request.

5:18-10.4 (Reserved)

5:18-10.5 Suspension and revocation of licenses and certifications and alternative sanctions

(a) The Bureau may suspend or revoke a license, or may deny renewal or issuance of a license, upon a finding that an applicant or licensee has engaged in acts or omissions harmful to public safety or to the protection of the public. Factors in determining whether a license should be revoked or suspended, or for how long a suspension should be in effect, shall include, but not be limited to, the extent and duration of the hazard to the public, the extent to which willful or reckless behavior was evident, prior history of like or similar violations and the extent to which appropriate corrective action was taken.

(b) As an alternative to revocation or suspension of a license, the Bureau may assess a civil penalty, in accordance with N.J.S.A. 21:1B-5, or may issue a letter of warning, reprimand or censure, if the Bureau determines any such action to be warranted. Any penalty imposed or letter issued shall be part of the licensing file of the business or individual, as the case may be.

(c) Conviction of a crime, or of an offense in connection with the LP-Gas business, shall constitute grounds for suspension or revocation of a license.

(d) Any person to whom the Bureau denies a license, or whose license is suspended or revoked, or who is ordered to pay a civil penalty, shall be entitled to appeal the action of the Bureau in an administrative hearing conducted in accordance with the Administrative Procedure Act, N.J.S.A. 52:14B-1 et seq., and the Uniform Administrative Procedure Rules, N.J.A.C. 1:1. The final decision shall be issued by the Commissioner.

APPENDIX A

AVAILABILITY OF STANDARDS AND PUBLICATIONS REFERRED TO IN THIS CHAPTER

A copy of each of the standards and publications referenced in this chapter is on file and may be inspected at the

following office of the Division of Codes and Standards between the hours of 9:00 A.M. and 5:00 P.M. on normal working days:

State of New Jersey
 Department of Community Affairs
 Division of Codes and Standards
 101 South Broad Street
 Trenton, New Jersey

Copies of the referenced standards and publications may be obtained from the organizations listed below. The abbreviations preceding these standards and publications have the following meanings and refer to the organizations issuing the standards and publications listed or to volumes of statutes or administrative rules.

- API American Petroleum Institute
 1220 L Street Northwest
 Washington, D.C. 20005
- BOCA Building Officials and Code Administration
 4051 W. Flossmoor Rd.
 Country Club Hills, Illinois 60477-5795
- CFR Code of Federal Regulations
 Copies available from:
 Superintendent of Documents
 Government Printing Office
 Washington, D.C. 20402
- NFPA National Fire Protection Association
 Batterymarch Park
 Quincy, Massachusetts 02269
- N.J.A.C. New Jersey Administrative Code
 Copies of N.J.A.C. 5:18 are available from:
 Bureau of Code Services
 New Jersey Department of Community Affairs
 PO Box 816
 Trenton, New Jersey 08625-0816
 Copies of N.J.A.C. 5:70-3 are available from
 Division of Fire Safety
 New Jersey Department of Community Affairs
 PO Box 809
 Trenton, New Jersey 08625-0809

N.J.S.A. New Jersey Statutes Annotated
 Copies of N.J.S.A. 21:1B-1 et seq. are available from:
 Bureau of Code Services
 New Jersey Department of Community Affairs
 PO Box 816
 Trenton, New Jersey 08625-0816

USC United States Code
 Copies available from:
 Occupational Safety and Health Administration
 U.S. Department of Labor
 1515 Broadway
 New York, New York 10036

<i>No. and Edition</i>	<i>Title</i>
API-2510-1995	American Petroleum Institute 2510-1995, Design and Construction of Liquefied Petroleum Gas Installations
BOCA-1996	The BOCA National Building Code
NFPA No. 30-1993	Flammable and Combustible Liquids Code
NFPA No. 58-1998	Liquefied Petroleum Gas Code
NFPA No. 59-1998	Storage and Handling of Liquefied Petroleum Gases at Utility Gas Plants
N.J.A.C. 5:70	New Jersey Uniform Fire Code
N.J.A.C. 5:23	New Jersey Uniform Construction Code
N.J.A.C. 5:11	Boilers, Pressure Vessels and Refrigeration
N.J.S.A. 21:1B-1 et seq.	Liquefied Petroleum Gas Act
29 USC 651 et seq.	Occupational Safety and Health Act

Amended by R.1990 d.436, effective September 4, 1990.
 See: 22 N.J.R. 1984(a), 22 N.J.R. 2744(a).
 Updated citations, addresses and added API to appendix.
 Amended by R.1995 d.391, effective July 17, 1995.
 See: 27 N.J.R. 1950(a), 27 N.J.R. 2694(b).
 Amended by R.2003 d.200, effective May 19, 2003.
 See: 35 N.J.R. 7(a), 35 N.J.R. 2187(a).
 Updated citations, addresses.