

**5:23-3.15 Plumbing subcode**

(a) Rules concerning subcode adopted are as follows:

1. Pursuant to authority of P.L. 1975, c. 217, as modified by P.L. 1996, c. 53, the Commissioner hereby adopts the Model Code of the National Association of Plumbing Heating-Cooling Contractors, known as "The National Standard Plumbing Code/2006," as the plumbing subcode for New Jersey.

i. Copies of this code may be obtained from the sponsor at: NAPHCC, P.O. Box 6808, Falls Church, VA 22046.

2. "The National Standard Plumbing Code/2006," including appendices, may be known and cited as "the plumbing subcode."

(b) The following pages, chapters, sections or appendices of the plumbing subcode shall be amended as follows:

1. The section entitled "Administration," comprising sections ADM 1.1 through ADM 1.13, is deleted in its entirety.

2. Chapter 1 of the plumbing subcode, entitled "Definitions," shall be amended as follows:

i. Delete the term and definition of "Adopting Agency."

ii. Amend the definition of "approved" as follows: delete "Sec. 3.12" and insert "N.J.A.C. 5:23-3.7."

iii. Delete the definition of "Authority Having Jurisdiction" and insert the following: "Unless otherwise defined herein, or unless the context clearly indicates otherwise, the term "authority having jurisdiction" for purposes of the plumbing subcode, shall mean the "plumbing subcode official."

iv. The definition of the term "building" is deleted, and substitute in lieu thereof, the definition of the term "building" found in N.J.A.C. 5:23-1.4.

v. In the definition of "Building Classification" delete "authority having jurisdiction" and insert "building subcode" at N.J.A.C. 5:23-3.14.

vi. The term and definition of "code" are deleted.

vii. The term and definition of "family" are deleted.

viii. The definition of "hot water" shall be deleted and the following definition shall be inserted: "Hot Water: Potable water at a temperature of not less than 120 degrees F and not more than 140 degrees F.

ix. The definition of "tempered water" shall be deleted and the following definition shall be inserted: "Tempered Water: Water at a temperature of not less than 90 degrees F and not more than 105 degrees F.

x. The term and definition of "nuisance" are deleted.

xi. Add the following new definition after the definition of Swimming Pool: Swimming Pool, Public: A swimming pool located on any property other than a one or two family residential property and including, but not limited to, swimming pools open to the use of members, residents or the public.

3. Chapter 2 of the plumbing subcode, entitled "General Regulations," shall be amended as follows:

i. Section 2.5 is deleted in its entirety.

ii. In Section 2.9.3 delete "Building Code or as required by the proper Authority Having Jurisdiction" and insert "building subcode."

iii. In Section 2.11, Piping materials exposed within plenums, "Codes" shall be deleted and "subcodes" shall be inserted.

iv. In Section 2.12, Sleeves, subparagraph e, "regulations" shall be deleted and "subcode" shall be inserted.

v. In Section 2.16, Freezing or overheating, at item 1, "42" shall be inserted in the blank space provided. Additionally, the following sentence shall be inserted: "Combination domestic/fire water service piping shall be installed such that the minimum earth cover is 42 inches or the top of the pipe is 12 inches below the frost depth of the locality, whichever is greater. Limited-area sprinkler systems installed in accordance with Section 903.3.5.1.1 of the building Subcode, shall be installed such that the minimum earth cover is 42 inches." In the same section, at Item 2, "24" shall be inserted in the blank space provided. In addition, in the second line of Item 2, "6" shall be inserted in the blank space provided.

vi. Section 2.19.1 is amended to delete the blank and the words "feet of any property line of the premises, or other."

vii. Section 2.19.2 is amended to delete the words "the Health Department or other agency having jurisdiction" and substitute in lieu thereof "The New Jersey Department of Environmental Protection."

viii. In Section 2.25, at Item 8, insert "and which does not otherwise adversely affect health and safety" at the end of the section.

4. Chapter 3 of the plumbing subcode, entitled "Materials," shall be amended as follows:

i. In Section 3.1.1 delete "Minimum." In the same section at items (1) and (2), delete "Section 3.12.2" and insert "N.J.A.C. 5:23-3.7."

ii. In Section 3.1.2, at Item a, delete "at least." In the same section, delete "Section 3.12" and insert "N.J.A.C. 5:23-3.7."

iii. In Section 3.1.3, Standards applicable to plumbing materials, "Section 3.12.2" shall be deleted and "N.J.A.C. 5:23-3.7" shall be inserted.

iv. Section 3.3.8a is amended to add the following phrase: "Pressure vessels shall be designed and constructed in accordance with the requirements of American Society of Mechanical Engineers, (ASME), Rules for Construction of Pressure Vessels, Section VIII/1998. Any pressure vessel that exceeds any of the following, shall meet the requirements of ASME and shall be stamped ASME: A heat input rating of 200,000 BTU per hour; or a water temperature of 200 degrees Fahrenheit; or a nominal water capacity of 120 gallons or any other thresholds of ASME that apply."

v. Section 3.3.11 entitled "Septic Tanks" is deleted in its entirety.

vi. Add new section 3.4.2.1 as follows: 3.4.2.1 Combination Domestic/Fire Water Service: Water service piping for combination domestic/fire water services shall be of materials listed in Table 3.4 and shall be water pressure rated not less than 200 psig at 73°F. Joint restraints shall comply with Section 6.3, entitled "Joint Restraint for Fire Mains" per NFPA 13.

Exception: Limited area sprinkler systems installed in accordance with Section 903.3.5.1.1 of the building subcode, shall be water pressure rated not less than 160 psig at 73°F.

vii. In Section 3.11.1 delete "approved by the Authority Having Jurisdiction."

viii. In Section 3.11.2 delete "except as may be otherwise authorized by the Authority Having Jurisdiction."

ix. Section 3.12, Alternate materials and methods, shall be deleted in its entirety.

5. Chapter 4 of the plumbing subcode entitled, "Joints and Connections" is amended as follows:

i. In Section 4.3.8(b)(3) delete "be approved by the Authority Having Jurisdiction if such products are not listed or labeled" and insert "or as permitted under N.J.A.C. 5:23-3.7."

6. Chapter 5 of the plumbing subcode entitled, "Traps, Cleanouts and Backwater Valves," shall be amended as follows:

i. In Section 5.3.2, Trap seals, in Exception (2), "in accordance with N.J.A.C. 5:23-3.3" shall be inserted after "Authority Having Jurisdiction."

ii. In Section 5.3.4, Building traps, "in accordance with N.J.A.C. 5:23-3.3" shall be inserted after "Authority Having Jurisdiction."

7. Chapter 6 of the plumbing subcode, entitled "Liquid Waste Treatment Equipment," shall be amended as follows:

i. At the end of Section 6.1.1, Where required, the following shall be inserted: "The determination of necessity shall be made by the plumbing subcode official in accordance with N.J.A.C. 5:23-3.3."

ii. Section 6.4.4 is amended to add the phrase "in accordance with N.J.A.C. 5:23-3.3" after the word "approval" on line 2.

8. Chapter 7 of the plumbing subcode, entitled "Plumbing Fixtures, Fixture Fittings and Plumbing Appliances," shall be amended as follows:

i. Section 7.2 is amended to read "Plumbing fixtures for accessible use and their installation shall conform to the requirements of N.J.A.C. 5:23-7 et. seq."

ii. In Section 7.4.4, Bowl height, Exception (2) and Exception (3) shall be deleted and the following text shall be inserted: "Accessible water closets shall conform to the requirements of N.J.A.C. 5:23-7 et seq."

iii. At the end of Section 7.18.2 after "Authority Having Jurisdiction" insert "in accordance with N.J.A.C. 5:23-3.3."

iv. Note 1 to Table 7.21.1 is amended to delete the words "For handicap requirements see local, state, or national codes." in the second sentence.

v. Figure 7.3.2 is amended to delete the word "Code" and substitute in lieu thereof "Subcode" in the block at bottom.

vi. Section 7.23, Safety features for spas and hot tubs, shall be deleted and Section 7.23, Safety features for swimming pools, spas and hot tubs, shall be inserted as follows:

"7.23 Safety Features for Swimming Pools, Spas and Hot Tubs.

7.23.1 General. Suction outlets shall be designed to provide circulation throughout the pool, spa or hot tub. Single-outlet systems, such as automatic vacuum cleaner systems, or other such multiple suction outlets whether isolated by valves or otherwise, shall be protected against user entrapment.

7.23.2 Suction fittings. All pool and spa suction outlets shall have a cover that conforms to ASME A112.19.8M, a 18-inch by 23-inch (457 mm by 584 mm) drain grate or larger, or an approved channel drain system.

Exception: Surface skimmers.

7.23.3 Atmospheric vacuum relief system required. Pool and spa single- or multiple-outlet circulation systems shall be equipped with atmospheric vacuum relief should grate covers located therein become missing or broken. This

vacuum relief system shall include at least one approved or engineered method of the type specified herein, as follows:

1. Safety vacuum release system conforming to ASME A112.19.17; or
2. Approved gravity drainage system.

7.23.4 Dual drain separation. Single- or multiple-pump circulation systems shall have a minimum of two suction outlets of the approved type. A minimum horizontal or vertical distance of 3 feet (914 mm) shall separate such outlets. The suction outlets shall be piped so that water is drawn through the outlets simultaneously through a vacuum-relief-protected line to the pump or pumps.

7.23.4.1 All swimming pools shall be equipped with main drain suction outlets in the lowest point of the swimming pool floor. The spacing of the main drain suction outlets shall not be greater than 20 feet on center, nor more than 15 feet from each side wall.

Exception: Swimming pools installed in or on the lots of one- or two-family dwellings.

7.23.5 Pool cleaner fittings. Where provided, vacuum or pressure cleaner fitting(s) shall be located in an accessible position(s) at least 6 inches (152 mm) and not more than 12 inches (305 mm) below the minimum operational water level or as an attachment to the skimmer(s)."

9. Chapter 8 of the plumbing subcode, entitled "Hangers and Supports," shall be amended as follows:

- i. In Section 8.9, Seismic supports for piping, "code" shall be deleted and "subcode" shall be inserted.

10. Chapter 10 of the plumbing subcode, entitled "Water Supply and Distribution," shall be amended as follows:

- i. In Section 10.2 after "Authority Having Jurisdiction" insert "in accordance with N.J.A.C. 5:23-3.3".
- ii. In Section 10.4.2 delete "with the approval of the Authority Having Jurisdiction" and insert "in accordance with the rules of the New Jersey Department of Environmental Protection at N.J.A.C. 7:10-10";
- iii. Section 10.4.3 is amended to read: "Potable water supplies shall be protected in accordance with the provisions of this code and where applicable the Safe Drinking Water Regulations (N.J.A.C. 7:10). The requirements of this code shall establish requirements for individual outlet protection. The requirements of the Safe Drinking Water Act shall establish the requirements for containment.";
- iv. In Section 10.4.4, Private supplies, at Note b, "in accordance with N.J.A.C. 7:10-10.2(e)" shall be inserted after "Authority Having Jurisdiction."

v. Section 10.5.6d. is amended to delete the words "and repair" on the first line, and to delete the third sentence.

vi. In Section 10.8.1 insert "as required by the Authority Having Jurisdiction" after "in accordance with good practice."

vii. Section 10.15.1, Hot water supply system, shall be amended to add the phrase "Outlet temperature of hot water from lavatory faucets in public facility restrooms (such as those in service stations, airports, train and bus terminals, and conventions halls) shall be provided with a means to limit the maximum temperature to 110 degrees F. as required in ASHRAE 90.1-1999."

11. Chapter 11 of the plumbing subcode, entitled "Sanitary Drainage Systems," is amended as follows:

- i. Section 11.4.3 is amended at the end to add the sentence "Diversity factors shall be established in accordance with N.J.A.C. 5:23-3.3."

12. Chapter 12 of the plumbing subcode, entitled "Vents and Venting," shall be amended as follows:

- i. Section 12.5 is deleted in its entirety.
- ii. Section 12.8.2 is deleted in its entirety.

13. Chapter 13 of the plumbing subcode, entitled "Storm Water Drainage," shall be amended as follows:

i. In Section 13.1.5, Foundation drains, Notes a. through c. shall be amended to read "subsoil drains shall be provided in accordance with the building subcode."

ii. Section 13.1.10.1, Primary roof drainage, shall be amended to delete the last sentence and to substitute in lieu thereof "Rainfall rates shall be applied so that the applicable rainfall rate for Burlington and Ocean counties and all counties south shall be six inches per hour and for Mercer and Monmouth counties and all counties north, the applicable rainfall rate shall be five inches per hour."

iii. Section 13.1.10.2, "Secondary Roof Drainage," is deleted.

iv. Section 13.1.10.4, "Equivalent Systems," is deleted.

v. In Section 13.9.1 after "Authority Having Jurisdiction" insert "in accordance with N.J.A.C. 5:23-3.3."

14. Chapter 15 of the plumbing subcode, entitled "Tests and Maintenance" is amended as follows:

- i. Add new Section 15.6.1 as follows: 15.6.1 Combination Domestic/Fire Water Service Systems: Piping for combination domestic/fire water services systems shall be pressure tested to not less than 200 psig and shall maintain that pressure without loss for 2 hours.

ii. Add new Section 15.6.1.1 as follows: 15.6.1.1 Leakage: The following provisions shall apply to buried pipe in all combination domestic/fire water service systems, except for limited sprinkler systems:

(1) The amount of leakage at the joints shall be no greater than 2 qt/hr (1.89 L/hr) per 100 joints or gaskets, regardless of pipe diameter.

(2) The amount of leakage in accordance with (1) above shall be permitted to be increased in increments of 1 fluid ounce (30 ml) per inch valve diameter per hour for each metal seated valve that isolates the test section.

(3) The amount of leakage in buried piping shall be measured at the test pressure specified by pumping from a calibrated container.

iii. Add new Section 15.9 as follows: 15.9 Flushing of Piping: Lead-in connections to system risers and fire service mains from the water supply to the system riser (excluding limited systems) shall be flushed completely before connection is made to sprinkler piping. The flushing operation shall be continued for a sufficient amount of time to ensure that the system is thoroughly cleaned. The minimum rate of flow shall be not less than one of the following:

(1) The hydraulically calculated water demand rate of the system, including any hose requirements.

(2) The flow that is necessary to provide a velocity of 10 ft/sec (3.1 m/sec).

(3) The maximum flow rate available to the system under fire conditions.

15. Chapter 16 of the plumbing subcode, entitled "Regulations Governing Individual Sewage Disposal Systems for Homes and Other Establishments Where Public Sewer Systems Are Not Available," shall be amended as follows:

i. Except as otherwise indicated in (b)15ii below, Sections 16.1 through 16.12.1.13 shall be deleted in their entirety.

ii. Section 16.1.7, Abandoned disposal systems, shall be retained and amended to read as follows: "When an existing sewage disposal system is being abandoned and a connection is being made to the public sewer system or new sewage disposal system, the plumbing subcode official shall ensure that the existing abandoned tank is disconnected from the building, pumped out and filled with gravel, stones or soil material."

Note: Existing standards of the Department of Environmental Protection and boards of health with respect to individual on-site sewage disposal systems remain in effect.

16. Chapter 17 of the plumbing subcode entitled, "Portable Water Supply Systems," shall be deleted in its entirety.

Note: Existing standards of the Department of Environmental Protection and boards of health with respect to individual on-site water supply systems remain in effect.

17. Chapter 18 of the plumbing subcode, entitled "Mobile Home and Travel Trailer Park Plumbing Standards," shall be amended as follows:

i. In Section 18.2.1, General, the last sentence beginning with "Trailer home park" shall be deleted.

ii. Section 18.2.2 is amended to delete the words "or sewerage disposal" on line 1.

iii. Section 18.5.8 is amended to add the phrase "and as provided by the authority having jurisdiction" after the words "chapter 10 of this code."

iv. Section 18.8.1.2 is deleted.

v. Section 18.8.3 is amended to add the phrase "for dependent trailers" after the word "park" on line 1.

vi. Section 18.8.4 is amended to add the phrase "for dependent trailers" after the word "park" on line 1.

vii. Section 18.9 is deleted.

viii. Section 18.10 is deleted.

18. Appendix A, entitled "Sizing Storm Drainage Systems," shall be deleted in its entirety.

19. Appendix F, entitled "Requirements of the Authority Having Jurisdiction," shall be amended as follows.

i. In Section F.2, References, the following shall be deleted: "1.7.2 Penalties; 1.9.8 Permit Expiration; 1.10.2 Plan Review Fees; 1.10.3 Plan Review Expiration; 1.10.5 Refunding of Fees; and 1.11.5 Requests for Inspection."

Amended by R.1981 d.132, effective May 7, 1981.

See: 13 N.J.R. 121(a), 13 N.J.R. 258(d).

Amended by R.1983 d.12, eff. February 7, 1983, operative February 22, 1983.

See: 14 N.J.R. 1326(a), 15 N.J.R. 141(c).

Added (a) 3 and (c).

Amended by R.1984 d.314, eff. August 6, 1984.

See: 16 N.J.R. 1139(a), 16 N.J.R. 2084(b).

Section substantially amended.

Amended by R.1986 d.12, effective February 3, 1986.

See: 17 N.J.R. 2714(a), 18 N.J.R. 267(a).

(a)1i had a change of address; (a)3 and (c) added.

Amended by R.1987 d.81, effective February 2, 1987.

See: 18 N.J.R. 2237(b), 19 N.J.R. 289(d).

Amended by R.1987 d.374, effective September 21, 1987.

See: 19 N.J.R. 1024(a), 19 N.J.R. 1720(b).

Model subcode revisions.

Amended by R.1989 d.66, effective February 6, 1989.

See: 20 N.J.R. 2846(a), 21 N.J.R. 288(a).

Added (c).

Amended by R.1990 d.58, effective February 5, 1990.

See: 21 N.J.R. 3346(a), 22 N.J.R. 351(a).

Added (d) adopting the 1989 Supplement to the 1987 National Standard Plumbing Code.

Amended by R.1990 d.253, effective May 21, 1990.

See: 22 N.J.R. 909(b), 22 N.J.R. 1554(a).

Text added at (a)3; (d)3ii amended.

Amended by R.1990 d.507, effective October 15, 1990.

See: 22 N.J.R. 2208(a), 22 N.J.R. 3214(a).

Text conformed to BOCA National Code/1990.

Amended by R.1991 d.326, effective July 1, 1991.

See: 23 N.J.R. 804(a), 23 N.J.R. 2044(a).

GPF set at 1.6; gravity water closets not permitted in commercial uses.

Amended by R.1991 d.571, effective November 18, 1991.

See: 23 N.J.R. 2619(a), 23 N.J.R. 3444(b).

Added new (c).

Amended by R.1992 d.67, effective February 3, 1992.

See: 23 N.J.R. 3602(a), 24 N.J.R. 404(b).

Low volume water closet exception added at (b)18i(1).

Amended by R.1993 d.662, effective December 20, 1993.

See: 25 N.J.R. 3891(a), 25 N.J.R. 5918(a).

Amended by R.1995 d.122, effective March 6, 1995 (operative July 1, 1995).

See: 26 N.J.R. 4874(a), 27 N.J.R. 894(a).

Amended by R.1998 d.136, effective March 16, 1998.

See: 30 N.J.R. 4(a), 30 N.J.R. 1038(a).

In (b)9, added xii.

Amended by R.1998 d.332, effective July 6, 1998.

See: 30 N.J.R. 1377(a), 30 N.J.R. 2421(b).

Rewrote the section.

Amended by R.2001 d.340, effective September 17, 2001.

See: 33 N.J.R. 1245(a), 33 N.J.R. 3308(b).

Rewrote the section.

Amended by R.2002 d.393, effective December 16, 2002.

See: 34 N.J.R. 2914(a), 34 N.J.R. 4428(a).

In (b)8, deleted former (ii) and recodified existing (iii) to (ix) as (ii) to (viii).

Amended by R.2005 d.35, effective January 18, 2005.

See: 36 N.J.R. 3329(b), 37 N.J.R. 267(a).

Rewrote the section.

Administrative correction.

See: 37 N.J.R. 885(a).

Amended by R.2005 d.341, effective October 17, 2005.

See: 37 N.J.R. 164(a), 37 N.J.R. 3974(b).

In (b)3iv, added "and add the following sentence at the end: 'Minimum earth cover for building sewers connected to a private sewage disposal system shall be 6 inches.'" at the end of the paragraph.

Amended by R.2007 d.65, effective February 20, 2007.

See: 38 N.J.R. 3348(a), 39 N.J.R. 633(a).

Rewrote the section.

Amended by R.2008 d.274, effective September 15, 2008.

See: 40 N.J.R. 2629(a), 40 N.J.R. 5195(b).

In paragraph 7.23 of (b)8vi, substituted "Spas and Hot Tubs" for "spas and hot tubs"; in subparagraph 2 of paragraph 7.23.3 of (b)8vi, inserted a period at the end; in paragraph 7.23.4.1 of (b)8vi, added the second paragraph; and in paragraph 7.23.5 of (b)8vi, inserted the closing quotation mark at the end.

#### Case Notes

Statute providing that only licensed master plumbers could be plumbing contractors was unconstitutional. *Mechanical Contractors Ass'n of New Jersey, Inc. v. State*, 255 N.J.Super. 488, 605 A.2d 743 (A.D.1992).

### 5:23-3.16 Electrical subcode

(a) Rules concerning the subcode adopted are as follows:

1. Pursuant to authority of P.L. 1975, c. 217, as modified by P.L. 1996, c.53, the Commissioner hereby adopts the model code of the National Fire Protection Association, known as "The National Electrical Code 2005" as the electrical subcode for New Jersey.

i. Copies of this code may be obtained from the sponsors at NFPA, One Batterymarch Park, Quincy, Massachusetts 02269.

2. The National Electrical Code 2005 may be known and cited as "the electrical subcode."

i. Codes and standards referenced in the Fine Print Notes (FPNs) of the electrical subcode (NEC 2005) shall be considered adopted by reference to the extent prescribed by each related section. These codes and standards also are printed in DCA Bulletin #06-2, which contains a list of adopted codes and standards that are applicable to the enforcement of the electrical subcode.

3. The Commissioner hereby adopts the National Electrical Safety Code (ANSI C2-2002) for the installation of area lighting facilities by an electric utility on private property on metal poles with an underground electric feed.

i. Copies of the National Electrical Safety Code may be obtained from the Institute of Electrical and Electronic Engineers, Inc., PO Box 1331, 445 Hoes Lane, Piscataway, New Jersey 08855-1331.

(b) The following chapters or articles of the electrical subcode are amended as follows:

1. Article 90 of the electrical subcode, entitled "Introduction," is amended as follows:

i. Section 90.4, entitled "Enforcement," is amended to delete in the first paragraph the phrase, "authority having jurisdiction for enforcement of the code" and substitute in lieu thereof, the term "electrical subcode official." And add a new last sentence in the first paragraph: "Approval shall be in accordance with N.J.A.C. 5:23-2.9." Delete in the second paragraph the phrase "authority having jurisdiction" and substitute in lieu thereof the term "electrical subcode official" and add after "effective safety" the phrase "as provided in N.J.A.C. 5:23-2.9." Delete in the third paragraph the phrase "authority having jurisdiction" and substitute in lieu thereof the term "electrical subcode official" and delete the phrase "by the jurisdiction" after the word "adopted."

ii. Section 90.5, entitled "Mandatory Rules, Permissive Rules, and Explanatory Material," is amended to add "except as outlined under N.J.A.C. 5:23-3.16(a)2i" after the word "Code" in line 6 under paragraph (C).

2. Chapter 1 of the electrical subcode, Article 100, entitled "Definitions," is amended as follows:

i. The definition of the term "approved" is amended to delete the phrase "the authority having jurisdiction" and substitute in lieu thereof, the phrase "electrical subcode official. Approval shall be in accordance with N.J.A.C. 5:23-3.7, 3.8 and 3.8A."

ii. The definition of "Authority having jurisdiction" is replaced with "Unless otherwise specifically noted, the authority having jurisdiction for the Electrical Subcode shall be the Electrical Subcode Official."

iii. The definition of the term "building" is deleted and in lieu thereof, substitute the definition of the term "building" found in N.J.A.C. 5:23-1.4".

3. Chapter 2 of the electrical subcode, entitled "Wiring and Protection," is amended as follows:

i. Section 210.12(B) of Article 210, entitled "Branch Circuits," is amended to insert the following sentence at the end of the section, "This requirement shall be considered optional."

4. Chapter 3 of the electrical subcode, entitled "Wiring Methods and Materials," is amended as follows:

i. Section 300.4(A)(1) is amended to delete the words from "so that the edge..." on line four through "... cannot be maintained" on line six and in lieu thereof substitute "as required by the building subcode. Where the distance from the edge of the hole to the nearest edge of the wood member is less than 32 mm (1¼ inches)."

ii. Section 334.10(1) is amended to add "and accessory buildings or structures" after the word dwellings.

iii. Section 334.12(A)(2) is deleted in its entirety.

5. Chapter 5 of the electrical subcode, entitled "Special Occupancies," is amended as follows:

i. Sections 514.11(B) and 514.11(C) are amended to delete the phrase "authority having jurisdiction" and substitute in lieu thereof the phrase "fire protection subcode official."

ii. Part II of Article 550, entitled "Mobile Homes, Manufactured Homes, and Mobile Home Parks" comprising sections 550.11 through 550.25 is deleted. Section 550.10 shall be retained.

(1) Exception—Part II is retained in its entirety in the case of mobile/manufactured homes undergoing repair, renovation, or alteration.

(A) Section 550.25 is amended to add the following sentence at the end of the section: "This requirement shall be considered optional."

iii. In Article 551, entitled "Recreation Vehicles and Recreation Vehicle Parks," delete from the title the words "Recreational Vehicles and."

(1) Section 551.1 is amended to delete the phrase "within or on recreational vehicles" on line 4.

(2) Parts II, III, IV, and V, comprising sections 551.20 through 551.60, are deleted in their entirety, with the exception of Figure 551.46(C), which shall be retained.

iv. Article 552 shall be applicable to structures covered by the recreational park trailers subcode, N.J.A.C. 5:23-4D, provided that:

(1) The structure is restricted to seasonal use as per Section 552.4. For purposes of applying this requirement, the park in which the structure is located shall be open for six months or less each year or access to the structures shall be otherwise restricted to a period of six months or less each year; and

(2) No additions, alterations, or extensions of any kind shall be made to the electrical system or structure unless the entire electrical system shall be made to conform to the electrical requirements of this code applicable to single family dwellings.

6. Annex G of the electrical subcode, entitled "Administration and Enforcement," is deleted in its entirety.

7. Chapter 6 of the electrical subcode, entitled "Special Equipment," is amended as follows:

i. Section 680.26(C), entitled "Equipotential Bonding Grid," is amended to add the phrase "conform to the contours of the pool and shall" before the word "extend" and to add the words "within or" after the word "extend" in the first paragraph. Insert the following paragraph immediately following the first paragraph: "Exception: The equipotential bonding grid shall not be required to be installed under the bottom of or vertically along the walls of vinyl lined polymer wall, fiberglass composite, or other pools constructed of nonconductive materials. Any metal parts of the pool, including metal structural supports, shall be bonded in accordance with 680.26(B). For the purposes of this section, poured concrete, pneumatically applied (sprayed) concrete, and concrete block, with painted or plastered coatings, shall be considered conductive material."

ii. Section 680.26(C)(1), is amended to add the phrase "or deck" after the word "pool". Add a new last sentence as follows: "Where deck reinforcing steel is not an integral part of the pool, the deck reinforcing steel shall be bonded to other parts of the bonding grid using a minimum 8 AWG solid copper conductor. Connection shall be per 680.26(D)."

(c) A newly installed automatic lawn sprinkler system, where such systems are not prohibited by local ordinance, shall be equipped with an automatic rain sensor device or switch that will override the irrigation cycle of the automatic lawn sprinkler system when rainfall of more than one-half inch has occurred.

Amended by R.1981 d.132, effective May 7, 1981.

See: 13 N.J.R. 121(a), 13 N.J.R. 258(d).

Amended by R.1984 d.314, effective August 6, 1984.

See: 16 N.J.R. 1139(a), 16 N.J.R. 2084(b).

Section substantially amended.

Amended by R.1987 d.374, effective September 21, 1987.  
See: 19 N.J.R. 1024(a), 19 N.J.R. 1720(b).

Model subcode revisions.

Amended by R.1990 d.253, effective May 21, 1990.  
See: 22 N.J.R. 909(b), 22 N.J.R. 1554(a).

Amendments to (b)4i(2), ii(2).

Administrative Correction to (b)4i(2).  
See: 22 N.J.R. 2503(b).

Amended by R.1990 d.507, effective October 15, 1990.  
See: 22 N.J.R. 2208(a), 22 N.J.R. 3214(a).

Text conformed to BOCA National Code/1990.

Amended by R.1993 d.662, effective December 20, 1993.  
See: 25 N.J.R. 3891(a), 25 N.J.R. 5918(a).

Amended by R.1998 d.332, effective July 6, 1998.  
See: 30 N.J.R. 1377(a), 30 N.J.R. 2421(b).

Rewrote the section.

Amended by R.1998 d.362, effective July 20, 1998.  
See: 30 N.J.R. 1122(a), 30 N.J.R. 2644(b).

In (a), inserted a new 3.

Amended by R.2000 d.48, effective February 7, 2000.  
See: 31 N.J.R. 2317(a), 32 N.J.R. 445(a).

In (a), substituted references to 1999 for references to 1996 through-out, substituted a reference to One Batterymarch Park for a reference to Batterymarch Park in 1i, and inserted 2i; and in (b), inserted 1ii, inserted a new 3, recodified former 3 and 4 as 4 and 5, substituted a reference to line four for a reference to line three and substituted a reference to line six for a reference to line five in the new 4i, and substituted a reference to section 500-5(a)(4) for a reference to section 500-3(a)4 in the new 5i.

Amended by R.2003 d.187, effective May 5, 2003.  
See: 34 N.J.R. 4248(a), 35 N.J.R. 1939(c).

Rewrote the section.

Amended by R.2003 d.240, effective June 16, 2003.  
See: 34 N.J.R. 3045(a), 35 N.J.R. 2637(c).

Added (c).

Amended by R.2006 d.158, effective May 1, 2006.  
See: 37 N.J.R. 4105(a), 38 N.J.R. 1827(a).

In (a)1, (a)2 and (a)2.i, substituted "2005" for "2002"; also in (a)2.i, substituted "#06-2" for "#03-1"; in (a)3, substituted "C2-2002" for "C2-1997"; deleted (b)1 and recodified (b)2 through (b)6 as (b)1 through (b)5; in (b)4.ii, substituted "(2)" for "(1)", in (b)5iii(1), substituted "4" for "2"; in (b)5iii(2), substituted "V" for "VI" and "551.20" for "551.10"; and inserted (b)6.

Amended by R.2007 d.310, effective October 1, 2007.  
See: 39 N.J.R. 135(a), 39 N.J.R. 4113(b).

Added (b)7.

Amended by R.2007, d.384, effective December 17, 2007.  
See: 39 N.J.R. 2684(a), 39 N.J.R. 5211(a).

Added new (b)4ii; recodified former (b)4ii as (b)4iii; and in (b)4iii, substituted "(2)" for "(1)".

Amended by R.2008 d.213, effective August 4, 2008.  
See: 39 N.J.R. 2411(a), 40 N.J.R. 4523(b).

Rewrote (b)5iv.

#### Case Notes

Former N.J.A.C. 5:23-3.6 designated "National Electrical code of 1975" as controlling code; statute of limitations. *Brown v. Jersey Central Power and Light Co.*, 163 N.J.Super. 179 394 A.2d 397 (App.Div.1978) certification denied 79 N.J. 489 401 A.2d 244.

#### 5:23-3.17 Fire protection subcode

(a) Rules concerning the subcode adopted are as follows:

1. Pursuant to the authority of P.L. 1975, c. 217 as modified by P.L. 1996, c. 53, the Commissioner hereby adopts the following portions of the building, electrical, mechanical and fuel gas subcodes, to the extent delineated in N.J.A.C. 5:23-3.4, as the fire protection subcode for New Jersey.