

**State of New Jersey****DEPARTMENT OF LABOR AND INDUSTRY****HARRY C. HARPER, COMMISSIONER**

STATE HOUSE

TRENTON 7

PERCY A. MILLER, JR., COMMISSIONER AUGUST 2, 1948

MECHANICAL ENGINEERING BUREAU

HIGH PRESSURE STEAM BOILER INSTALLATIONS

THE FOLLOWING REGULATIONS ARE ISSUED PURSUANT TO THE AUTHORITY VESTED IN THE COMMISSIONER OF LABOR AND INDUSTRY, HIS DEPUTIES, BOARDS AND COMMISSIONS, UNDER TITLE 34 OF THE REVISED STATUTES:

1. WHEREVER POSSIBLE, HIGH PRESSURE BOILERS SHALL BE INSTALLED ABOVE GRADE OR STREET LEVEL.
2. HIGH PRESSURE STEAM BOILERS OR STEAM GENERATORS MAY BE INSTALLED IN A BASEMENT AND BELOW GRADE OR STREET LEVEL, PROVIDED: THERE IS AMPLE VENTILATION, EGRESSSES, SPACE AND INSULATION AGAINST FIRE HAZARDS.
3. SUCH BASEMENT INSTALLATIONS MUST BE APPROVED BY THE PROPER AUTHORITIES.

A. G. ERHOLM  
~~JOSEPH F. SCOTT~~  
 DEPUTY DIRECTOR

NJ/KAB  
 L1/M4  
 1948a  
 C.1